

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. *f6/DFS/MS/CNG/2015/573*

Dated: *21/04/15*

FIRE SAFETY CERTIFICATE

Certified that the CNG Station at Dilshad Garden, Delhi, comprising of ground floor only, owned/occupied by Indraprastha Gas Limited was issued NOC vide letter no-FS/(3A)/DFS/CNG/2005/374 dated-12/08/2005. The CNG station was re-inspected by the officer concerned of this department on 25/02/2015 in the presence of Mr. Prince Kumar, Dy. Manager of the CNG station (storage & dispensing unit) and found that the premises is deemed fit for occupancy CNG station for ground floor with effect from *21/04/15* for a period of **three** years, subject to conditions, printed overleaf.

Issued on *21/04/15* at New Delhi by



(Dr. G.C. Misra)
Chief Fire Officer
Ph.011-23414333

d/c

To,

The General Manager (Fire & Safety),
IGL Bhawan, Plot No-04, Community Center,
R.K. Puram Sector-09, New Delhi-110022

CONDITIONS

1. No trade susceptible to cause ignition to CNG by generating heat, mechanical/electrical spark should be allowed with in the licensed premises.
2. Overhead electrical cable and loose/naked wiring shall not be allowed across the licensed premises. The electrical equipments, electrical gadgets and fitting in the premises shall conform to hazardous area classification for that purpose and be of a type approved by the CCE.
3. In premises "No Smoking" signs board both in Hindi and English shall be displayed in such a manner as to be easily readable by all people.
4. All fire protection arrangements shall be maintained.
5. Nothing contravention of the explosive Act. 1884 and Rules their under 1983, and static and mobile pressure vessels (unfired) Rules 1981 as modified from time to time.
6. All comments/directions of the Chief Inspector of Explosives should always be permitted and followed.

1. Name & address of the building : CNG Dispensing Station at Dilshad Garden
Delhi by IGL
2. Building is comprised of : Ground floor
3. Type of Occupancy : CNG Storage & Dispensing Unit
4. Type of Case : **Renewal**
5. Details of Previous NOC / Site Clearance : FS/(3A)/DFS/CNG/2005/374 dated-12/08/2005
6. Fire Safety direction letter No : OISD-179
7. Date of Inspection : 25/02/2015
8. Name of the Inspecting officers : ADO Vijay Bahadur
9. Name and designation of Officer
from the building side : Mr. Prince Kumar (Dy. Manager)
10. Year of Construction : 2005
11. Applicant's letter No : IGL/F&S/2014-15/15/04, Dated- 09/12/14

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	As per Directives	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	12 mtr.	15 mtr.	MR
	• Gate width	4.5 mtr.	06 mtr.	MR
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	• Number of Staircases	N/A	N/A	N/A
	• Width of Staircases	N/A	N/A	N/A
03	Compartmentation.	Required	Provided	MR
04	Smoke Management System.	Required	Provided	MR
05.	Fire Extinguishers			
	• DCP type 10 Kg.	15 nos.	29 nos.	MR
	• DCP type 75 Kg.	03 nos.	11 nos.	MR
	• CO ₂ type 4.5 Kg.	04 nos.	04 nos.	MR
	• IS marking	ISI marked	ISI marked	MR
06	First-Aid-Hose Reels.			
	Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	Gas	Provided	MR
	• Location of main panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	Required	Provided	MR
08	MOEFA	N/A	N/A	N/A
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.	N/A	N/A	N/A
11	Internal Hydrants	N/A	N/A	N/A
12	Yard Hydrants.	N/A	N/A	N/A

13	Pumping Arrangements.			
	• Terrace Level	N/A	N/A	N/A
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the Pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
15	Exit Signage / No Smoking Signage	Required	Provided	MR
16	Provision of Lifts.	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
20	Special Fire Protection Systems			
	• CO ₂ DCP local application	Required	Provided	MR
	• Hand held explosive meter	02 nos.	Provided	MR

The fire protection systems provided in the CNG station were tested/checked and found functional at the time of inspection. The CNG station was issued NOC earlier vide letter no- FS/(3A)/DFS/CNG/2005/374 Dated-12/08/2005.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required as per OISD-179, renewal of Fire Safety Certificate is recommended.



Signature of the Inspecting Officer
Name- Vijay Bahadur
Designation- A.D.O

