

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/2015/ *NDZ/556*

Dated *20/04/15*

**FIRE SAFETY CERTIFICATE**

Certified that **Dharamshala for Dr. R.M.L. Hospital at Sarai Complex,mandir Marg,DIZ Area,New Delhi** comprised of **Ground + 3 upper floors** owned/ occupied by Dr. R.M.L. Hospital,New Delhi have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service on 13/03/15 in the presence of Sh. Dubey J.E. & that the building/premises is fit for occupancy of class Group A Sub Division C-I ground + 3 upper floor with effect from ~~20/04/15~~ for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on *20/04/15*..... at New Delhi by.



(Dr. G.C. Misra)  
Chief Fire Officer  
Delhi Fire Service  
Ph: - 011-23414333

Copy to:-

1. Sh. Alok Kumar Sanyal,  
Assistant Architect,  
Ministry of Health & Family Welfare,  
Nirman Bhawan,New Delhi.
2. Dr. V.K. Sabharwal,  
Additional Medical Suptd.,  
PGIMER & Dr. R.M.L. Hospital, New Delhi.

*ok*  
*mn*

**Condition for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

## INSPECTION REPORT

1. Name & address of the building : Dharmshala for Dr. R.M.L Hospital at Sarai Complex, at Mandir Marg, DIZ Area, New Delhi.
2. Type of Occupancy : New Building ( Ground + 3 upper floor) LR 13.35 mtr.
3. Type of Case : Fresh
4. Details of previous NOC : NA
5. Fire Safety directives Letter No. : F6/DFS/MS/2007/1598 dated 15/06/2007
6. Date of inspection : 13/03/2015
- 7 Name of the Inspecting Officer : Sh. M. K. Sharma (ADO/CC)
- 8 Name and designation of Officer  
from the building side : Sh. Dubey JE
- 9 Year of Construction : 2007
10. Applicant's letter No. : No. Nil1 Dated 09/02/15

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements	Provided at site	Remarks
1.	Access of building			MR/NMR
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	6 Mtr.	12 Mtr.	MR
		5 Mtr.	5 Mtr.	MR
		6 Mtr.	6 Mtr.	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper floors</li> <li>• Basements</li> </ul>	1 Nos.	1 Nos.	MR
		NA	NA	NA
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper floors</li> <li>• Basements</li> </ul>	1.5 mtr.	2 mtr.	MR
		NA	NA	NA
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	NA	NA	NA

	<ul style="list-style-type: none"> <li>• Pressurization</li> </ul>	NA	NA	NA
	d. No of continuous staircase to terrace	1 Nos.	1 Nos.	MR
	e. Width of Corridor	1.5Mtr.	2 Mtr.	MR
	f. Door Size	1 Mtr.	1 Mtr.	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Sealing of electrical shafts</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Water Curtain</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Fire Dampers</li> </ul>	NA	NA	NA
4	Smoke managements System			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	30 ACPH	NA	NA
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	12 ACPH	NATURAL	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> </ul>	12 Nos.	15 Nos.	MR
	<ul style="list-style-type: none"> <li>• Types</li> </ul>	ABC, CO <sub>2</sub> , Wco <sub>2</sub>	ABC, CO <sub>2</sub> , Wco <sub>2</sub>	MR
	<ul style="list-style-type: none"> <li>• IS marking</li> </ul>	YES	Provided	MR
6	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>	02	02	MR
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>	30 Mtr.	30 Mtr.	MR
	<ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>	05 MM	05 MM	MR
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Hooters' Location</li> </ul>	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler			

	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> <li>Size of riser/down- comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main pump</li> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>auto Staring/Manual stopping</li> <li>Pump House Access</li> <li>Terrace level</li> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power supply</li> <li>Auto starting of pump</li> </ul>			
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 LPM	450 LPM	MR
		35 mtr.	35 mtr.	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> <li>Under ground tank capacity</li> <li>Draw of connection</li> <li>Fire service inlet</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA

	<ul style="list-style-type: none"> <li>• Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	NA 5000 ltr.	NA 5000 ltr.	NA MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of lift lobby</li> <li>• Communication in lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	NA NA Required Required Required	NA NA Provided Provided Provided	NA NA MR MR MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> <li>• Total area</li> <li>• Location</li> </ul>	NA NA	NA NA	NA NA
19	Fire control room			
	<ul style="list-style-type: none"> <li>• Detector system panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	Co2 & ABC	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rule it is recommended to grant fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / is recommended.

Signature of the Inspecting Officer

*M.K. Sharma*  
07/4/15

Name:-M.K.Sharma

Designation :- A. D.O. (CC)