

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/2015/W2/534

Dated: 15/04/15

FIRE SAFETY CERTIFICATE

Certified that the Gopal Heights, located at Plot no. D-9, Netaji Subhash Place, Pitam Pura, Delhi - 110034, comprised of One Blocks (B+G+13 Upper Floor) was issued FSC vide Letter No. F6/DFS/MS/2010/2021 dated 09-07-2010. The premises was re inspected by the officers concerned of this department on 03-03-2014 in the presence of Mr. Nirmal Kr Sharma (Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Mercantile & Business Building" Group F & Group E with effect from 15/04/15 for a period of three years in accordance with rule 36, unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 15/04/15 at New Delhi by.


(Santosh Singh)
Chief Fire Officer
Delhi Fire Service
Tel.No. - 23414250

Copy to:

Sh Nirmal Kr Sharma (Manager), Gopal Heights, Plot no. D-9, Netaji Subhash Place, Pitam Pura, Delhi - 110034.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire-Service Rules 2010, form is available on www.dfs.delhi.govt.nic.in.

INSPECTION REPORT

1. Name & address of the building : Gopal Heights, Plot no. D-9, Netaji Subhash Place, Pitam Pura, Delhi – 110034.
2. Type of Occupancy : Mercantile + Business (Mixed), one Block (B+G+13 Upper floor)
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F6/DFS/MS/2010/2021 dated 09-07-2010
5. Fire Safety directives Letter No. : Letter No. F6/DFS/MS/BP/2007/595 dated 28-02-2007
6. Date of inspection : 27-02-2015
7. Name of the Inspecting Officer : DO (West) & ADO (WP)
8. Name and designation of Officer
from the building side : Sh. Nirmal Kr Sharma (Mangar)
9. Year of Construction : 2008
10. Applicant's letter No. : Form J dated Nil

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	50 m	Provided	MR
	• Gate width	6 m	Provided	MR
	• Width of internal road	6 m	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	2	Provided	MR
	b. Width of staircases			
	• Upper floors	1X150cm & 1X125 cm	Provided	MR
	• Basements	1X150cm & 1X 125 cm	Provided	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	2	Provided	MR
	e. Width Of Corridor	2 mtr	Old case	MR
	f. Door Size	01 mtr	Old Case	MR

3.	Compartmentation		Required	Provided	MR
	<ul style="list-style-type: none"> • Fire check door 		Required	Provided	MR
	<ul style="list-style-type: none"> • Sealing of electrical shafts 		Required	Provided	MR
	<ul style="list-style-type: none"> • Fire Rating of shaft door 		NR	NR	NR
	<ul style="list-style-type: none"> • Water Curtain 		Required	Provided	MR
	<ul style="list-style-type: none"> • Fire Dampers 				
4.	Smoke managements System				
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour		Provided	MR
	<ul style="list-style-type: none"> • Upper floors 	Required		Provided	MR
5.	Fire Extinguishers				
	<ul style="list-style-type: none"> • Total numbers 	48 nos.		Provided	MR
	<ul style="list-style-type: none"> • Types 	CO ₂ & WCO ₂		Provided	MR
	<ul style="list-style-type: none"> • IS marking 	ISI marked		Provided	MR
6.	First – Aid Hose Reels				
	<ul style="list-style-type: none"> • Total numbers on each floor 	2		Provided	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 m		Provided	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	5 mm		Provided	MR
7.	Automatic fire detection and alarming system				
	<ul style="list-style-type: none"> • Type of detectors 	Smoke & Heat		Provided	MR
	<ul style="list-style-type: none"> • Location of Main Panel 	Required		Provided	MR
	<ul style="list-style-type: none"> • Location of Repeater Panel 	Required		Provided	MR
	<ul style="list-style-type: none"> • Alternate source of power 	Required		Provided	MR
	<ul style="list-style-type: none"> • Hooters' Location 	Required		Provided	MR
8.	MOEFA		Required	Provided	MR
9.	Public Address System		Required	Provided	MR
10.	Automatic Sprinkler System				
	<ul style="list-style-type: none"> • Basements 	Required		Provided	MR
	<ul style="list-style-type: none"> • Upper Floor 	Required		Provided	MR
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	Required		Provided	MR
11.	Internal Hydrants				
	<ul style="list-style-type: none"> • Size of riser/down- comer 	150 mm		Provided	MR
	<ul style="list-style-type: none"> • Number of hydrants per floor 	2		Provided	MR
	<ul style="list-style-type: none"> • Hose Box 	Required		Provided	MR
12.	Yard Hydrants				
	<ul style="list-style-type: none"> • Total number of hydrants 	Required		Provided	MR
	<ul style="list-style-type: none"> • Hose Box 	Required		Provided	MR

13.	Pumping Arrangements(All the pump are connected with DG set)			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	2850 lpm	Provided	MR
		75 m	Provided	MR
		2	Provided	MR
		180 lpm	Provided	MR
		75 m	Provided	MR
		2850 lpm	Provided	MR
		75 m	Provided	MR
		Required	Provided & Functional	MR
		Required	Provided	MR
		900lpm	Provided	MR
		75m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	2,00,000 litres	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		20, 000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts(Lift Terminate at Ground Floor)			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	Old Case	Old Case	MR
	➤ Location	5 th , 7 th & 12 th Floor	Provided	MR
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR

N-2

20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	Provided FM 200	MR
-----	--	----------	--------------------	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/2010/2021 dated 9/07/2010 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

~~Signature of the Inspecting Officer~~

Signature of the Inspecting Officer

Name

Uday V K Singh

Name

Designation

ASD/WP

Designation