

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

Fax:-011-23412593

E-mail ID: director.dlfire@nic.in

No. F6/DFS/MS/GH/2015/ND2/541

Dated 17/04/15

FIRE SAFETY CERTIFICATE

Certified that the **Hotel Marry Gold** located at **1623-24, Raj Pura Road, Chuna Mandi, Pahar Ganj, New Delhi** comprises of **Basement+Ground + 3upper floor,(With 16guest room)** was granted NOC by this department vide letter No.F6/DFS/MS/GH/2011/1748 dated 29-07-2011. The premises was re-inspected by the officer concerned of this department on 15-03-2015 in the presence of Mr. Rajive (Manager) and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Sub Division-A-1 Lodging or Rooming House of Group - A** for 12 Guest room at first floor to third floor with effect from ~~17/04/15~~ 17/04/15 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 17/04/15 at New Delhi by.


(**Dr. G.C. Misra**)
Chief Fire Officer
Delhi Fire Service
Ph-011-23414333

Copy to:-

1. Mr. Rajive (Manager) Hotel Marry Gold located at 1623-24, Raj Pura Road, Chuna Mandi, Pahar Ganj, New Delhi.
2. The Addl. Commissioner of police (Lic), 1st floor, P S Defence colony, New Delhi for information.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form K provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry"

INSPECTION REPORT

1. Name & address of the building : **Hotel Marry Gold** at 1623-24, Raj Guru Road, Chuna Mandi, Pahar Ganj, New Delhi.
...
2. Type of Occupancy : Residential (Guest house) B+G+3floors (12 Guest rooms)
3. Type of Case : **Renwal**
4. Details of previous NOC : F6/DFS/MS/GH/2011/1748 dated 29/07/2011
5. Fire Safety directives Letter No. : NA
- 6 Date of inspection : 15/03/2015
- 7 Name of the Inspecting Officer : M. K. Sharma (Assistant Divisional Officer)
- 8 Name and designation of Officer
from the building side : Sh. Rajive (Manager)
- 9 Year of Construction : 2008
10. Applicant's letter No. : 24411/Joint. C.P./Lic.(H) dated, New Delhi the 08/07/2014.

S No	Minimum standards on fire prevention and fire safety U/R 33	Existing Requirements	Provided at site	Remarks Old Case MR/NMR
1.	Access of building			
	• Road width	NA	9mtr.	NA
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1 No.	1 No.	MR
	• Basements	1 No.	1 No.	MR
	b. Width of staircases			
	• Upper floors	0.80 Mtr.	1.05 Mtr.	MR
	• Basements (100 SQM)	1.0mtr	1.0mtr.	MR
	c. Protection of exits			
	Fire check door	NA	NA	NA
		NA	NA	NA

	<ul style="list-style-type: none"> • Pressurization 	NA	NA	NA
	d. No of continuous staircase to terrace	01	01	MR
	e. Width Of Corridor	1.0 Mtr.	1.0 Mtr.	MR
	f. Door Size	1.0mt.	1.25mt.	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	30 ACPH	Mechanical	MR
	<ul style="list-style-type: none"> • Upper floors 	12 ACPH	NATURAL	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	10 Nos.	12 Nos.	MR
	<ul style="list-style-type: none"> • Types 	ABC, CO ₂ , Wco ₂	ABC, CO ₂ , Wco ₂	MR
	<ul style="list-style-type: none"> • IS marking 	Required	Provided	MR
6	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	01	01	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 mtr.	30 mtr.	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	05 mm	05 mm	MR
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> • Hooters' Location 	NA	NA	NA
8	MOEFA	NA	Provided	NA
9	Public Address System	NA	Provided	NA
10	Automatic Sprinkler			
	<ul style="list-style-type: none"> • Basements 	NA	Provided	NA

	Upper floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements			
	○ Ground Level			
	• Discharge of main pump	NA	NA	NA
	• Head of main pump	NA	NA	NA
	• Number of main pumps	NA	NA	NA
	• Jockey pump out put	NA	NA	NA
	• Jockey pump head	NA	NA	NA
	• Standby Pump out put	NA	NA	NA
	• Standby Pump Head	NA	NA	NA
	• auto Staring/Manual stopping	NA	NA	NA
	• Pump House Access	NA	NA	NA
	○ Terrace level			
	• Discharge of pump	NA	180 LPM Exiting	NA
	• Head of the pump	NA	30 Mtr.	NA
	• Power supply	Required	Provided	MR
	• Auto starting of pump	NA	Provided	NA
14	Captive water Storage for fire fighting			
	• Under ground tank capacity	NA	NA	NA
	• Draw of connection	NA	NA	NA
	• Fire service inlet	NA	NA	NA
	• Access to tank	NA	NA	NA

219

	<ul style="list-style-type: none"> Overhead Tank capacity 	2500 ltr.	2500ltr.	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	NA	NA	NA
	<ul style="list-style-type: none"> Pressurization of lift lobby 	NA	NA	NA
	<ul style="list-style-type: none"> Communication in lift Car 	NA	NA	NA
	<ul style="list-style-type: none"> Fireman's Grounding Switch 	NA	NA	NA
	<ul style="list-style-type: none"> Lift Signage 	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area			
	<ul style="list-style-type: none"> Total area 	NA	NA	NA
	<ul style="list-style-type: none"> Location 	NA	NA	NA
19	Fire control room			
	<ul style="list-style-type: none"> Detector system panel 	NA	NA	NA
	<ul style="list-style-type: none"> Flow Switch Panel 	NA	NA	NA
	<ul style="list-style-type: none"> PA System Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Batter backup 	NA	NA	NA
	<ul style="list-style-type: none"> Building Floor Plans 	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC,CO ₂	MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no.

F6/DFS/MS/GH/2011/1748 dated 29/07/2011 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer

M.K. Sharma
8/4/15

Name :- M.K. Sharma

Designation :- A. D.O. (CC)

no lead
loc. hand