

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110 001.**

E-mail:- [cfohq.dlfire@nic.in](mailto:cfohq.dlfire@nic.in)

Fax:- 011-23412593

No. F.6/DFS/MS/GH/2015/ 52/585

Dated: 22/04/15

**FIRE SAFETY CERTIFICATE**

Certified that the **Hotel Mohini Palace** located at 14B/35, Pyare Lal Road, Dev Nagar, Karol Bagh, New Delhi-110005 is comprised of Basement, Ground Floor plus three upper floors, using basement as hall/storage, ground floor as reception, office & 01 guest room, first & second floor each having 05 guest rooms respectively, third floor having 01 guest room & a pantry for staff (Total 12 guest rooms) was issued NOC by this department vide letter No.F.6/DFS/MS/GH/2012/985 dated 20.03.2012 owned/ occupied by Sh. Harpreet Walia. The guest house building was re- inspected by the officers concerned of this department on 15.04.2015 in the presence of Sh. Jagan Parsad and found that the owner have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class residential w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....22/04/15..... at New Delhi.



(DR. G.C. MISRA)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE  
Ph:- 011-23414333

Copy to:-

1. The Joint Commissioner of Police (Lic.)  
1<sup>st</sup> floor, P.S., Defence Colony, New Delhi.  
(Re. No.3797/Joint C.P./Lic.(H), Dated 24.02.2015)
2. Sh. Harpreet Walia (Owner)  
Hotel Mohini Palace, 14B/35,  
Pyare Lal Road, Dev Nagar,  
Karol Bagh, New Delhi – 110005.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The basement shall be used strictly as per the provisions of the building bye laws.
7. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

M/23.

Basement, Ground Floor plus three upper floors.

**INSPECTION REPORT**

1. Name & address of the building : Hotel Mohini Palace, 14B/35, Pyare Lal Rd., Dev Nagar, Karol Bagh, ND-05.
2. Type of Occupancy : Residential (Guest House)
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. F.6/DFS/MS/GH/2012/985 Date 20.03.2012
5. Fire Safety directives letter No : —
6. Date of inspection : 15.04.2014
7. Name of Inspecting Officer : D.O S.K. Tomar & A.D.O P.S. Sahiya
8. Name and designation of officers  
From the building side : Sh. Jagan Parsad
9. Year of Construction : Before 2002
10. Applicant's letter No. : 3797/Joint C.P/LIC.(H) dated 24.02.2015

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks
1.	Access to building			MR/NMR
	• Road width	Accessible	09 mtr	MR
	• Gate width	—	102 cms	MR
	• Width of internal road	—	—	—
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	One	One	MR
	• Basements	Two	Two	MR
	b. Width of staircases			
	• Upper Floor	—	103 cms	MR, Old Case
	• Basements	—	110 cms, 70 cms	- do -
	c. Protection of exits			
	• Fire check door	—	—	—
	• pressurization	—	—	—
	d. No. of continuous staircases to terrace	—	One	—
	e. Width of Corridor	—	157 cms,	—
	f. Door Size	—	80 cms x 200 cms	—
3.	Compartmentation			
	• Fire check door	—	—	—
	• Sealing of electrical shafts	—	Sealed	—
	• Fire Rating of shaft door	—	—	—
	• Water Curtain	—	—	—
	• Fire Dampers	—	—	—
4.	Smoke Management System			
	• Basements	30 a/c per hour	Exhaust Fans are Provided	MR
	• Upper floors		Natural Ventilation	MR

N/24

		12 a/c per hour	-	-
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	Two at each Floor ABC, Co <sub>2</sub> ISI marked	Provided - do - ISI Marked	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	N/R 30 m 5 mm	Provided - do - - do -	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	-	-	-
8.	MOEFA			
		N/R	Provided	MR
9.	Public Address System			
		N/R	- do -	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	N/R - -	Provided - -	MR, Area less than 200 sq. m - -
11.	Internal Hydrants			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	-	-	-
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	-	-	-
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/Manual stopping</li> </ul>	-	-	-

M/25

14B/35, Pyare Lal Road, Dev Nagar,  
Korol Bagh, New Delhi - 110005.

	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul>	—	—	—
		NIR	180 LPM	MR
		NIR	30M	MR
		—	—	—
		—	—	—
<b>14.</b>	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	—	—	—
		—	—	—
		—	—	—
		—	—	—
		NIR	2000 Ltr	MR
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16.</b>	<b>Provision of Lifts:</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	—	—	No Lift
		—	—	-do-
		—	—	-do-
		—	—	-do-
		—	—	-do-
<b>17.</b>	<b>Standby power supply</b>	Required	D.G. Set of 10kVA	MR
<b>18.</b>	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	—	—	—
		—	—	—
<b>19.</b>	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
<b>20.</b>	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	—	—	—

N/26.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/GH/2012/985 dated 20.03.2012 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.


Note:- The Guest House having 12 Guest rooms hence No Fire safety is required except Fire Extinguishers as safety measures.

  
17/1/15

Signature of Inspecting Officer

Name S.K. Tomar

Designation Divisional Officer

  
16/4/15

Signature of Inspecting Officer

Name P.S. Dahiya

Designation Asstt. Divisional Officer.