

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F.6/DFS/MS/2014/ School/w2/562

Dated: 21/04/2015

FIRE SAFETY CERTIFICATE

Certified that **Indraprastha Public School, A-3, Rajiv Nagar, Begum Pur, Opp. Sector-22, Rohini, Delhi-110086** comprised of **Ground + Two Upper Floor** owned/occupied by **Indraprastha Public School** has already been issued fire safety certificate **vide letter no. F-6/DFS/MS/2011/2008 dated 17/08/2011.** The premises now comprise of **ground + three upper floor** and was re-inspected by the officer from this department on dated **26/12/2014** in the presence of **Sh. Ashok Kumar (Manager)** and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of **Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011** issued by Director of Education and the building / premise is fit for occupancy of **Group Class B (Educational)** with effect from **21/04/2015** for a period of **three years**, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 21/04/15 at New Delhi by


SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:

1. The Principal, Indraprastha Public School, A-3, Rajiv Nagar, Begum Pur, Opp. Sector-22, Rohini, Delhi-110086
2. The Director of Education, Old Secretariate, Delhi

Previous - Gr + two floor
Present - Gr + Three floor

INSPECTION REPORT

1. Name & address of the building : Indraprastha Public School, A-3, Raj-eev Nagar
2. Type of Occupancy : Educational Begampur opp. sec. 22 Rohini
3. Type of Case : New Case/ Renewal Delhi-86
4. Details of previous NOC : Letter No. E6/DFS/MS/2011/2008 Dated: 17.8.11
5. Fire Safety directives letter No : Dir. of Edu. Cir. 01.03.2011
6. Date of inspection : 17.3.15
7. Name of the Inspecting Officers : ADO (BW)
8. Name and designation of officers from the building side : Sh. Ashok Kumar Manager
9. Year of Construction : 2005 & 2013
10. Applicant's letter No. : DPS/2014-15 Dt-5-11-14

Plot Area: 4184sqm Covered Area: 2500sqm No. of Students: 666 No. of Class Rooms: 40
13 room for other purpose.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<u>Accessible</u>	<u>Accessible</u>	<u>MR</u> ✓
	• Gate width	<u>do</u>	<u>do</u>	<u>MR</u> ✓
	• Width of internal road	<u>-</u>	<u>-</u>	<u>-</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	<u>-</u>	<u>-</u>	<u>-</u>
	• Upper Floors	<u>02</u>	<u>02</u>	<u>MR</u> ✓
	• Basements	<u>-</u>	<u>-</u>	<u>-</u>
	b. Width of staircases	<u>-</u>	<u>-</u>	<u>-</u>
	• Upper Floors	<u>1.50 mtrs each</u>	<u>1.50 mtrs each</u>	<u>MR</u> ✓
	• Basements	<u>-</u>	<u>-</u>	<u>-</u>
	c. Protection of exits	<u>-</u>	<u>-</u>	<u>-</u>
	• Fire check door	<u>-</u>	<u>-</u>	<u>-</u>
	• Pressurization	<u>-</u>	<u>-</u>	<u>-</u>
	e. No. of continuous staircases to terrace	<u>R</u>	<u>P</u>	<u>MR</u> ✓
	g. Width of Corridor	<u>-</u>	<u>-</u>	<u>-</u>
	h. Door Size	<u>old case 1st & 2nd floor</u> <u>1.00 mtrs</u>	<u>old case</u> <u>1.00 mtrs</u>	<u>old case -</u> <u>MR</u> ✓

3	Compartmentation.				
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 				
4	Smoke Management System.				
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour			
5	Fire Extinguishers				
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	14 ABC ISI marked	14 ABC gas	MR ✓ MR ✓ MR ✓	
6	First-Aid Hose Reels.				
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	one 30 m 5 mm	P P P	MR ✓ MR ✓ MR ✓	
7	Automatic fire detection and alarming system.				
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 				
8	MOEFA				
9	Public Address System.				
10	Automatic Sprinkler System.				
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 				
11	Internal Hydrants				
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 				

12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 			
	<ul style="list-style-type: none"> Hose Box 			
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 			
	<ul style="list-style-type: none"> ➤ Head of Main pump 			
	<ul style="list-style-type: none"> ➤ Number of main pumps 			
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 			
	<ul style="list-style-type: none"> ➤ Jockey pump head 			
	<ul style="list-style-type: none"> ➤ Standby Pump out put 			
	<ul style="list-style-type: none"> ➤ Standby Pump Head 			
	<ul style="list-style-type: none"> ➤ Auto Starting/ Manual stopping 			
	<ul style="list-style-type: none"> ➤ Pump House Access 			
	<ul style="list-style-type: none"> Terrace level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump 	450CPH	P	MR ✓
	<ul style="list-style-type: none"> ➤ Head of the pump 	40M	P	MR ✓
	<ul style="list-style-type: none"> ➤ Power Supply 	—	—	—
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	—	—	—
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity 			
	<ul style="list-style-type: none"> ➤ Draw-off connection 			
	<ul style="list-style-type: none"> ➤ Fire service inlet 			
	<ul style="list-style-type: none"> ➤ Access to tank 			
	<ul style="list-style-type: none"> Overhead Tank capacity 	10,000Lts	P	MR ✓
15	Exit Signage.	R	P	MR ✓
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 			
	<ul style="list-style-type: none"> Pressurization of Lift lobby 			
	<ul style="list-style-type: none"> Communication In lift Car 			
	<ul style="list-style-type: none"> Fireman's Grounding Switch 			
	<ul style="list-style-type: none"> Lift Signage 			
17	Standby power supply			

18	Refuge Area.			
	➤ Total Area			
	➤ Location			
19	Fire Control Room			
	• Detector System Panel			
	• Flow Switch Panel			
	• PA System Panel			
	• Batter backup			
	• Building Floor Plans			
20	Special Fire Protection Systems for Protection of special Risks, if any:			

Note:-General requirements for school as per Director of Education Circular dated 01/03/2011

1. Escape route..... *clear*
2. LPG cylinders in laboratories *Nb*
3. Electric wiring *concealed* MCB and ELCB *provided*
- Electric circuit.....
4. Electric meter board *not below SIC*
5. Basement use as per BBL 1983..... *N/A*
6. Emergency telephone no. board..... *displayed*
7. Generator set..... *Nb*

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. *F-6/DA-5/MS/2011* dated *17.8.11* renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended. *2008*

Signature of the Inspecting Officer

Name

Signature of the Inspecting Officer

Name

Designation

Jhokan
25.3.15

IAO(BW)