

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/EH/2015/ ND2/535

Dated 15/04/15

FIRE SAFETY CERTIFICATE

Certified that the **Open House Bar + Kitchen (A Unit of Jv Café Private Limited)** located at **First Floor, Atma Ram House, C-37, Connaught Place New Delhi** building is comprised of **Ground + 2 floor (Open House Bar + Kitchen at first floor)** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service on **06/04/15** in the presence of **Mr. Shashi** that the premises is fit for occupancy of class **Assembly Building Group-D** for first floor only with effect from ~~---~~ **15/04/15** for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on **15/04/15** at New Delhi by.



(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service
Ph: - 011-23414333

Copy to:-

1. Dr. P.K. Sharma, Medical Officer of Health, Health Department, New Delhi Municipal Council Palika Kendra, New Delhi.
2. The Manager, Open House Bar + Kitchen (A Unit of Jv Café Private Limited) First Floor, Atma Ram House, C-37, Connaught Place New Delhi

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT

1. Name & address of the building:- Open House Bar + Kitchen(A Unit of Jv Café Private Limited) First Floor, Atma Ram House, C-37, Connaught Place New Delhi
2. Type of occupancy:- Group – D Assembly Building (Ground + 2 upper floors)
3. Type of case:- New
4. Details of previous NOC:- NA
5. Fire safety directives No.- NA
6. Date of inspection:- 06/04/15
7. Name of the inspecting officer:- D.O. Gurmukh Singh & A.D.O. Manoj Kumar
8. Name & designation of officer
From the building side:- Mr. Shashi
9. Year of construction:- Old Heritage Building 1927
10. Applicant's letter No:- No.MOH/D/483/(Licensing)/S1-1 dated 23/03/15

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	9 mtr.	18mtr.	MR
	2) Gate width	2 gate	1.27&1.65 Mtr	MR
	3)Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 Nos	2 Nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.25 mtr. & 1 Mtr.	1.25 Mtr. & 1.04 Mtr.	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	Required	one	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	2 mtr.	2 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	N/A	N/A

	2) Upper floors	12 a/c per hour	Exhaust fan provided	MR
5.	Fire Extinguishers			
	1) Total numbers	07 Nos.	07 Nos.	MR
	2) Types	CO2 & W.CO2	ABC, Co2 & W.Co2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	Required	1 No	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	NA	NA	NA
	2) Location of main panel	NA	NA	NA
	3) Location of repeater panel	NA	NA	NA
	4) Alternate source of power	NA	NA	NA
	5) Hooter's Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm.	100 mm.	MR
	2) Number of hydrants per floor	1 No.	1 No at ground floor	MR
	3) Hose box	1 Nos.	1 Nos.	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A

13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	40 mtr.	40 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR

Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A
	a) Draw-off connection	N/A	N/A
	b) Fire service inlet	Required	Provided
	c) Access to tank	NA	NA
	d) Over head tank capacity	15,000 ltrs.	15,000 Ltr.
15.	Exit Signage.	Required	Provided
16.	Provision of Lifts.		
	a) Pressurization of lift shaft	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A
	c) Communication in lift car	N/A	N/A
	d) Fireman's switch	N/A	N/A

	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, grant of fire Safety Certificate, under rule 35 of the Delhi Fire Service Rules 2010, is recommended please.

Gurmukh Singh
8/11/15
Gurmukh Singh
Divisional Officer

Manoj Kumar Sharma
31/11/15
Manoj Kumar Sharma
Assistant Divisional Officer