

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

Fax: 011-23412593, Ph. 011-23414333

NO. F6/DFS/MS/Indl/2015/SZ/ 520

DATED: 10/04/15

FIRE SAFETY CERTIFICATE

Certified that Richa Fashion Pvt. Ltd at F-23/2, Okhla Industrial Area, Phase-II New Delhi-110020 comprised of basement, ground mezzanine floor, first floor and one room at second floor was granted NOC by this department vide letter No. F6/DFS/MS/2012/1428 Dated 20.4.2012. The premises was re-inspected by the officer concerned of Delhi Fire Service on 23.03.2015 in the presence of Sh. Sunil Kumar Jain (Director) of the factory and observed that fire safety norms as required under Rule 33 of Delhi Fire Service Rules, 2010 are deemed complied and that the building / premises is fit for occupancy class G "Industrial building" with effect from 10/04/15..... for a period of **three years**, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010.

Issued on 10/04/15..... at New Delhi by


(Dr. G.C. Misra)
Chief Fire Officer

Copy to,

1. The Executive Engineer (Bldg) HQ, Building Department, MCD, Town Hall, Delhi.
2. Sh. S.K. Jain (Director), Richa Fashion Pvt. Ltd at F-23/2, Okhla Industrial Area, Phase-II New Delhi-110020.

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The basement shall be used strictly as per the provisions of Building Bye laws.
- e. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on www.dfs.delhigovt.nic.in
- f. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

1	Name & address of the building	Richa Fashion Pvt. Ltd., at Plot No F-23/2, Okhla Industrial Area, Phase-II New Delhi		
2	Type of Occupancy	Industrial building "G"		
3	Type of case	Renewal		
4	Details of previous NOC	F6/DFS/MS/2012/1428 Dated 20.4.2012		
5	Fire safety directives letter No	F6/DFS/MS/BP/1990/803 dated 17.05.1990		
6	Date of inspection	23.03.2015		
7	Name of the inspecting Officers :	DO Dharampal Bhardwaj, ADO D.B. Mukherjee		
8	Name and designation of officers from the building side	Mr. Sunil Kumar Jain (Director)		
9	Year of construction	1990		
10	Applicant's letter No.	Nil dated 20.2.2015	basement, ground , mezzanine floor, first floor and one room at second floor	
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	20 Mtr	Provided	MR
	2) Gate width	5 Mtr	Provided	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	Required	Two Provided	MR
	2. basements	Required	Two Provided	MR
	b. Width of staircase			
	1. Upper floors	1.25 Mtr	1.5 Mtr & 1.19 Mtr Provided	MR
	2. basements	1.25 Mtr	1.5 Mtr & 1.12 Mtr Provided	MR
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1 Mtr	Provided	MR
3	Compartmentation.			
	1. Fire check door	Required	Open Sky	MR
	2. Sealing of electrical shafts	Required	Provided	MR
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	30 a/c per hour	12 Exhust Fan Provided	MR
	upper floors	a/c per hour		Natural Ventilation
5	Fire Extinguishers			
	total numbers		25 Nos. Provided	MR
	Types		ABC, CO2	MR
	ISI marking	ISI	Provided	MR

6	First-Aid Hose Reels.			
	total numbers on each floor	One	Provided	MR
	Length of Hose reel hose	30 Mtr	Provided	MR
	Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system			
	Type of detectors	Required	Smoke & Heat Provided	MR
	location of Main Panel	Required	Ground Provided	MR
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	Required	Battery Backup Provided	MR
	hooter's location	Required	Staircase Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	Required	Provided	MR
	upper floors	Required	Provided	MR
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	150 MM	Provided	MR
	Number of Hydrants per floor	Required	One Provided	MR
	hose Box	Required	One Provided	MR
12	Yard Hydrants.			
	total number of hydrants	Required	Four Provided	MR
	house box	Required	Four Provided	MR
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	2280 LPM	Provided	MR
	b. Head of main pump	60 Mtr	Provided	MR
	c. Number of main pumps	One	Provided	MR
	d. jockey pump out put	180 LPM	Provided	MR
	e. jockey pump head	60 Mtr	Provided	MR
	f. Standby Pump output	2280 LPM	Provided	MR
	g. Stanby Pump head	60 Mtr	Provided	MR
	h. Auto Starting/Manual stopping	Required	Both Provided	MR
	pump house access	Provided	Provided	MR
	2. Terrace level			
	a. Discharge of pump	900 LPM	Provided	MR
	b. head of the pump	40 Mtr	Provided	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	75,000 ltr	Provided	MR
	a. Draw-off connection	Required	Provided	MR
	b. fire service inlet	Required	Provided	MR
	c. Access to tank	Required	Provided	MR
	Over head tank Capacity	20,000 ltr	Provided	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of lifts.	N/A		
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. Detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: No			

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules of NOC issued vide letter no. **F6/DFS/MS/2012/1428 Dated 20.4.2012** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Accordingly DFA is put up for your approval and signature please.

Signature of the inspecting officer
 Name Dharampal Bhardwaj
 Designation : Divisional Officer

Signature of the Inspecting Officer
 Name D.B. Mukherjee
 Designation ADO (BCP)