

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No.F.6/DFS/MS/School/2015/52/550

Dated: 17/04/15

FIRE SAFETY CERTIFICATE

Certified that the building of **SDMC Primary Model School**, Deendar Pur I/II, Najafgarh, New Delhi-110043, is comprised of ground floor plus two upper floors, but school is running at ground plus one upper floor only. The school is owned/occupied by the school management was inspected by the officer concerned of this department on 07.04.2015 in the presence of Smt. Usha Devi (Principal) and found that the school management have complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the school building/ premises (**Ground plus one upper floor**) is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed as under.

Issued on.....17/04/15..... at New Delhi.

(DR. G.C. MISRA)

CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to:-

1. The Principal,
SDMC Primary Model School, Deendar Pur I/II,
Najafgarh, New Delhi-110043.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi - 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

Ground plus two upper floors but school running at ground plus one upper floor only
(SDMC Primary Model School, Deendar Pur I/II, Najafgarh, New Delhi-110043)

INSPECTION REPORT

1. Name & address of the building : SDMC Primary Model School, Deendar Pur I/II, Najafgarh, New Delhi-110043.
2. Type of Occupancy : Educational
3. Type of Case : New
4. Details of Previous NOC : N/A
5. Fire Safety directives letter No : N/A
6. Date of inspection : 07.04.2015
7. Name of Inspecting Officer : A.D.O. Sandeep Duggal
8. Name and designation of officers
From the building side : Smt. Usha Devi (Principal)
9. Year of Construction : 2013-2014
10. Applicant's letter No. : Letter No. Nil dated 09.03.15

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | Dir. Of Edu. Circular dt. 01.03.2011 | Provided at site | Remarks MR/NMR |
|--------|---|--|--|--|
| 1. | Access to building | | | |
| | <ul style="list-style-type: none"> • Road width • Gate width • Width of internal road | <p>Accessible</p> <p>—</p> <p>—</p> | <p>09 mtrs</p> <p>04 mtrs.</p> <p>—</p> | <p>M/R</p> <p>—</p> <p>—</p> |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | <ul style="list-style-type: none"> • Upper Floors • Basements | <p>03 No's</p> <p>N/A</p> | <p>03 No's</p> <p>N/A</p> | <p>M/R</p> <p>No basement</p> |
| | b. Width of staircases | | | |
| | <ul style="list-style-type: none"> • Upper Floor • Basements | <p>1.5 mtrs</p> | <p>220,155 & 155 cms.</p> | <p>M/R</p> |
| | c. Protection of exits | | | |
| | <ul style="list-style-type: none"> • Fire check door • Pressurization | <p>N/A</p> <p>N/A</p> | <p>N/A</p> <p>N/A</p> | <p>No basement</p> <p>N/A</p> <p>N/A</p> |
| | d. No. of continuous staircases to terrace | | | |
| | e. Width of Corridor | | | |
| | | <p>N/A</p> | <p>02</p> | <p>N/A</p> |
| | f. Door Size | <p>1.5 mtrs.</p> <p>N/A</p> | <p>220 cms</p> <p>110 cms (Double Door)</p> | <p>M/R</p> <p>M/R</p> |
| 3. | Compartmentation | | | |
| | <ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers | <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> | <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> | <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> |
| 4. | Smoke Management System | | | |
| | <ul style="list-style-type: none"> • Basements | <p>N/A</p> | <p>N/A</p> | <p>No basement</p> |

Ground plus two upper floors but school running at ground plus one upper floor only
(SDMC Primary Model School, Deendar Pur I/II, Najafgarh, New Delhi-110043)

| | | | | |
|------------|--|-------------------------------------|---------------------|-----|
| | <ul style="list-style-type: none"> Upper floors | N/A | Natural Ventilation | M/R |
| 5. | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> Total numbers Types IS marking | 08 no's ABC/CO ₂ type | Provided | M/R |
| | | | Provided | M/R |
| | | ISI marked | ISI marked | M/R |
| 6. | First-Aid Hose Reels | | | |
| | <ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 7. | Automatic fire detection and alarming system | | | |
| | <ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 8. | MOEFA | N/A | N/A | N/A |
| 9. | Public Address System | N/A | N/A | N/A |
| 10. | Automatic Sprinkler System | | | |
| | <ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 11. | Internal Hydrants | | | |
| | <ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 12. | Yard Hydrants | | | |
| | <ul style="list-style-type: none"> Total number of hydrants Hose Box | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 13. | Pumping Arrangements | | | |
| | <ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |

N/7

Ground plus two upper floors but school running at ground plus one upper floor only
(SDMC Primary Model School, Deendar Pur I/II, Najafgarh, New Delhi-110043)

| | | | | |
|------------|---|----------------|-----|-----|
| | <ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump | N/A | N/A | N/A |
| 14. | Captive Water Storage for fire fighting | | | |
| | <ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity | N/A | N/A | N/A |
| 15. | Exit Signage. | N/A | N/A | N/A |
| 16. | Provision of Lifts. | No Lift | | |
| | <ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage | N/A | N/A | N/A |
| 17. | Standby power supply | N/A | N/A | N/A |
| 18. | Refuge Area. | | | |
| | <ul style="list-style-type: none"> ➤ Total Area ➤ Location | N/A | N/A | N/A |
| 19. | Fire Control Room | | | |
| | <ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans | N/A | N/A | N/A |
| 20. | Special Fire Protection System for Protection of special Risks, if any: | N/A | N/A | N/A |

218

Ground plus two upper floors but school running at ground plus one upper floor only
(SDMC Primary Model School, Deendar Pur I/II, Najafgarh, New Delhi-110043)

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the above substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Note :- As per the letter given by the principal of the school (Placed at C-10), the school building is comprised of ground plus two upper floors but the school is running at ground plus one upper floor only.

Sandeep
08/11/15

Signature of Inspecting Officer

Name:- Sandeep Duggal

Designation:- Asstt. Divisional Officer

Signature of Inspecting Officer

Name

Designation