

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/GH/2015/ 1102/558

Dated : 20/04/15

FIRE SAFETY CERTIFICATE

Certified that the **The Janpath Hotel** located at **Janpath, New Delhi** comprised of **Small Basement + Ground + Five Upper Floors** was granted FSC by this department vide letter No.F6/DFS/MS/2012/Hotel/1858 dated **22/05/2012**. The premise was re-inspected by the officer concerned of this department on **25/03/15** in the presence of **Mr. Vinod (Sr. Manager Adm. E/M)** and found that the said Hotel have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Group A, Sub Division A-5 "Hotel Building"** with effect from 20/04/15 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 20/04/15 at New Delhi by.



(Dr. G.C.Misra)
Chief Fire Officer
Delhi Fire Service
Ph. 011-23414333

GC Misra

Copy to:-

1. The Joint Commissioner of Police (Lic.), 1st Floor, Police Station, Defence Colony, New Delhi. (ref letter no. 3636/Jt CP/Lic dt 23.02.15)
2. Medical Officer Health, NDMC, Palika Kendra, New Delhi.(ref. letter no. D 470& 472/MOH(Lic.)/SI-I dated 03/03/15)
3. The Manager, Hotel Janpath ,
Janpath, New Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : **The Janpath Hotel at Janpath, New Delhi**
2. Type of occupancy : Hotel Building A-5,
(Small Basement + Ground + 5 Upper floor)
3. Type of case:- : Renewal
4. Details of previous NOC : No. F6/DFS/MS/2012/Hotel/1858 dated
22/05/2012.
5. Fire safety directives No. : F.6/DFS/MS/93/Hotel/2090 dated 22/12/93
6. Date of inspection:- 25/03/15
7. Name of the inspecting officer : Sh. Rajesh Panwar Dy. CFO/NDZ
Sh. Gurmukh Singh DO/CD
Sh. Manoj Kumar Sharma ADO/CC
8. Name & designation of officer
From the building side : Mr. Vinod (Sr. Manager Adm. E/M)
9. Year of construction : 1960
10. Applicant's letter No : 3636/Joint.C.P./Lic. (H) Dated 23/02/15

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	09 mtr.	12 Mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	NA	NA	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02	02	MR
	2. Basements	01	01	MR
	B. Width of staircase			
	1. Upper floors	1.25 mtr.Existing	1.25 mtr	MR
	2. Basements	0.60 mtr.Existing	0.60 mtr.	MR
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	02 No	02 No	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1 Mtr.	1 Mtr.	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	Provided	MR
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	170 Nos.	172 Nos.	MR

	2) Types	ABC & CO2	ABC, CO2 & W.CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	05 No.	05 No. at each floor	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm.	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Required	Provided	MR
	2) Location of main panel	Required	Gr. floor	MR
	3) Location of repeater panel	Required	Every floor	MR
	4) Alternate source of power	Required	UPS/Battery	MR
	5) Hooter's Location	Required	Near Staircase	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	100 mm	MR
	2) Number of hydrants per floor	05	05	MR
	3) Hose box	05	05	MR
12.	Yard Hydrants			
	1) Total number of hydrants	07	07	MR
	2) Hose box	07	07	MR
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	2850 LPM	2850 LPM	MR
	b) Head of main pump	70 mtr	70 mtr	MR
	c) Number of main pump	01	01	MR
	d) Jockey pump out put	380 LPM	380 LPM	MR
	e) Jockey pump head	55 mtr.	55 mtr.	MR
	f) Stand by pump output	Required	Provided	MR
	g) Stand by pump head	Required	Provided	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank	1,00,000 ltr.	2,00,000 ltr.	MR

	capacity			
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	10,000 Ltrs.	10,000 Ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	Required	Provided	MR
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	Required	Provided	MR
	c) PA system panel	Required	Provided	MR
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	Required	Provided	MR
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F6/DFS/MS/Hotel/2012/1858 dated 22/05/2012 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name :- Sh. Rajesh Panwar
Designation :- DCFO (NDZ)

Name :- G.S Chauhan
Designation :- DO (CD)

Name :- M.K. Sharma
Designation :- ADO (CC)

