

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F6/DFS/MS/GH/2015/52/559

Dated: 20/04/15

**FIRE SAFETY CERTIFICATE**

Certified that the M/S Vishwa Yuvak Kendra, located at Circular Road, Chanakyapuri, New Delhi-110021, comprised of basement, ground plus four upper floors only, was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/GH/2012/1741, dated 14-05-12. The premises was re-inspected by the officer concerned of this department on 09-04-2015 in the presence of Sh. B.S.Rathore (Hostel Supervisor) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class A "Residential Dormitory Building" with effect from ...20/04/2015 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on.....20/04/15... 2015 at New Delhi by.



(Dr.G.C.Misra)

Chief Fire Officer

T.No.011-23414333

Copy to:-

1. Joint Commissioner of Police, Licensing Unit, 1<sup>st</sup> floor, P.S.Defence Colony, New Delhi in r/o letter No.3646, dated 23.02.2015.
2. Sh. Mukul Gupta, Vishwa Yuvak Kendra, Circular Road, Chanakyapuri, New Delhi-110021.

**Conditions for the validity of fire safety certificate are overleaf:-**

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate on form J, six month prior to its expiry.

N/49

**INSPECTION REPORT**

1. Name & address of the building : M/S Vishwa Yuvak Kendra, Circular Road, Chanakyapuri, New Delhi-110021.
2. Building comprised of : B+G+4Upper floors.
3. Type of Occupancy : Group "A" Residential Dormitory Building.
4. Type of Case : Renewal.
5. Details of Previous NOC :No.F6/DFS/MS/GH/2012/1741, dated 14.05.12.
6. Fire Safety direction letter No : Nil.
7. Date of Inspection : 09.04.15.
8. Name of the Inspecting Officers: : Vedpal (ADO).
9. Name and designation of Officer from the building side : Sh. B.S.Rathore(Hostel Supervisor).
10. Year of Construction : 1969.
11. Applicant's letter No :No.3646/Joint C.P./Lic(H), dated 23.02.15.

S.No	Minimum Standards on fire prevention and fire safety as per Rule 33.	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	10m	MR
	Gate width	4.5m.	4.5m.	MR
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases	.		
	Upper Floor	Upto 1 <sup>st</sup> floor=02nos. 1 <sup>st</sup> floor to terrace=3nos.	Upto 1 <sup>st</sup> floor=02nos. 1 <sup>st</sup> floor to terrace=3nos.	MR
	Basement	02nos	02nos.	MR
	B. Width of Staircases	.		
	Upper Floor	1.25m(two)	1.27m,1.23m & 60cm from 1 <sup>st</sup> floor to terrace.	MR (old case)
	Basement	1.25m	1.5m & 1.27m	MR
	c. Protection of exits	Required	Provided	MR
	Fire check door	Required	Provided	MR
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	1no.	2nos.	MR
g. Width of Corridor	N.A.	N.A.	N.A.	
h. Door Size	1mtr.	1mtr.	MR	
3	Compartmentation			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	Required	Provided	MR
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	30a/c per hour	Exhaust fan Provided	MR
	Upper floor	15 a/c per hour	Natural Ventilation	MR

M/S Vishwa Yuvak Kendra, Circular Road, Chanakyapuri, New Delhi-21.

5.	Fire Extinguisher			
	Total numbers	24 nos.	30 nos.	MR
	Types	ABC&WCO <sub>2</sub>	ABC&WCO <sub>2</sub>	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	02nos.	02nos.	MR.
	Length of hose reel hose	30m	30m	MR.
	Nozzle diameter	5cm	5cm	MR.
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	MOEFA	Required	Provided	M R
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	Basement	Required	Provided	MR
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	N.A.	N.A.	N.A.
	Number of hydrants per floor	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	➤ Ground Level	Required	Provided	MR
	➤ Discharge of main Pump	900LPM	900LPM	MR
	➤ Head of Main Pump	70m	70m	MR
	➤ Number of main pumps	01no.	01no.	MR
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	Required	Provided	MR
	➤ Terrace Level	Required	Provided	MR
	➤ Discharge of pump	900LPM	900 & 180 LPM (two set)	MR
	➤ Head of the Pump	40m	40m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	50000Liters	50000Liters	MR
	Draw-off connection	Required	Provided	MR
	Fire service inlet	Required	Provided	MR
	Access to tank	Required	Provided	MR
	Overhead Tank capacity	10000Liters	10000+10000Liters	MR
15	Exit Signage.	Required	Provided	M R
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	Required	Provided ( DG Set)	M R
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Battery backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked randomly and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the Fire Safety Certificate issued vide letter No.F.6/DFS/MS/GH/2012/1741, dated 14.05.12, renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly DFA is put up for kind consideration please.

Signature of the Inspecting Officer

Name Vedpal

Designation ADO

D.O. (South)

10/4/15

10/4/15