

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/2015/W2/647

Dated: 30/04/15

**FIRE SAFETY CERTIFICATE**

Certified that the **Shop in Park Mall** located at **Plot No 2, B Block, Community Centre, Shalimar Bagh, New Delhi** comprised of 2 Basement + Ground + 3 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/2011/3125 dated 23/11/2011. The premises was re inspected by the officers concerned of this department on 20/01/2015 in the presence of Mr.D P Vashishit (General Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly Building" Group D with effect from 30/04/15 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on .....30/04/15..... at New Delhi by.

  
(Santokh Singh)  
Chief Fire Officer  
PH 011-23414250

Copy to:

Sh. D P Vashishit (General Manager),  
Shop in Park Mall ,Plot No 2, B Block,  
Community Centre, Shalimar Bagh, New Delhi

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

M-16

INSPECTION REPORT

1. Name & address of the building: SHOP IN PARK Located at Plot no. 2.B-Block,Community centre, Shalimar Bagh, New Delhi.
2. Type of Occupancy :Class-F(Mercantile)Mall (2 Basement+Ground+ 3 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F6/DFS/MS/2011/3125 dated 23-11-2011
5. Fire Safety directives Letter No. : Letter No. F6/DFS/MS/BP/2005/935 dated 03-03-2005
6. Date of inspection : 20-01-2015
7. Name of the Inspecting Officer : ADO (WP)
8. Name and designation of Officer  
from the building side : Sh. DP Vashishit (General Manager)
9. Year of Construction : 2006
10. Applicant's letter No. : Nil Dated 22-11-2014

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC/BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 m	Provided	MR
	• Gate width	5 m	Provided	MR
	• Width of internal road	6 m	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	7	Provided	MR
	• Basements	9	Provided	MR
	b. Width of staircases			
	• Upper floors	1.5m	Old Case	MR
	• Basements	1.5m	Old Case	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	Old Case	Old Case	Old case
	f. Door Size	Old Case	Old Case	Old case



N-12

3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	Required	Provided	MR
	• Fire Dampers	Required	Provided	MR
4.	Smoke managements System			
	• Basements	30 a/c per hour	Connected with Detection & alarm system	MR
	• Upper floors	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	80 nos.	Provided	MR
	• Types	ABC, CO2 & WCO2	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	Required	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke & Heat	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location			
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	Required	Provided	MR
	• Hose Box	Required	Provided	MR

N/18

Yard Hydrants				
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	08	Provided	MR
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	08	Provided	MR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>			
	<ul style="list-style-type: none"> <li>Discharge of main pump</li> </ul>	2850 lpm	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Head of main pump</li> </ul>	60 m	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Number of main pumps</li> </ul>	2	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Jockey pump out put</li> </ul>	180 lpm	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Jockey pump head</li> </ul>	70 m	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Standby Pump out put</li> </ul>	2850 lpm	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Standby Pump Head</li> </ul>	70 m	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Auto Staring/Manual stopping</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Terrace level</li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of pump</li> </ul>	NR	NR	NR
	<ul style="list-style-type: none"> <li>➤ Head of the pump</li> </ul>	NR	NR	NR
	<ul style="list-style-type: none"> <li>➤ Power supply</li> </ul>	NR	NR	NR
	<ul style="list-style-type: none"> <li>➤ Auto starting of pump</li> </ul>	NR	NR	NR
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> <li>Under ground tank capacity</li> </ul>	2,00,000 litres	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Draw of connection</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Access to tank</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Overhead Tank capacity</li> </ul>	30, 000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lift (As per approved plan lift lobby is marked but not seen at site.)			
	<ul style="list-style-type: none"> <li>➤ Pressurization of Lift Shaft</li> </ul>	NR	NR	NR
	<ul style="list-style-type: none"> <li>➤ Pressurization of lift lobby</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Communication in lift Car</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Fireman's Grounding Switch</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Lift Signage</li> </ul>			
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> <li>➤ Total area</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Location</li> </ul>	NA	NA	NA
19.	Fire control room			



4/19

	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	CO2 Flooding System for HT & LT Panel	Provided	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/2011/3125 dated 23-11-2011 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note,- Lift lobby has been provided in basement 1 & 2 and compartmented by FCD and capsule lift is running from basement to 3<sup>rd</sup> floor.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Uday Kir Singh

Name

Designation

AD/WP

Designation