

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

No.F6/DFS/MS/GH/2015/ND2) 672


Dated :-----01/05/15

FIRE SAFETY CERTIFICATE

Certified that the M/s **Shakun Guest House** located at **723, Church Mission Road, Fatehpuri, Delhi** comprised of **Ground + 3 Upper Floors (Ground floor—Reception, First floor --06 guest rooms, Second floor --06 guest rooms, Third floor -- 02 Guest rooms)** was granted FSC by this department vide letter No.F6/DFS/MS/GH/2012/393 dated 07/02/2012. The premise was re-inspected by the officer concerned of this department on **09/04/15** in the presence of **Mr. Surya Parkash Sharma (caretaker)** and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Residential Group A-1 for (Ground floor—reception, 1st floor—04 Guest rooms with 04 beds, 2nd floor—04 guest rooms with 05 beds & 3rd floor—02 guest rooms with 03 beds total 10 guest rooms with 12 beds only)** with effect from -----01/05/15----- for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued -----01/05/15-----at New Delhi by.


(Dr. G.C.Misra)
Chief Fire Officer
Delhi Fire Officer
Ph: - 011-23414333

- Copy to: (1) The Joint Commissioner of Police (Lic.), 1st Floor, Police Station, Defence Colony, New Delhi. Ref:- 3630/Jt CP/lic(H) dated 23.02.2015. 
- (2) The Manager, Shakun Guest House, 723, C. M. Road, Fatehpuri, Delhi.

Conditions:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry”.

INSPECTION REPORT

1. Name & address of the building:- Shakun Guest House, 723, C. M. Road, Fatehpuri, Delhi-110006.
2. Type of occupancy:- Residential Group A-1 Ground plus 03 upper floors (Ground—reception, 1st floor—04 Rooms, 2nd floor—04 rooms & 3rd floor—02 rooms)
3. Type of case:- Renewal
4. Details of previous ~~NOE~~ *FSC* h No. F6/DFS/MS/GH/2012/393 dated 07/02/2012.
5. Fire safety directives No.- N/A
6. Date of inspection:- 09/04/15
7. Name of the inspecting officer:- A.D.O. Rajesh Kumar
8. Name & designation of officer
From the building side:- Mr. Surya Prakash Sharma (caretaker)
9. Year of construction:- Old
10. Applicant's letter No:- 3630/Jt CP/Lic (H) dated 23.02.2015

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement (PSS Area)	Provided at site PSS	Remarks MR/NMR
1.	Access to Building			
	1) Road width	N/A	12.0 m (approx)	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01 No	01 No	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	0.80 m	0.80 to 0.86 m	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
		01 No	01 No	MR
	E. Width of corridor			
		N/A	N/A	N/A
	F. Door size			
		1.0 m	1.0 m	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	N/A	N/A
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			

Alh

N/20

	1) Total numbers	08 Nos.	08Nos.	
	2) Types	ABC & CO2	ABC, CO2 & W.CO2	MR
	3) ISI marking	ISI	Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01 no.	Provided at 3 rd floor	MR
	2) Length of hose reel hose	30m	30m	MR
	3) Nozzle diameter	5mm	5mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	225 lpm	225 lpm	MR
	b) Head of pump	40m	40m	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			

M

	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	2500 ltrs	2500 ltrs	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply (Emergency light)	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the guest house were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No.F6/DFS/MS/GH/2012/393 dated 07/02/2012, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended