

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110 001

No. *F6/DFS/MS/School/2015/52/620*

Dated: *27/04/15*

FIRE SAFETY CERTIFICATE

Certified that SDMC Primary Boys School, Shahbad Mohd. Pur, New Delhi-110061 comprised of ground and first floor, was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2012/2736 dated 26-07-2012. The premises was re-inspected by the officer concerned of this department on 13-04-2015 in the presence of Sh. Lal Singh Yadav, Principal of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 01.03.2011 and that the premises is fit for occupancy class "B" educational building with effect from *27/04/2015* for period of three years.

Issued *27/04/2015* at New Delhi by.



(Dr.G.C.Misra)

Chief Fire Officer

T.No.011-23414333

To,
The Principal,
SDMC Primary Boys School,
Shahbad Mohd. Pur, New Delhi-110061.

Copy to:-

The Director of Education(SDMC),
Civic Centre, New Delhi.

Conditions for the validity of fire safety certificate are overleaf:-

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. The employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All fire fighting equipments shall be maintained in perfect working condition all time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate in form J, six month prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : SDMC Primary Boys School, Shahbad Mohd. Pur, New Delhi-110061.
2. Building is comprised of : G+1.
3. Type of Occupancy : Education
4. Type of Case : Renewal
5. Details of Previous NOC : No.F6/DFS/MS/School/2012/247, Dated 27.01.2012.
6. Fire Safety direction letter No : F.16/Estate/CC/Fire safety/2011/3298 to 3398
Dated- 01.03.11
7. Date of Inspection : 13.04.15.
8. Name of the Inspecting Officers: : Vedpal (ADO)
9. Name and designation of Officer from the building side : Sh. Lal Singh Yadav(Principal)
10. Year of Construction : 2008.
11. Applicant's letter No : Nil, dated 03.03.15.

| S.No | Minimum Standards on fire prevention and fire safety as per circular no.3298-3398 Dated01.03.11 | Requirement | Provided at Site | Remarks MR/NMR |
|----------------------|---|-----------------|------------------|----------------|
| 1 | Access to building | | | |
| | Road width | 6 m | 6 m | MR |
| | Gate width | N.A. | N.A. | N.A. |
| | Width of internal road | N.A. | N.A. | N.A. |
| 2 | Number, Width, Type and Arrangement of Exits. | | | |
| | a. Number of Staircases | . | | |
| | Upper Floor | 02nos. | 02nos. | MR |
| | Basement | N.A. | N.A. | N.A. |
| | B. Width of Staircases | . | | |
| | Upper Floor | 1.5 m | 1.5m&1.25m | MR |
| | Basement | N.A. | N.A. | N.A. |
| | c. Protection of exits | N.A. | N.A. | N.A. |
| | Fire check door | N.A. | N.A. | N.A. |
| | Pressurization | N.A. | N.A. | N.A. |
| | e. No. of continuous staircases to terrace | N.A. | N.A. | N.A. |
| g. Width of Corridor | 1.5 m | 1.5 m | MR | |
| h. Door Size | 1 m | 1m | MR | |
| 3 | Compartmentation | | | |
| | Fire check door | N.A. | N.A. | N.A. |
| | Sealing of electrical shafts | N.A. | N.A. | N.A. |
| | Fire rating of shaft door | N.A. | N.A. | N.A. |
| | Water curtain | N.A. | N.A. | N.A. |
| | Fire Dampers | N.A. | N.A. | N.A. |
| 4 | Smoke Management System. | | | |
| | Basement | 30a/c per hour | N.A. | N.A. |
| | Upper floor | 12 a/c per hour | N.A. | N.A. |

Handwritten signature

SDMC Primary Boys School, Shahbad Mohd. Pur, New Delhi-110061.

| | | | | |
|----|---|-----------------------|------------|------|
| 5. | Fire Extinguisher | | | |
| | Total numbers | 08 nos. | 09 nos. | MR |
| | types | CO ₂ & ABC | DCP Type | MR |
| | IS marking | ISI marked | ISI marked | MR |
| 6 | First-aid-Hose Reels. | | | |
| | Total numbers of each floor | N.A. | N.A. | N.A. |
| | Length of hose reel hose | N.A. | N.A. | N.A. |
| | Nozzle diameter | N.A. | N.A. | N.A. |
| 7 | Automatic fire detection and alarming system. | | | |
| | Type of detectors | N.A. | N.A. | N.A. |
| | Location of main panel | N.A. | N.A. | N.A. |
| | Location of repeater panel | N.A. | N.A. | N.A. |
| | Alternate source of power | N.A. | N.A. | N.A. |
| | Hooters | N.A. | N.A. | N.A. |
| 8 | MOEFA | N.A. | N.A. | N.A. |
| 9 | Public address System. | N.A. | N.A. | N.A. |
| 10 | Automatic Sprinkler System. | | | |
| | Basement | N.A. | N.A. | N.A. |
| | upper floor | N.A. | N.A. | N.A. |
| | sprinkler above false ceiling | N.A. | N.A. | N.A. |
| 11 | Internal Hydrants | | | |
| | size of riser/down-comer | N.A. | N.A. | N.A. |
| | Number of hydrants per floor | N.A. | N.A. | N.A. |
| | Hose Box | N.A. | N.A. | N.A. |
| 12 | Yard Hydrants. | | | |
| | Total number of hydrants | N.A. | N.A. | N.A. |
| | Hose Box | N.A. | N.A. | N.A. |
| 13 | Pumping Arrangements. | | | |
| | ➤ Ground Level | N.A. | N.A. | N.A. |
| | ➤ Discharge of main Pump | N.A. | N.A. | N.A. |
| | ➤ Head of Main Pump | N.A. | N.A. | N.A. |
| | ➤ Number of main pumps | N.A. | N.A. | N.A. |
| | ➤ Jockey pump out put | N.A. | N.A. | N.A. |
| | ➤ Jockey pump head | N.A. | N.A. | N.A. |
| | ➤ Standby pump out put | N.A. | N.A. | N.A. |
| | ➤ Standby pump Head | N.A. | N.A. | N.A. |
| | ➤ Auto Starting /Manual stopping | N.A. | N.A. | N.A. |
| | ➤ Pump House Access | N.A. | N.A. | N.A. |
| | ➤ Terrace Level | N.A. | N.A. | N.A. |
| | ➤ Discharge of pump | N.A. | N.A. | N.A. |
| | ➤ Head of the Pump | N.A. | N.A. | N.A. |
| | ➤ Power supply | N.A. | N.A. | N.A. |
| | ➤ Auto Starting of pump | N.A. | N.A. | N.A. |


SDMC Primary Boys School, Shahbad Mohd. Pur, New Delhi-110061.

| | | | | |
|----|--|------|------|------|
| 14 | Captive Water Storage for Fire Fighting. | | | |
| | Underground tank capacity | N.A. | N.A. | N.A. |
| | Draw-off connection | N.A. | N.A. | N.A. |
| | Fire service inlet | N.A. | N.A. | N.A. |
| | Access to tank | N.A. | N.A. | N.A. |
| | Overhead Tank capacity | N.A. | N.A. | N.A. |
| 15 | Exit Signage. | N.A. | N.A. | N.A. |
| 16 | Provision of Lifts. | | | |
| | Pressurization of Lift Shaft | N.A. | N.A. | N.A. |
| | Pressurization of Lift lobby | N.A. | N.A. | N.A. |
| | Communication in lift car | N.A. | N.A. | N.A. |
| | Firemen's grounding switch | N.A. | N.A. | N.A. |
| | Lift Signage | N.A. | N.A. | N.A. |
| 17 | Standby power supply | N.A. | N.A. | N.A. |
| 18 | Refuge Area. | | | |
| | Total area | N.A. | N.A. | N.A. |
| | Location | N.A. | N.A. | N.A. |
| 19 | Fire Control Room | | | |
| | Detector system panel | N.A. | N.A. | N.A. |
| | Flow switch panel | N.A. | N.A. | N.A. |
| | PA system panel | N.A. | N.A. | N.A. |
| | Batter backup | N.A. | N.A. | N.A. |
| | Building Floor Plans | N.A. | N.A. | N.A. |
| 20 | Special Fire Protection systems for protection of special Risks, if any: | N.A. | N.A. | N.A. |

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under circular of Director of Education, the FSC issued vide letter No: F6/DFS/MS/School/2012/247, dated 27.01.2012, renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly DFA is put up for kind consideration please.

Signature of the Inspecting Officer
 Name: Vedpal
 Designation: ADO

 13/4/15





