

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE
(SEE SUB -RULE (1) OF RULE 35)
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/EH/2015/62/658

Dated 01/05/15


FIRE SAFETY CERTIFICATE

Certified that the Pulse Restaurant (A unit of Nanak Food) located at First Floor A-5, Vishal Enclave, Rajouri Garden, New Delhi – 110027, comprised of Ground + Two Upper Floors was granted NOC/FSC vide letter No. F.6/DFS/MS/EH/2012/1610 dated 03.05.2012. The premises was re-inspected by the officer concerned of this department on 10.04.2015 in the presence of Sh. Anudeep Narang and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "Assembly" Group-D with effect from 01 / 05 / 2015 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire service rule, 2010.

Conditions for the validity of Fire Service Certificate:

1. All the fire safety arrangement provided therein shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the / construction etc. shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' (sub rule (1) of rule 37) along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs. Delhigovt.nic.in](http://www.dfs.Delhigovt.nic.in)
8. The number of seats in the restaurant shall not be increased.

Issued on 01/05/15.....at New Delhi by


(Santokh Singh)
Chief Fire Officer
Delhi Fire Service
Phone -23414250

Copy to:

1. Sh. Anudeep Narang, Pulse Restaurant (A unit of Nanak Food), First Floor A-5, Vishal Enclave, Rajouri Garden, New Delhi – 110027.

1. Name & address of the building: Pulse Restaurant (A Unit of Nanak Food),
First Floor A-5, Vishal Enclave, Rajouri Garden, New Delhi-110027.
2. Type of Occupancy : Class-D (Assembly)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/EH/2012/1610 dated 03/05/2012
5. Fire Safety directives Letter No. : F6/6/TSM/inspection/2004/106 dated 04/04/2005
6. Date of inspection : 10/04/2015
7. Name of the Inspecting Officer : DO (West) & (A.D.O. M.N)
8. Name and designation of Officer
from the building side : Sh. Anudeep Narang
9. Year of Construction : 2004-2005
10. Applicant's letter No. : -NF/2014-15/2303 Dated 23/03/2015

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC/BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 Mtrs	Provided	MR
	• Gate width	4.5 Mtr	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	No basement	N/A	N/A
	b. Width of staircases			
	• Upper floors	Old Case	Old Case	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	2	2	MR
	e. Width Of Corridor	Old Case	Old Case	MR
	f. Door Size	Old Case	Old Case	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	10	14	M/R
	• Types	ISI marked ABC/CO ₂	Provided	M/R

6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	Provided	MR
	• Length of hose reel hose	30 mtr	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	NR	Provided	MR
	• Sprinkler above false ceiling	NR	Provided	MR
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	1	Provided	MR
	• Hose Box	1	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level	N/A		
	• Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	180 LPM, 450 LPM	Provided	MR
	➤ Head of the pump	30 mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A

15	Exit Signage	Required	Provided	M/R
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Batter backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/EH/2012/1610 dated 03/05/2012 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name : Mukesh Verma

Designation : A.D.O. (Moti Nagar)