

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001


No. *fg/dfs/ms/school/2015/402/593*

Dated: *23/04/15*

FIRE SAFETY CERTIFICATE

Certified that the Pragati Public School, A-312/4, Gali no. 4, South Gamri Extn., Delhi-53 comprised of ground plus one upper floor owned/occupied by Pragati Public School, have complied with the fire prevention and fire safety requirements in accordance with the circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education and verified by the officer concerned of Fire Service on 09.04.2015 in the presence of Manager of the school and found that the building GF+FF is fit for occupancy class B 'Educational Building' with effect from *23/04/15* for a period of three years, subject to conditions printed overleaf.

Issued on *23/04/15* at New Delhi by



(Dr. G.C. Misra)

Chief Fire Officer

Ph -011- 23414333

Dr. G.C. Misra

To,

The Principal

Pragati Public School, A-312/4, Gali no. 4, South Gamri Extn., Delhi-53

Copy to:-

The Director of Education,

East Delhi Municipal Corporation,

419, Udyog Sadan, Patparganj Industrial Area, Delhi-92

CONDITIONS:

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Pragati Public School, A-312/4, Gali no. 4, South Gamri Extn., Delhi-53.
2. Building is comprised of : G+1
3. Type of Occupancy : Educational
4. Type of Case : Renewal Case
5. Details of Previous NOC : F.6/MS/DFS/2007/3598 dated 03.12.2007 for ground floor only
6. Fire Safety direction letter No : F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.11
7. Date of Inspection : 09.04.2015
8. Name of the Inspecting Officers: : Suresh Singh (ADO)
9. Name of the designation of Officer from the building side : Manager
10. Year of Construction : 2003
11. Applicant's letter No : dated 23.03.2015

S.No	Minimum Standards on fire safety requirements as per circular no. 3298 to 3398 Dated: 01.03.11	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	4.5 m	Old case/MR
	Gate width	N.A	N.A	N.A
	Width of internal road	N.A	N.A	N.A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	1 no.	2 no.	MR
	Basement	N.A	N.A	N.A
	B. Width of Staircases			
	Upper Floor	1.5 m	0.95m, 0.90m	MR
	Basement	N.A	N.A	N.A
	c. Protection of exits			
	Fire check door	N.A	N.A	N.A
	Pressurization	N.A	N.A	N.A
	e. No. of continuous staircases to terrace	1 no.	1 no.	MR
g. Width of Corridor	1.5 m	1.5 m	MR	
h. Door Size	1 m	1 m	MR	
3	Compartmentation.			
	Fire check door	N.A	N.A	N.A
	Sealing of electrical shafts	N.A	N.A	N.A
	Fire rating of shaft door	N.A	N.A	N.A
	Water curtain	N.A	N.A	N.A
	Fire Dampers	N.A	N.A	N.A
4	Smoke Management System.			
	Basement	30a/c per hour	N.A	N.A
	Upper floor	12a/c per hour	N.A	N.A

* Acceptable as per Rules 2010 [Rule 35(6)].

5.	Fire Extinguisher			
	Total numbers	04 no.	04 no.	MR
	types	CO ₂ & ABC	CO ₂ & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	N.A	N.A	N.A
	Length of hose reel hose	N.A	N.A	N.A
	Nozzle diameter	N.A	N.A	N.A
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A	N.A	N.A
	Location of main panel	N.A	N.A	N.A
	Location of repeater panel	N.A	N.A	N.A
	Alternate source of power	N.A	N.A	N.A
	Hooters	N.A	N.A.	N.A.
8	MOEFA	N.A	N.A.	N.A.
9	Public address System.	N.A	N.A.	N.A.
10	Automatic Sprinkler System.			
	basement	N.A	N.A	N.A
	upper floor	N.A	N.A	N.A
	sprinkler above false ceiling	N.A	N.A	N.A
11	Internal Hydrants			
	size of riser/down-comer	N.A	N.A	N.A
	Number of hydrants per floor	N.A	N.A	N.A
	Hose Box	N.A	N.A	N.A
12	Yard Hydrants.			
	Total number of hydrants	N.A	N.A	N.A
	Hose Box	N.A	N.A	N.A
13	Pumping Arrangements.			
	• Ground Level	N.A	N.A	N.A
	➤ Discharge of main Pump	N.A	N.A	N.A
	➤ Head of Main Pump	N.A	N.A	N.A
	➤ Number of main pumps	N.A	N.A	N.A
	➤ Jockey pump out put	N.A	N.A	N.A
	➤ Jockey pump head	N.A	N.A	N.A
	➤ Standby pump out put	N.A	N.A	N.A
	➤ Standby pump Head	N.A	N.A	N.A
	➤ Auto Starting /Manual stopping	N.A	N.A	N.A
	➤ Pump House Access	N.A	N.A	N.A
	• Terrace Level	N.A	N.A	N.A
	➤ Discharge of pump	N.A	N.A	N.A
	➤ Head of the Pump	N.A	N.A	N.A
	➤ Power supply	N.A	N.A	N.A
	➤ Auto Starting of pump	N.A	N.A	N.A

14	Captive water storage for Fire Fighting.			
	Underground tank capacity	N.A	N.A	N.A
	Draw-off connection	N.A	N.A	N.A
	Fire service inlet	N.A	N.A	N.A
	Access to tank	N.A	N.A	N.A
	Overhead Tank capacity	N.A	N.A	N.A
15	Exit Signage.	N.A	N.A	N.A
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A	N.A	N.A
	Pressurization of Lift lobby	N.A	N.A	N.A
	Communication in lift car	N.A	N.A	N.A
	Firemen's grounding switch	N.A	N.A	N.A
	Lift Signage	N.A	N.A	N.A
17	Standby power supply	N.A	N.A	N.A
18	Refuge Area.			
	Total area	N.A	N.A	N.A
	Location	N.A	N.A	N.A
19	Fire Control Room			
	Detector system panel	N.A	N.A	N.A
	Flow switch panel	N.A	N.A	N.A
	PA system panel	N.A	N.A	N.A
	Batter backup	N.A	N.A	N.A
	Building Floor Plans	N.A	N.A	N.A
20	Special Fire Protection systems for protection of special Risks, if any:	N.A	N.A	N.A

Delhi Fire Service has issued NOC vide letter no. F.6/MS/DFS/2007/3598 dated 03.12.2007 for ground floor only, now the School is running at ground plus one upper floor.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules the NOC issued vide letter no. F.6/MS/DFS/2007/3598 dated 03.12.2007 renewal under the circular No. F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.11 is recommended.

Signature of the Inspecting Officer

Name Suresh Singh

Designation ADO (Shah)



Shah
16.4.15