

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

NO. F6/DFS/MS/School/2015/SZ/ 625

Dated: 27/4/15

**FIRE SAFETY CERTIFICATE**

Certified that the New Era Public School, located at Pochanpur, Sec-24, Phase-II, Dwarka, New Delhi, having two blocks. A block comprised of ground plus one upper floor, B block comprised of basement, ground plus one upper floor was granted NOC by this department vide letter No.F6/DFS/MS/School/2012/1300 dated 12.4.2012. The school building was re-inspected by the officer concerned of this department on 18.4.2015 in presence of Sh. Vivekanand (Security) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education GNCT of Delhi Letter No: Estate/CC/Fire Safety/2011/3298 Dtd. 01.03.2011 and that the building is fit for occupancy of class B "Educational Building" with effect from 27/4/15 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 27/4/15 at New Delhi by



(Dr. GC Misra)  
Chief Fire Service  
Ph.011-23414333

**Copy to:**

- 1 Deputy Director (Education) Govt. of NCT of Delhi, Old Secretariat, New Delhi-110045.
- 2 Principal, New Era Public School, Pochanpur, Sec-24, Phase-II, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The basement shall be used strictly as per the provisions of the building bye laws.
7. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

## INSPECTION REPORT

1	Name & address of the building	New Era Public School, Pochanpur, Sector-24, Phase-II, Dwarka, New Delhi.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal		
4	Details of previous NOC	F6/DFS/MS/School/2012/1300 dated 12.4.2012		
5	Fire safety directives letter No	Directorate Of Education Circular. No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011.		
6	Date of inspection	18.4.2015		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Sh. Vivekanand (Security).		
9	Year of construction	2011	Two Blocks	
10	Applicant's letter No.	8.4.2015	(Basement, Ground plus One upper floor.	
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
<b>1</b>	<b>Access to building</b>			
	1) Road width	Accessible	9 Mtrs.	MR
	2) Gate width	Approachable	5 Mtrs.	MR
	3) Width of internal road	N/A	4.70 to 6 Mtrs.	MR
<b>2</b>	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	4 Nos.	4 Nos	MR
	2. basements	2 Nos.	2 Nos.	MR
	<b>b. Width of staircase</b>			
	1. Upper floors	1.5 Mtr.	2 Nos: 1.45 & 2 Nos: 1.44 Mtrs.	Old case
	2. basements	1.44 Mtrs.	1.44 Mtrs.	MR
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	N/A	N/A	N/A
	e. Width of corridor	2.30 Mtrs.	2.30 Mtrs.	MR
	f. Door size	1.10 to 2.07 Mtr.	1.10 to 2.07 Mtrs.	MR
<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
<b>4</b>	<b>Smoke Management system.</b>			
	basement	Required	Exhaust Fan Provided	MR
		N/A		
	upper floors		N/A	N/A
<b>5</b>	<b>Fire Extinguishers</b>			
	total numbers	1 Co2 OR ABC for every 300 Sq. Mtrs.	8 Nos. each floor	MR
	Types	ISI	ABC	MR
	ISI marking		Provided	MR

<b>6</b>	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	3 Nos.	3 Nos.	MR
	Length of Hose reel hose	30 Mtrs.	30 Mtrs.	MR
	Nozzle Diameter	5 MM	5 MM	MR
<b>7</b>	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
<b>8</b>	<b>MOEFA</b>	N/A	N/A	N/A
<b>9</b>	<b>Public Address System.</b>	N/A	Provided	MR
<b>10</b>	<b>Automatic Sprinkler System.</b>			
	basement	Required	Provided	MR
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
<b>11</b>	<b>Internal Hydrants</b>			
	Size of riser/down-corner	Old Case	100 mm	MR
	Number of Hydrants per floor	Old Case	3 Nos.	MR
	hose Box	Old Case	Provided	MR
<b>12</b>	<b>Yard Hydrants.</b>			
	total number of hydrants	Old Case	2 Nos.	MR
	hose box	Old Case	Provided	MR
<b>13</b>	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2. Terrace level</b>			
	a. Discharge of pump	450,180 LPM	450,180 LPM	MR
	b. head of the pump	30 Mtrs.	30 Mtrs.	MR
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	Required	Provided	MR
<b>14</b>	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	5000 Ltrs.	12000 Ltrs.	Old case
<b>15</b>	<b>Exit Signage.</b>	N/A	N/A	N/A
<b>16</b>	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

N/A

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:	ABC		

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, renewal of Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

*Sury*  
21/4/15

Signature of the Inspecting Officer

Name S.P. Bhardwaj

Designatic ADO (Dwarka)