

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

No.F6/DFS/MS/GH/2015/ND2/577

Dated :-21/04/15

FIRE SAFETY CERTIFICATE

Certified that the **M/s Ayesha Palace** Guest House located at **1092-95, Gali Madarsa Hussain Baksh, Bazar Matia Mahal, Jama Masjid, Delhi-110006** comprised of **Ground + 04 Upper Floors (Ground floor--- reception +03 guest rooms, first floor---04 rooms, 2nd Floor—04 rooms, 3rd floor—04 guest rooms & 4th floor—04 rooms)** was granted FSC by this department vide letter No.F6/DFS/MS/GH/2012/1667 dated **08/05/2012**. The premise was re-inspected by the officer concerned of this department on **09/04/15** in the presence of **Mr. Saleem (Owner)** and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Residential Group A-1 for 19 guest rooms only as above** with effect from 21/04/15 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 21/04/15 at New Delhi by.


(Dr. G. C. Misra)
Chief Fire Officer
Ph: - 011-23414333

- Copy to: (1) The Additional Commissioner of Police (Lic.), (ref no. 3785/Jt CP/Lic dt 24.02.15)
1st Floor, Police Station, Defence Colony, New Delhi.
(2) Smt Shaheeda Begum, M/s Ayesha Palace, 1092-95 Gali Madarsa Hussain Baksh,
Bazar Matial Mahal Jama Masjid, Delhi-110006.

Conditions:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

N/13


INSPECTION REPORT

1. Name & address of the building:- M/s Ayesha Palace, 1092-95, Gali Madarsa Hussain Baksh, Bazar Matia Mahal, Jama Masjid, Delhi-110006
2. Type of occupancy:- Residential Group A-1 Ground+ 4 Upper Floors (19 guest rooms)
3. Type of case:- Renewal
4. Details of previous ~~NOC~~ FSC:- No. F6/DFS/MS/GH/2012/1667 dated 08/05/2012.
5. Fire safety directives No.- N/A
6. Date of inspection:- 09/04/15
7. Name of the inspecting officer:- A.D.O. Rajesh Kumar
8. Name & designation of officer
From the building side:- Mr. Saleem (Owner)
9. Year of construction:- Old.
10. Applicant's letter No:- 3785/Joint.C.P./Lic. (H) Dated 24/02/15
Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement (PSS Area)	Provided at site PSS	Remarks MR/NMR
1.	Access to Building			
	1) Road width	N/A	2.0 m to 3.0 m	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01 No	01 No.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	80 cm	1.07m	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01 No	01 No	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1 mtr.	1 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	N/A	N/A
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	06 Nos.	Provided	MR

N/14

	2) Types	ABC & CO2	ABC, CO2 & W.CO2	MR
	3) ISI marking	ISI	Yes	MR
6.	First-Aid Hose Reel	01 No.	Provided at Ground & 3 rd floor	MR
	1) Total number of each floor	30 m	30 m	MR
	2) Length of hose reel hose	5 mm	5 mm	MR
	3) Nozzle diameter	Automatic Fire Detection & Alarming System		MR
7.	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System	N/A	N/A	N/A
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants	N/A	N/A	MR
	1) Size of riser/down-comer	N/A	N/A	MR
	2) Number of hydrants per floor	N/A	N/A	MR
	3) Hose box	N/A	N/A	MR
12.	Yard Hydrants	N/A	N/A	N/A
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement	N/A	N/A	N/A
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump output	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 lpm	450 lpm	MR
	b) Head of pump	30m	30m	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR



N/15

14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	5,000 Ltrs.	5,000 Ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply (Emergency light)	Required	Provided (Inverter)	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			01 ABC Fire Extinguisher provided near elect panel board

The fire protection systems provided in the building were randomly tested, Checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire Prevention and fire safety required under the rules the FSC issued vide letter no.F.6/DFS/MS/GH/2012/1667 dated 08.05.2012, renewal under rules 35 of the Delhi Fire Service Rules, 2010 is recommended.

13/11/15
Rajesh Kumar

Assistant Divisional Officer

DO/CC

Rajesh Kumar
13/11/15

