

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001
Fax: 23412593, Tel:- 011-23414000


No. F6/MS/DFS/SZ/EH/2015/82/603

Dated: 23/04/15

FIRE SAFETY CERTIFICATE

Certified that the Diva Restaurant located at M-8 Greater Kailash Part –II, M Block Market, New Delhi-110048, comprised of basement, ground + three upper floors but the restaurant is running on ground & first floor was issued FSC vide letter no.F6/DFS/MS/EH/2012/972 dated: 16-03-2012. The premises was re – inspected by the officer concerned of this department on 10/04/2015 in the presence of Mr. Dinesh and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group – D, Assembly Building(Restaurant) with effect from ~~23/04/15~~ the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued 23/04/15 at New Delhi by.



(Dr. G.C. Misra)
Chief Fire Officer

Tel: 011-2341433

9c
21/4/15

Copy to:-

- (1) Authorised Signatory
Diva Restaurant
M-8 Greater Kailash-II, M Block Market New Delhi-110048,

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of NBC
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building:- Diva Restaurant, M-8, Greater Kailash -II, New Delhi-110048
2. Type of occupancy:- Group – D, Assembly Building, (Restaurant)
3. Type of case:- Renewal
4. Details of previous NOC:- F6/DFS/MS/EH/2012/972 dated 16/03/2012
5. Fire safety directives No.- Nil
6. Date of inspection:- 24 /03/15
7. Name of the inspecting officer:- D.B. Mukherjee, A.D.O.(BCP)
8. Name & designation of officer From the building side:- Mr. Dinesh
9. Year of construction:- 1978
10. Applicant's letter No:- Nil dated 13/03/15.

The restaurant is running at ground & 1st floor of a building comprised of basement, ground + 03 upper floors. Restaurant is running in ground & 1st floor.

Sl. No.	Minimum Standards on Fire Prevention and Fire Safety U/R 33	Requirement BBL/NBC	Provided at Site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	09 m	Provided	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits:			
	A. Number of staircases			
	1. Upper floors	02	03	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.25 mtrs.	1.10m, 1.10 m & 0.80m	MR (Old Case)
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	Required	Provided	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	Required	1 m	MR (Old Case)
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	Exhaust Fan	MR
5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	08 Nos.	MR
	2) Types		ABC, Co2 ,Foam	MR
	3) ISI marking		Yes	MR

6.	First-Aid Hose Reel			
	1) Total number of each floor	01	Provided	MR
	2) Length of hose reel hose	30 mm	Provided	MR
	3) Nozzle diameter	5 mm	Provided	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Required	Smoke Detector	MR
	2) Location of main panel	Required	Ground Floor	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting / Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	Provided	MR
	b) Head of pump	Required	Provided	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	Required	2 Way	MR
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	5,000 Ltrs.	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A

17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the building were tested and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to renew the FSC issued vide letter No. F6/DFS/MS/ EH/2012/972 dated 16/03/2012 under rules 35 of the Delhi Fire Service Rules 2010. Accordingly DFA is put up for perusal and signature pl.

D.B. Mukherjee
13/4/15

Signature of the inspecting officer
Name :- D.B. Mukherjee.
Designation :- Assitt. Div. Officer(BCP).