

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001


No. *F6/DFS/MS/2015/402/591*

Dated: *22/04/15*

FIRE SAFETY CERTIFICATE

Certified that the Golden Leaf (Banquet Hall) running at ground & mezzanine floor of a building comprised of basement, ground, mezzanine & first floor at B-15 (Old no. 91/386/2) Main Road ,Gazipur, Delhi, owned/occupied by M/s Golden Leaf Banquet Hall have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of this department on dated 01.04.15 in the presence of Sh.Sunil Kumar Singh (Onwer) and found that the B+GF + mezzanine floor of building is fit for occupancy class D 'Assembly (Banquet Hall)' with effect from *22/04/15* for a period of **three** years, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, subject to conditions printed overleaf.

Issued on.....*22/04/15*.....at New Delhi by



(Dr.G.C.Misra)
Chief Fire Officer
Ph.011-23414333

o/c

To,
The Dy. Health Officer,
East Delhi Municipal Corporation ,Health Department,
Shahdara (South) Zone, Karkardooma, Shahdara, Delhi

Copy to-
Shri Sunil Kumar Singh
Golden Leaf Banquet Hall
B-15(Old No.91/386/2), Main Road Gazipur, Delhi.

CONDITIONS:

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. Basement shall be used as per BBL.
6. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J'[sub rule(1) of rule 37] along with a copy of this certificate,six months prior to its expiry"
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building : Golden Leaf Banquet Hall running at Ground & Mazzanine floor at B-15 (Old No.91/386/2) Main Road,Gazipur,Delhi.

2. Building is comprised of :Basement, Ground ,Mazzanine &First Floor
 3. Type of Occupancy : Assembly (Banquet Hall)
 4. Type of Case : New Case
 5. Details of Previous NOC : Nil
 6. Fire Safety direction letter No : NBC Part IV
 7. Date of Inspection : 01.04.15
 8. Name of the Inspecting Officers: :DO Virendra Singh & ADO Suresh Singh
 9. Name of the designation of Officer from the building side : Sh. Sunil Kumar Singh (Owner)
 10. Year of Construction : 2010
 11. Applicant's letter No : DHO/Sha.(S)/Zone/2014/1803 dated 04.12.14

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirement/NBC	Provided at Site	Remarks
1	Access to building			
	Road width	6 m	15 m	MR
	Gate width	N.A.	N.A.	N.A.
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	1 no.	02 nos.	MR
	Basement	2 nos.	02 nos.+ 1Ramp	MR
	b. Width of Staircases			
	Upper Floor	1.5 m	1.5M & 90 cm	MR
	Basement	1.5 m	1.5 m,90 cm+ 3 M Ramp	MR
	c. Protection of exits			
	Fire check door	Required	Provided	MR
	Pressurization	N.A.	N.A.	N.A.
	d. No. of continuous staircases to terrace	01 no.	1 no.	MR
	e. Width of Corridor	N.A.	N.A.	N.A.
	f. Door Size	2 M	4 M & 1.5 M	MR
3	Compartmentation.			
	Fire check door	Required	Provided	MR
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	Required	Provided	MR
	Upper floor	Required	Ventilated	M/R

5.	Fire Extinguisher			
	Total numbers	10 Nos.	12 Nos.	MR
	types	CO ₂ & ABC	Provided	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	1 no.	1 no.	MR
	Length of hose reel hose	30 m	30 m	MR
	Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	Not Required	Provided	MR
	Location of main panel	Main Gate	Provided	MR
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters's location	Staircase	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	Basement	Required	Provided	MR
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	100 mm	100 mm	MR
	Number of hydrants of each floor	1 no.	1 no.	MR
	Hose Box	1 no.	1 no.	MR
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level			
	➤ Discharge of pump	900 LPM	900 LPM	MR
	➤ Head of the Pump	40 m	40 m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Auto	MR

N13

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	15,000 Liters	25,000 Liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	Required	Provided	MR
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	Required	Provided	MR
	Battery backup	Required	Provided	MR
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A	N.A	N.A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

S Singh
9.4.2015

Signature of the Inspecting Officer

Name : Suresh Singh

Designation: ADO (Shah)

DO (FD)