

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DfS/ans/2015/W2/660

Dated: 01/05/15

FIRE SAFETY CERTIFICATE

Certified that the Jain Banquet located at Plot no-10 Wazirpur Press Area, Near Panjab Kesari, N Delhi -110035 in a building comprised of Basement + Ground Floor + 01 Upper Floor owned/occupied by Jain Banquet have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of this department on 04/03/2015 in the presence of Sh. Sanjeev Jain (Owner) and the building/premises is fit for occupancy class "Assembly" Group D with effect from 01/05/15 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 01/05/15 at New Delhi by


(Santokh Singh)
Chief Fire Officer
Delhi Fire Service
Phone -23414250
01/05/15

Copy to:

Sh. Sanjeev Jain, Jain Banquet, Plot no-10 Wazirpur Press Area, Near Panjab Kesari, N Delhi -35

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws 1983.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. form is available on www.dfs.delhi.gov.in.

INSPECTION REPORT

1. Name & address of the building: Jain Banquet at Plot no-10 Wazirpur Press Area, Near Panjab Kesari, N Delhi -110035
2. Type of Occupancy : Assembly (Basement+G+1 upper Floor)
3. Type of Case : New
4. Details of previous NOC : F-6/DFS/MS/BP/97/1521 Dated 15/10/97 (For Industry)
5. Fire Safety directives Letter No. : F-6/MS/BP/96/879 dated 25/07/1996 (For Industry)
6. Date of inspection : 04-03-2015
7. Name of the Inspecting Officer : DO/W&ADO (WP)
8. Name and designation of Officer
from the building side : Sh. Sh Sanjeev Jain (owner)
9. Year of Construction : 1997 -98
10. Applicant's letter No. : Nil Dated 02/01/2015

Plot Area = 810m²
 Covered Area = 995m²
 Basement = 405m²,
 Ground = 405 m²
 1st Floor = 185 M²

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	09 m	12mtrs ✓	MR
	• Gate width	5 m	Provided ✓	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided ✓	MR
	• Basements	2	Provided ✓	MR
	b. Width of staircases			
	• Upper floors	2 mtr & 1.25mtr	2 m & 1.3m ✓	MR
	• Basements	1.5m & 1.25m	1.5m & 1.3m ✓	
	c. Protection of exits			
	• Fire check door	Required	Provided ✓	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2x1.2m	2mtrs & 1.3m ✓	MR

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	Required	Provided /	MR
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	Required	Provided /	MR
	<ul style="list-style-type: none"> • Upper floors 	Required	Provided /	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	08 nos.	Provided	MR
	<ul style="list-style-type: none"> • Types 	ABC & CO2	Provided /	MR
	<ul style="list-style-type: none"> • IS marking 	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	01	Provided	MR
		30 m	Provided /	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	5 mm	Provided	MR
	<ul style="list-style-type: none"> • Nozzle diameter 			
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> • Hooters' Location 	NA	NA	NA
8.	MOEFA	Required	Provided ✓	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements 	Required	Provided ✓	MR
	<ul style="list-style-type: none"> • Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	100 mm /	Provided /	MR
		1	Provided /	MR
	<ul style="list-style-type: none"> • Number of hydrants per floor 	1	Provided /	MR
	<ul style="list-style-type: none"> • Hose Box 			

12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access			
	• Terrace level	NA	NA	NA
	➤ Discharge of pump			
	➤	900 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	NA	10000 ltrs	Provided in 2 plastic tanks at GF
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	20,000 ltrs	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR

18.	Refuge Area	NA	NA	
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans			
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers

..... Nil

Signature of the Inspecting Officer

Name

Uday Kir Singh

Designation

ADO/WP

Signature of the Inspecting Officer

Name

Shri Sunil Choudhary

Designation

DO/W