

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

No.F6/DFS/MS/GH/2015/ 1402/607

Dated : 24/04/15

FIRE SAFETY CERTIFICATE

Certified that the **Jukaso Inn** located at **P. 49-50, Sunder Nagar, New Delhi.** comprised of **Ground +2 Upper Floors having 31 guest rooms (Ground floor has 05 guest rooms + 01 Conference room +01 Pantry, Mezzanine floor 03 guest rooms +01 office, 1st floor 10 guest rooms, 2nd floor 13 guest rooms + Residence +01 store)** was granted FSC by this department vide letter No.F6/DFS/MS/GH/2012/1074 dated 23/03/2012. The premise was re-inspected by the officer concerned of this department on **20/04/15** in the presence of Sh. Parmod Sharma (**Manager**) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Residential Group A-1 for 31 guest rooms only at ground to 2nd floor** with effect from 24/04/15 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 24/04/15 at New Delhi by.


(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service
Ph: - 011-23414333

Copy to: (1) The Joint Commissioner of Police (Lic.), 1st Floor, Police Station, Defence Colony, New Delhi.

(2) The Manager, Jukaso Inn P. 49-50, Sunder Nagar, New Delhi.

Conditions:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

INSPECTION REPORT

1. Name & address of the building:- Jukaso Inn P. 49-50, Sunder Nagar, New Delhi.
2. Type of occupancy:- Residential Group A-1 Ground+ 02 Upper Floors (31 guest rooms)
3. Type of case:- Renewal
4. Details of previous FSC :- No. F6/DFS/MS/GH/2012/1074 dated 23/03/2012.
5. Fire safety directives No.- N/A
6. Date of inspection:- 20/04/15
7. Name of the inspecting officer:- D.O. Gurmukh Singh
8. Name & designation of officer
From the building side:- Sh. Parmod Sharma (Manager)
9. Year of construction:-
10. Applicant's letter No:- 4498/Joint C.P./Lic.(H) Dated 05/03/2015

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement (Existing)	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 Mtr.	06 Mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 No	02 No.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	90 Cm each	90 Cm each	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01 No	01 No	MR
	E. Width of corridor	1.00 Mtr.	1.00 Mtr.	MR
	F. Door size	1.0 Mtr.	1.0 Mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	N/A	N/A
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	08 Nos.	10 Nos.	MR

	2) Types	ABC & CO2	ABC, CO2 & W.CO2	
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01 No.	01 No.	MR
	2) Length of hose reel hose	30 mm	30 mm.	MR
	3) Nozzle diameter	5 mm	5 mm.	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump output	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450LPM	450LPM	MR
	b) Head of pump	30 Mtr.	30 Mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank	N/A	N/A	N/A

	capacity			
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	5,000 Ltrs.	5,000 Ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the guest house were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No.F6/DFS/MS/2012/GH/1074 dated 23/03/2012, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended