

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**


No.F6/DFS/MS/EH/2015/ NO2/631

Dated: 29/04/15

**FIRE SAFETY CERTIFICATE**

Certified that the **M/S My Bar Headquarters (A Unit of Sransh Traders Pvt. Ltd.)** located at **N-49, 2<sup>nd</sup> floor, Connaught Place, New Delhi** building comprised of **Ground + Mezzanine + 2 Upper Floors and My Bar at 2<sup>nd</sup> floor** was inspected by the officer concerned of this department on **23/04/15** in the presence of **Mr. Gurvinder Singh** and found that the said premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Assembly Building Group D (My Bar at 2<sup>nd</sup> floor only)** with effect from ~~---~~ 29/04/15 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued ~~---~~ 29/04/15 at New Delhi by.



(Dr. G. C. Misra)  
Chief Fire Officer

Copy to:-

1. Dr. P.K. Sharma,  
Medical Officer of Health,  
NDMC, Palika Kendre, New Delhi.
2. The Manager,  
M/S My Bar,  
(A Unit of Bravo Hotels Pvt. Ltd.)  
N-49, 2<sup>nd</sup> floor, Connaught Place, New Delhi



**Condition for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry”.

## INSPECTION REPORT

1. Name & address of the building:- M/S My Bar Headquarters  
(A Unit of Sransh Traders Pvt. Ltd.) at  
N-49, 2<sup>nd</sup> floor, Cannaught  
Place, New Delhi
2. Type of occupancy:- Group – D Assembly Building  
Gr. + Mezzanine + 2 upper floor  
(My Bar at 2<sup>nd</sup> floor)
3. Type of case:- Fresh
4. Details of previous FSC:- NA
5. Fire safety directives No.- N/A
6. Date of inspection:- 23/04/15
7. Name of the inspecting officer:- D.O. Gurmukh Singh &  
A.D.O. Manoj Sharma
8. Name & designation of officer  
From the building side:- Mr. Gurvinder Singh
9. Year of construction:- Old Heritage.
10. Applicant's letter No:- MOH/D-443/(Licensing)SI-I dated 09/02/15

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	09 mtr.	12 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	A. Number of staircases			
	1. Upper floors	02 Nos.	03 Nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.50 mtr.	1.50 mtr & 2 Nos. 1.20 mtr.	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
		01	02	MR
	E. Width of corridor			
		N/A	N/A	N/A
	F. Door size			
		2 mtr.	2 mtr.	MR
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management System</b>			
	1) Basements			
		N/A	N/A	N/A

h

muk


	2) Upper floors	12 a/c per	Natural	MR
<b>5.</b>	<b>Fire Extinguishers</b>			
	1) Total numbers	08 Nos.	08 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	ISI	Provided	MR
<b>6.</b>	<b>First-Aid Hose Reel</b>			
	1) Total number	01	01	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm	MR
<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	Required	Provided	MR
	2) Location of main panel	Required	Provided	MR
	3) Location of repeater panel	Required	Provided	MR
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	N/A	N/A	N/A
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	N/A	N/A	N/A
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1) Basement	N/A	N/A	N/A
	2) Upper floors,	N/A	Provided	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	100 mm	100 mm	MR
	2) Number of hydrants per floor	01	01	MR
	3) Hose box	01	01	MR
<b>12.</b>	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
<b>13.</b>	<b>Pumping Arrangement</b>			
	1)Ground level	N/A	N/A	N/A
	a)Discharge of main pump	N/A	N/A	N/A
	b)Head of main pump	N/A	N/A	N/A
	c)Number of main pump	N/A	N/A	N/A
	d)Jockey pump out put	N/A	N/A	N/A
	e)Jockey pump head	N/A	N/A	N/A
	f)Stand by pump output	N/A	N/A	N/A
	g)Stand by pump head	N/A	N/A	N/A
	h)Auto starting/Manual stopping	N/A	N/A	N/A
	2)Terrace level			
	a)Discharge of pump	450LPM &	450LPM & 280 LPM	MR
	b)Head of pump	40 mtr.	40 mtr.	MR
	c)Power supply	Required	Provided	MR
	d)Auto starting of pump	Required	Provided	MR

h

Man

17/3

<b>14.</b>	<b>Captive Water Storage for Fire Fighting</b>			
	1)Under ground tank capacity	N/A	N/A	N/A
	a)Draw-off connection	N/A	N/A	N/A
	b)Fire service inlet	N/A	N/A	N/A
	c)Access to tank	N/A	N/A	N/A
	d)Over head tank capacity	10,000 ltrs.	10,000 ltrs.	MR
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16.</b>	<b>Provision of Lifts.</b>			
	a)Pressurization of lift shaft	N/A	N/A	N/A
	b)Pressurization of lift lobby	N/A	N/A	N/A
	c)Communication in lift car	N/A	N/A	N/A
	d)Fireman's switch	N/A	N/A	N/A
	e)Lift signage	N/A	N/A	N/A
<b>17.</b>	<b>Stand by Power Supply</b>	Required	Provided	MR
<b>18.</b>	<b>Refuge Area</b>	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
<b>19.</b>	<b>Fire Control Room</b>	N/A	N/A	N/A
	a)Detector system panel	N/A	N/A	N/A
	b)Flow switch panel	N/A	N/A	N/A
	c)PA system panel	N/A	N/A	N/A
	d)Battery backup	N/A	N/A	N/A
	e)Building floor plan	N/A	N/A	N/A
<b>20.</b>	<b>Special Fire Protection System for Protection of special Risk, if any:</b>			N/A



The fire protection systems provided in the restaurant were randomly tested, checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, grant of fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / is recommended please.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

*G.S Chauhan*  
23/4/15

*M.K. Sharma*  
23/4/15

Name :- G.S Chauhan  
Designation :- DO (CD)

Name :- M.K. Sharma  
Designation :- ADO (CC)