

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**

**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

**Fax: 23412593, E-mail: [cfohq.dlfire@nic.in](mailto:cfohq.dlfire@nic.in), Tel:- 011-23414333**


NO.F6/DFS/MS/2015/ 52/613

Dated: 27/04/15


**FIRE SAFETY CERTIFICATE**

Certified that M/s AMP Motors located at Plot No. G-3, Block B-1, Mohan Co-operative Industrial Estate, Mathura Road, New Delhi, comprised of two tier basements, stilt, ground plus seven upper floors was inspected by the officer concerned of this department on 13-04-2015 in the presence of Mr. Rizvi & Mr. Subhash Chandra, Project Incharge and found that the said building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises / building is fit for **occupancy class Business** with effect from 27/04/15 for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules,2010.

Issued on 27/04/15 at New Delhi by.



(Dr. G.C. MISRA)  
CHIEF FIRE OFFICER

92 

Copy to: -

1. The Authorised Signatory, M/s AMP Motors, Plot No. G-3, Block B-1, Mohan Co-operative Industrial Estate, Mathura Road, New Delhi
2. The Joint Director (Bldg.) C&I, DDA, Building Section, INA, Vikas Sadan, New Delhi.

**Conditions for the validity of fire safety certificate**

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

## INSPECTION REPORT

1. Name & address of the building : M/s AMP Motors, Plot No. G-3, Block B-1, Mohan Co-operative Industrial Estate, Mathura Road, New Delhi.
2. Type of Occupancy : Business Occupancy
3. Type of Case : New Case
4. Details of previous NOC : N/A
5. Fire Safety directives letter No : F.6/MS/DFS/MS/BP/2013/117 dated 07.01.2013.
6. Date of inspection : 13.04.2015
7. Name of the Inspecting Officers : Atul Garg, DCFO(SZ) Dharampal (DO, SZ),  
M.K.Chattopadhyay, ADO (M. Road)
8. Name and designation of officers from the building side : Mr. Rizvi & Mr.Subhash Chandra, Project Incharge
9. Year of Construction : 2013-14
10. Applicant's letter No. : Nil dated 04.03.2015

The building is comprised of two tier basements, stilt, ground plus seven upper floors

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	09 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	06 mts	Provided	MR
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-	-	-
	• Upper Floors	02	Provided	MR
	• Basements	02	Provided	MR
	b. Width of staircases	-	-	-
	• Upper Floors	1.50 mts each	Provided	MR
	• Basements	1.50 mts each	Provided	MR
	c. Protection of exits	-	-	-
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	e. No. of continuous staircases to terrace	02	Provided	MR
	g. Width of Corridor	1.5 mts	Provided	MR
	h. Door Size	1.5 mts	Provided	MR

*(Signature)*



3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Sealing of electrical shafts</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Water Curtain</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Fire Dampers</li> </ul>	Required	Provided	MR
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	30 a/c per hour	Provided	MR
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	12 a/c per hour	Provided	MR
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> </ul>	40	Provided	MR
	<ul style="list-style-type: none"> <li>• Types</li> </ul>	CO <sub>2</sub> , WCO <sub>2</sub>	Provided	MR
	<ul style="list-style-type: none"> <li>• IS marking</li> </ul>	ISI marked	Provided	MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>	02	Provided	MR
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>	30 m	Provided	MR
	<ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>	5 mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>	Required	Provided at GF	MR
	<ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> </ul>	Required	Provided at each floor	MR
	<ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Hooters' Location</li> </ul>	Required	Provided at each floor	MR
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	Required	Provided	MR
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Upper Floor</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>	Required	Provided	MR
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>	150 mm	Provided	MR
	<ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> </ul>	Required (02)	Provided	MR

	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	Required (02)	Provided	MR
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	Required	Provided (04)	MR
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	Required	Provided(04)	MR
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>	---	---	---
	<ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> </ul>	2280, 2850 LPM	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Head of Main pump</li> </ul>	88 mts	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Number of main pumps</li> </ul>	02	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Jockey Pump out put</li> </ul>	280, 180 LPM	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Jockey pump head</li> </ul>	88 mts	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Standby Pump out put</li> </ul>	2850 LPM	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Standby Pump Head</li> </ul>	88 mts	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Auto Starting/ Manual stopping</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Terrace level</li> </ul>	-----	-----	-----
	<ul style="list-style-type: none"> <li>➤ Discharge of pump</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Head of the pump</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Power Supply</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Auto Starting of pump</li> </ul>	N/A	N/A	N/A
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> </ul>	1,00,000 lts	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Draw-off connection</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Access to tank</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Overhead Tank capacity</li> </ul>	10,000 lts	Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Pressurization of Lift lobby</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Communication In lift Car</li> </ul>	Required	Provided	MR




	<ul style="list-style-type: none"> <li>Fireman's Grounding Switch</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Lift Signage</li> </ul>	Required	Provided	MR
17	<b>Standby power supply</b>	Required	Provided	MR
18	<b>Refuge Area.</b>			
	➤ Total Area	Required (160 m <sup>2</sup> )	Provided	MR
	➤ Location	Required	Provided at 6 <sup>th</sup> floor	MR
19	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>Detector System Panel</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Flow Switch Panel</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>PA System Panel</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Batter backup</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Building Floor Plans</li> </ul>	Required	Provided	MR
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	Provided	MR


The fire protection systems provided in the building were test checked and found functional at the time of inspection.


All the shortcomings pointed out by this department vide letter no. F.6/DFS/MS/School/2014/2762 dated 05.12.2014 have been complied.

In view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, it is recommended to grant fire safety certificate under the Delhi Fire Service Act-2007 & Rules-2010.

DFA is put up for approval & signature please

  
ATUL GARG  
DCFO (SZ)

  
DHARAMPAL BHARDWAJ  
DO (SZ)

  
M.K.CHATTOPADHYAY  
ADO (M. Road)