

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/2015/CNG/w2/650

Dated: 01/05/2015

**FIRE SAFETY CERTIFICATE**

Certified that the CNG Station located at Service Centre No. S-18, Pitam Pura, Sub Jone, H-4, Delhi, comprised of Ground + One upper floor only owned / occupied by Indraprastha Gas Limited has already been issued NOC / FSC by this department vide letter No. F5(3A)/DFS/CNG/09/254 dated 11/08/2009. The premises was re-inspected by the officer concerned of this department on 06.04.2015 in the presence of Mr. Sanjay Tiwari (Manager) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Hazardous (Group J) with effect from 01/05/2015 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010 subject to conditions printed below.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

Issued on 01/05/15 at New Delhi by.

  
(SANTOKH SINGH)  
CHIEF FIRE OFFICER  
Phone:-23414250

Copy to :-

1. General Manager (Fire & Safety), Indraprastha Gas Limited, IGL Bhawan, Plot No.4, Community Centre, R.K. Puram, Sec.-9, New Delhi.

INSPECTION REPORT

1. Name & address of the building: **CNG Station, Service Centre No. S-18, Pitam Pura, Sub Jone, H-4, Delhi.**
2. Type of Occupancy : **Hazardous**
3. Type of Case : **Renewal**
4. Details of previous NOC : **F5(3A)/DFS/CNG/09/254 dated 11/08/2009**
5. Fire Safety directives Letter No. : **F5(3A)/DFS/CNG/09/170 dated 16/05/2009**
6. Date of inspection : **06/04/2015**
7. Name of the Inspecting Officer : **Udaivir Singh (A.D.O. Wazir Pur)**
8. Name and designation of Officer  
from the building side : **Mr. Sanjay Tiwari (Manager)**
9. Year of Construction : **2009**
10. Applicant's letter No. : **IGL/F & S/2014-15/15/92 dated 09/12/2014**

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL / NBC-IV / OISD / Guidelines Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6mtr	30mtr	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	N/A	N/A	N/A
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	1mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	14	14	M/R
	• Types	ISI marked	Provided	M/R



6.	First – Aid Hose Reels			
	• Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
7.	Automatic fire detection and alarming system			
	• Type of detector	Hand Held explosive Meter / Detector	Provided	MR
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System / water spray system (Exempted)			
	• Ground Floor	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level	N/A		
	• Discharge of main pump	N/A	N/A	
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
14.	Captive water Storage for fire fighting			
	• Underground tank	N/A	N/A	N/A

N/10

		Required	Provided	MR
15	Exit Signage			
16.	Provision of Lifts			N/A
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			N/A
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Batter backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note:- During the inspection no flammable material was found stored in the premises.

1. The boundary wall is 6ft height and barbed wired.
2. No smoking board in Hindi & English are displayed.
3. The premises is properly illuminated.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. **F5(3A)/DFS/CNG/09/254 dated 11/08/2009** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.