

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2015/ND2/657

Dated: 01/05/15

FIRE SAFETY CERTIFICATE

Certified that the EDMC Primary School No.1 at Mandawali Fazal Pur, Delhi-92, owned/occupied by EDMC Primary School No.1, comprised of ground plus one upper floor was issued Fire Safety Certificate vide letter no. No.F.6/DFS/MS/School/2012/851 dated 07.03.12. The school building was inspected by the officer concerned of this department on 22.04.2015 in the presence of Smt. Nirmal Gaur (Incharge) of school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular no.F.16/Estate/CC/FS/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education and found that the GF+FF of building is fit for occupancy class B "Educational Building" with effect from 01/05/15 for a period of three years, subject to conditions printed overleaf.

Issued on 01/05/15 at New Delhi by



(Dr.G.C.Misra)
Chief Fire Officer
Ph.011-23414333



To,

The Principal
EDMC Primary School No.1(Girls)
Mandawali Fazal Pur, Delhi-92

Copy to:-

1. The Dy. Director of Education
East Delhi Municipal Corporation
Udyog Sadan, 419, FIE, Patparganj, Delhi.
2. The Principal
EDMC Primary School No.1(Boys)
Mandawali Fazal Pur, Delhi-92

- Conditions -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
- 6 . "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J'[sub rule(1) of rule 37] along with a copy of this certificate,six months prior to its expiry"
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

- Name & address of the building : EDMC Primary School at Mandawali Fazal Pur,
No.1,Delhi-92.
2. Building is comprised of : Ground +one upper floor
3. Type of Occupancy : Educational
4. Type of Case : **Renewal**
5. Details of Previous FSC : F.6/DFS/MS/School/2012/851 dated 07.03.12
6. Fire Safety Circular No. : F.16/Estate/CC/FS/2011/3298 to 3398
dated 1.3.11
7. Date of Inspection : **22.04.2015**
8. Name of the Inspecting officers : ADO R.K.Yadav
9. Name and designation of
Officer from the building side : Smt. Nirmal Gaur (Incharge).
10. Year of Construction : 2009-2010
11. Applicant's letter No : Dated 02.03.2015


| NO. | Minimum Standards on fire prevention and fire safety U/R33 | Circular Requirement | Provided at Site | Remarks |
|-----|---|----------------------|------------------|---------|
| 1 | Access to building | | | |
| | <ul style="list-style-type: none"> Road width Gate width Width of internal road | 06 Mtrs. | 06 Mtrs. | MR |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 2 | Number, Width, Type and Arrangement of Exits | | | |
| | a. Number of Staircases | | | |
| | <ul style="list-style-type: none"> Upper Floor Basement | 02 Nos. | 02 Nos. | MR |
| | | N/A | N/A | N/A |
| | B. Width of Staircases | | | |
| | <ul style="list-style-type: none"> Upper Floor Basement | 1.5 M | 1.5 M each | MR |
| | | N/A | N/A | N/A |
| | c. Protection of exits | | | |
| | <ul style="list-style-type: none"> Fire check door Pressurization | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | d. No. of continuous staircases to terrace | 01 No. | 02 Nos. | MR |
| | e. Width of Corridor | 1.5 M | 2 M | MR |
| | f. Door Size | 1.0 Mtrs | 1.0 Mtrs | MR |
| | Compartmentation. | | | |
| | <ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire rating of shaft door Water curtain Fire Dampers | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 4 | Smoke Management System. | | | |
| | <ul style="list-style-type: none"> Basement Upper floor | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 5. | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> Total numbers Types | 06 Nos. | 08 Nos. | MR |
| | | ABC & Co2 | ABC & Co2 | MR |
| | <ul style="list-style-type: none"> IS marking | ISI marked | ISI marked | MR |

| | | | | |
|----|---|-----|-----|-----|
| 6 | First-aid-Hose Reels. | | | |
| | Total numbers of each floor | N/A | N/A | N/A |
| | • Length of hose reel hose | N/A | N/A | N/A |
| | • Nozzle diameter | N/A | N/A | N/A |
| 7 | Automatic fire detection and alarming system. | | | |
| | • Type of detectors | N/A | N/A | N/A |
| | • Location of main panel | N/A | N/A | N/A |
| | • Location of repeater panel | N/A | N/A | N/A |
| | • Alternate source of power | N/A | N/A | N/A |
| | • Hooter's location | N/A | N/A | N/A |
| 8 | MOEFA | N/A | N/A | N/A |
| 9 | Public address System. | N/A | N/A | N/A |
| 10 | Automatic Sprinkler System. | N/A | N/A | N/A |
| | • Basement | N/A | N/A | N/A |
| | • upper floor | N/A | N/A | N/A |
| | • sprinkler above false ceiling | N/A | N/A | N/A |
| 11 | Internal Hydrants | N/A | N/A | N/A |
| | • size of riser/down-comer | N/A | N/A | N/A |
| | • Number of hydrants per floor | N/A | N/A | N/A |
| | • Hose Box | N/A | N/A | N/A |
| 12 | Yard Hydrants. | N/A | N/A | N/A |
| | • Total number of hydrants | N/A | N/A | N/A |
| | • Hose Box | N/A | N/A | N/A |
| 13 | Pumping Arrangements. | N/A | N/A | N/A |
| | • Ground Level | N/A | N/A | N/A |
| | ➤ Discharge of main Pump | N/A | N/A | N/A |
| | ➤ Head of Main Pump | N/A | N/A | N/A |
| | ➤ Number of main pumps | N/A | N/A | N/A |
| | ➤ Jockey pump out put | N/A | N/A | N/A |
| | ➤ Jockey pump head | N/A | N/A | N/A |
| | ➤ Standby pump out put | N/A | N/A | N/A |
| | ➤ Standby pump Head | N/A | N/A | N/A |
| | ➤ Auto Starting /Manual stopping | N/A | N/A | N/A |
| | ➤ Pump House Access | N/A | N/A | N/A |
| | • Terrace Level | N/A | N/A | N/A |
| | ➤ Discharge of pump | N/A | N/A | N/A |
| | ➤ Head of the Pump | N/A | N/A | N/A |
| | ➤ Power supply | N/A | N/A | N/A |
| | ➤ Auto Starting of pump | N/A | N/A | N/A |
| 14 | Captive Water Storage for Fire Fighting. | N/A | N/A | N/A |
| | • Underground tank capacity | N/A | N/A | N/A |
| | ➤ Draw-off connection | N/A | N/A | N/A |
| | ➤ Fire service inlet | N/A | N/A | N/A |
| | ➤ Access to tank | N/A | N/A | N/A |
| | • Overhead Tank capacity | N/A | N/A | N/A |
| 15 | Exit Signage. | N/A | N/A | N/A |

| | | | | |
|----|--|-----|-----|-----|
| 16 | Provision of Lifts. | N/A | N/A | N/A |
| | • Pressurization of Lift Shaft | N/A | N/A | N/A |
| | • Pressurization of Lift lobby | N/A | N/A | N/A |
| | • Communication in lift car | N/A | N/A | N/A |
| | • Firemen's grounding switch | N/A | N/A | N/A |
| | • Lift Signage | N/A | N/A | N/A |
| 17 | Standby power supply | N/A | N/A | N/A |
| 18 | Refuge Area. | N/A | N/A | N/A |
| | • Total area | N/A | N/A | N/A |
| | • Location | N/A | N/A | N/A |
| 19 | Fire Control Room | N/A | N/A | N/A |
| | • Detector system panel | N/A | N/A | N/A |
| | • Flow switch panel | N/A | N/A | N/A |
| | • PA system panel | N/A | N/A | N/A |
| | • Battery backup | N/A | N/A | N/A |
| | • Building Floor Plans | N/A | N/A | N/A |
| 20 | Special Fire Protection systems for protection of special Risks, if any: | N/A | N/A | N/A |

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The FSC issued vide letter no. F.6/DFS/MS/School/2012/851 Dated 07.03.12 renewal under the circular no. F.16/Estate/CC/FS/2011/3298 to 3398 dated 1.3.11 is recommended


 Signature of the Inspecting Officer 22/4/2015
 Name:-R.K.Yadav
 Designation:-ADO (LN)