

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. FG/DFS/MS/2015/1021760

Dated: 13/5/2015

FIRE SAFETY CERTIFICATE

Certified that Haldiram Products Pvt. Ltd. at 5A, 6, 7 of "D" Mall, Sector-10, Rohini, Delhi-110085 comprised of Ground + Mezzanine Floor only owned / occupied by Haldiram Products Pvt. Ltd was granted NOC by this department vide letter no F6/DFS/MS/2012/1070 dated 23/03/2012. The premise was re-inspected by the officers concerned of this department on 17/04/2015 in presence of Mr. Alok Bajpai (Manager) and found that the building have deem complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and premises is fit for Assembly Building Div- D-5 occupancy with effect from 13/5/2015 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of Delhi Fire Service Rules, 2010.

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able by guests in an event of emergency.
2. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
3. The fire suppression / protection arrangements provided in the restaurant are to minimize losses, if maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
4. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
5. This report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 13/5/15 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250



Copy to:

1. The Dy Health Officer, North Delhi Municipal Corporation, Health Department, Rohini Zone, Sector-V, Rohini, Delhi-110085 for information.
2. The Authority Signatory Haldiram Products Pvt. Ltd. at 5A, 6, 7 of "D" Mall, Sector-10, Rohini, Delhi-110085

INSPECTION REPORT

Ground + Mezzanine Floor

1. Name & address of the building : Haldiram Products Pvt. Ltd. at 5A, 6, 7 of "D" Mall, Sector -10
Rohini, Delhi-110085
2. Type of Occupancy : Restaurant Assembly building Sub Div- D-5
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2012/1070 dated 23/03/2012
5. Fire Safety directives letter No : nil
6. Date of inspection : 17/04/2015
7. Name of the Inspecting Officers : DO (NW)
8. Name and designation of officers
from the building side : Mr. Alok Bajpai (Manager)
9. Year of Construction :
10. Applicant's letter No. : nil dated 18/03/2015

S. No	Minimum Standards on fire prevention and fire safety U/R 33	BBL & NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	12 mtr	Provided	M.R.
	• Gate width	----	No gate provided	----
	• Width of internal road	06 mtr	Provided	M/R
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02 S/C 02 mtr	1.36 mtr , 02 mtr	M.R.
	• Basements	02 S/C 02 mtr	1.36 mtr , 02 mtr	M.R.
	b. Width of staircases			
	• Upper Floors	02 S/C 02 mtr	1.36 mtr , 02 mtr	M.R.
	• Basements	02 S/C 02 mtr	1.36 mtr , 02 mtr	M.R.
	c. Protection of exits			
	• Fire check door	R	P	M/R
	• Pressurization			
	d. No. of continuous staircases to terrace	---	---	---
	e. Width of Corridor	---	---	---
	f. Door Size	1.50 mtr 2 mtr	P P	M/R M/R
3	Compartmentation.			
	➤ Fire check door	R	P	M/R
	➤ Sealing of electrical shafts	R	P	M/R
	➤ Fire Rating of shaft door	R	P	M/R

9/N

	➤ Water Curtain	N.A	N.A	N.A
	➤ Fire Dampers	N.A	N.A	N.A
4	Smoke Management System.			
	➤ Basements	30 a/c per hour	P	M.R.
	➤ Upper floors	12 a/c per hour	P	M.R.
5	Fire Extinguishers			
	➤ Total numbers	One @ 300 m ² ISI marked	5	M.R.
	➤ Types		ABC / CO2	M.R.
	➤ IS marking		yes	M.R.
6	First-Aid Hose Reels.			
	• Total numbers on each floor	one	P	M.R.
	• Length of hose reel hose	30mm	(One in common area)	M.R.
	• Nozzle diameter	5mm	Yes	M.R.
7	Automatic fire detection and alarming system.			
	➤ Type of detectors	R	Provided in restaurant common with Mall	M.R.
	➤ Location of Main Panel	R	Ground Floor	Already issued NOC of D mall
	➤ Location of Repeater Panel	R	In side common area on GF	M/R
	➤ Alternate source of power	R	Provided	M/R
	➤ Hooters' Location	R	At strategic location	M/R
8	MOEFA	R	Provided on mez. Floor and common area on GF	M.R.
9	Public Address System.	NR	Provided	---
10	Automatic Sprinkler System.			
	➤ Basement	N/A	Provided with mall	N/A
	➤ Upper Floor	R	Provided in restaurant & Mall	M.R.
	➤ Sprinkler above false ceiling	R	Provided on GF + Mez. Floor	M.R.
11	Internal Hydrants			
	➤ Size of riser/down-comer	NR	Provided with mall	---
	➤ Number of hydrants per floor	NR	One in common area	---
	➤ Hose Box	NR	One in common area	---
12	Yard Hydrants.			
	➤ Total number of hydrants	N/R	Two	---
	➤ Hose Box	N/A	yes	---

10/2

13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	4500 LPM	Common with mall	M.R.
		70 M	Common with mall	M.R.
		—	—	—
		180 LPM	Common with mall	M.R.
		70 M	Common with mall	M.R.
		4500 LPM	Common with mall	M.R.
		70 M	Common with mall	M.R.
		R	Common with mall	M.R.
		R	Common with mall	M.R.
		—	—	—
		—	—	—
		—	—	—
		—	—	—
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	1,50,000 ltr	Common with mall	M.R.
		R	Common with mall	M.R.
		R	Common with mall	M.R.
		R	Common with mall	M.R.
		10,000 ltr	Common with mall	M.R.
		R	Provided	MR
15	Exit Signage.			
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	Provided in mall	N/A
		N/A	Provided in mall	N/A
		N/A	Provided in mall	N/A
		N/A	Provided in mall	N/A
		N/A	Provided in mall	N/A
		N/A	Provided in mall	N/A
17	Standby power supply	R	Provided in mall	M.R.

18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	R	Common with mall	M.R
	• Flow Switch Panel	R	Common with mall	M.R
	• PA System Panel	R	Common with mall	M.R
	• Batter backup	R	Common with mall	M.R
	• Building Floor Plans	R	Common with mall	M.R
20	Special Fire Protection Systems for Protection of special Risks, if any:		No special risk seen at time of inspection	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. **F6/DFS/MS/2012/1070 dated 23/03/2012** Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

Defto (nw)

Signature of the Inspecting Officer

Name

Designation

[Signature]
29/4/15
Do (nw)

294/Defto @ 15
8/5/15