

A-41, Mangolpuri, Block- A, Industrial Area, Phase-II, Delhi.

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/2015/W21 787

Dated: 18/05/2015


FIRE SAFETY CERTIFICATE

Certified that A – 41, Block A, Mangol Puri, Industrial Area, Phase- II, New Delhi. Comprised of Ground + Mezzanine + First Upper Floor owned / occupied by Mr. Anil Wadhawan was granted NOC by this department vide letter no. F6/DFS/MS/2012/1084 dated 26/03/2012. The premises was re-inspected by the officers concerned of this department on 29/04/2015 in the presence of Sh. Gurvinder Singh (Chief Manager) of the factory and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010. Hence the Fire Safety Certificate is renewed and a premise is fit for Bank Chest (Business Building) with effect from 18/05/2015 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rule, 2010.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 18/05/15 at New Delhi by

  
(SANTOKH SINGH)  
Chief Fire Officer  
Ph: 011-23414250

**Copy to:**

1. A – 41, Block A, Mangol Puri, Industrial Area, Phase- II, New Delhi
2. Executive Engineer (Building), North Delhi Municipal Corporation, Rohini Zonal, Rohini Zone Building Sector - 05, Delhi

**INSPECTION REPORT**

**Ground + M + First Floor**

1. Name & address of the building: A-41, Mangolpuri, Block- A, Industrial Area, Phase-II, Delhi.
2. Type of Occupancy : Business Building Bank Chest
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2012/1084 Dated 26/03/2012
5. Fire Safety directives letter No : F6/DFS/MS/BP/2012/711 dated 29/02/2012
6. Date of inspection : 29/04/2015
7. Name of the Inspecting Officers : DO (NW) & ADO (RN)
8. Name and designation of officers  
from the building side : Gurvinder Singh (Chief Manager)
9. Year of Construction : 1992
10. Applicant's letter No. : Nil Dated 10/04/2015

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Accessible	P	M/R
		4.5 mtr	P	M/R
		--	--	--
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	02 --	02 --	M/R --
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	1.25 m & 1.5 mtr --	P --	M/R --
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	R N.A	P --	M/R --
	e. No. of continuous staircases to terrace	--	--	--
	g. Width of Corridor	1.5 mtr	P	M/R
	h. Door Size	1 mtr	1.25 mtr	M/R
3	<b>Compartmentation.</b>			



	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	R	P	M/R
		--	No Electric shaft	--
		--	--	--
		N.A	--	--
		N.A	--	--
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour	N.A	---
		12 a/c per hour	P	M/R
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	06	06	M/R
			WCo2 – 03, Co2 type - 03	M/R
		ISI marked	P	M/R
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	01 no	P	M/R
		30 m	P	M/R
		5 mm	P	M/R
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	N/A	N/A	N/A
		--	--	--
		--	--	--
		--	--	--
		--	--	--
8	<b>MOEFA</b>	R	P	M/R
9	<b>Public Address System.</b>	N/A	N/A	N/A
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	R	P	M/R
		R	P	M/R
		No false ceiling	--	--
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	100 mm	P	M/R
		01	P	M/R
		01	P	M/R
12	<b>Yard Hydrants.</b>			

	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>	N/A	01	N/A
		--	--	--
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>• Ground Level <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>• Terrace level <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>			
		--	--	--
		--	--	--
		--	--	--
		--	--	--
		--	--	--
		--	--	--
		--	--	--
		900 LPM	P	M/R
		30 mtr	P	M/R
		R	P	M/R
		R	P	M/R
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	--	--	--
		--	--	--
		--	--	--
		--	--	--
		10000 LTR	P	M/R
15	<b>Exit Signage.</b>	R	P	M/R
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	N/A	N/A	N/A
		--	--	--
		--	--	--
		--	--	--
		--	--	--
17	<b>Standby power supply</b>	R	P	M/R
18	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	N/A	N/A	N/A
		—	—	—



A-41, Mangolpuri, Block- A, Industrial Area, Phase-II, Delhi.

19	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> </ul>	—	—	—
	<ul style="list-style-type: none"> <li>• Flow Switch Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• PA System Panel</li> </ul>	—	—	—
	<ul style="list-style-type: none"> <li>• Batter backup</li> </ul>	—	—	—
	<ul style="list-style-type: none"> <li>• Building Floor Plans</li> </ul>	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. : **F6/DFS/MS/2012/1084 dated 26/03/2012** Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

*RK*  
Rajesh Kumar  
AO IRM

Designation


DeFO (W2)

Signature of the Inspecting Officer

Name

*Geeth*  
13/5/15

Designation



10 (13/5)