

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO.F6/DFS/MS/2015/CNG/652/771

Dated: 14/05/2015

FIRE SAFETY CERTIFICATE

Certified that the CNG Filling Station (IGL) at Sanjay Gandhi Transport Nagar, Phase-II, Delhi-110042 comprised of Single Story Building was granted NOC by this department vide letter no F.5(3A)/DFS/CNG/ 2005/96 dated 24/03/2005. The premises was re-inspected by officer concerned of this department on 16/04/2015 in the presence of Sh. Harvinder Singh (Manager) and found that the premises have deemed complied with fire prevention & fire safety requirement in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and the building/ premises fit for occupancy CNG Filling Station Group 'J' with effect from 14/05/2015 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rule, 2010 subject to conditions printed below.

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
- 2 Any loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use for land if any.
- 6 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 14/05/15 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250



Copy to:

1. Chief General Manager (project), Indraprastha Gas Limited, IGL Bhawan, Plot no-4, Community Center, R.K. Puram, Sect-9, New Delhi-110022

INSPECTION REPORT

1. Name & address of the building : CNG Filling Station (IGL) at Sanjay Gandhi Transport Nagar Phase-II, Delhi-110042
2. Type of Occupancy : CNG Filling Station **Group 'J'**
3. Type of Case : Renewal
4. Details of previous NOC : F.5(3A)/DFS/CNG/ 2005/96 dated 24/03/2005
5. Fire Safety directives letter No : -----
6. Date of inspection : 16/04/2015
7. Name of the Inspecting Officers : ADO (BW)
8. Name and designation of officers
from the building side : Sh. Harvinder Singh (Manager)
9. Year of Construction :
10. Applicant's letter No. : IGL/F&S/2014-15/15/19 dated 09/12/2014 _____

Plot Area:1080 m2

| --- | Minimum Standards on fire prevention and fire safety U/R 33 | NBC 015D Requirement 179-16 | Provided at site | Remarks MR/NMR |
|-----|---|-----------------------------------|------------------|-------------------|
| 1 | Access to building | | | |
| | • Road width | Required | 30m | MR |
| | • Gate width | N.A | N.A | N.A |
| | • Width of internal road | N.A | N.A | N.A |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | — | — | — |
| | • Upper Floors | N.A | N.A | N.A |
| | • Basements | N.A | N.A | N.A |
| | b. Width of staircases | — | — | — |
| | • Upper Floors Old case | N.A | N.A | N.A |
| | • Basements | N.A | N.A | N.A |
| | c. Protection of exits | — | — | — |
| | • Fire check door | N.A | N.A | N.A |
| | • Pressurization | N.A | N.A | N.A |
| | d. No. of continuous staircases to terrace | N.A | N.A | N.A |
| | e. Width of Corridor | — | — | — |
| | f. Door Size | Required | 1mtr | M.R. |

| | | | | |
|----|---|-----|-----|-----|
| 12 | Yard Hydrants. | | | |
| | • Total number of hydrants | N.A | N.A | N.A |
| | • Hose Box | N.A | N.A | N.A |
| 13 | Pumping Arrangements. | | | |
| | • Ground Level | | | |
| | ➤ Discharge of main Pump | N.A | N.A | N.A |
| | ➤ Head of Main pump | N.A | N.A | N.A |
| | ➤ Number of main pumps | N.A | N.A | N.A |
| | ➤ Jockey Pump out put | N.A | N.A | N.A |
| | ➤ Jockey pump head | N.A | N.A | N.A |
| | ➤ Standby Pump out put | N.A | N.A | N.A |
| | ➤ Standby Pump Head | N.A | N.A | N.A |
| | ➤ Auto Starting/ Manual stopping | N.A | N.A | N.A |
| | ➤ Pump House Access | N.A | N.A | N.A |
| | • Terrace level | | | |
| | ➤ Discharge of pump | N.A | N.A | N.A |
| | ➤ Head of the pump | N.A | N.A | N.A |
| | ➤ Power Supply | N.A | N.A | N.A |
| | ➤ Auto Starting of pump | N.A | N.A | N.A |
| 14 | Captive Water Storage for fire fighting. | | | |
| | • Underground tank capacity | N.A | N.A | N.A |
| | ➤ Draw-off connection | N.A | N.A | N.A |
| | ➤ Fire service inlet | N.A | N.A | N.A |
| | ➤ Access to tank | N.A | N.A | N.A |
| | • Overhead Tank capacity | N.A | N.A | N.A |
| 15 | Exit Signage. | N.A | N.A | N.A |
| 16 | Provision of Lifts. | | | |
| | • Pressurization of Lift Shaft | N.A | N.A | N.A |
| | • Pressurization of Lift lobby | N.A | N.A | N.A |
| | • Communication In lift Car | N.A | N.A | N.A |
| | • Fireman's Grounding Switch | N.A | N.A | N.A |
| | • Lift Signage | N.A | N.A | N.A |
| 17 | Standby power supply | N.A | N.A | N.A |

N-10

CNG Filling Station (IGL) at Sanjay Gandhi Transport Nagar, Phase-II, Delhi-110042

| | | | | |
|----|---|---|-----|-----|
| 18 | Refuge Area. | | | |
| | ➤ Total Area | N.A | N.A | N.A |
| | ➤ Location | N.A | N.A | N.A |
| 19 | Fire Control Room | | | |
| | • Detector System Panel | N.A | N.A | N.A |
| | • Flow Switch Panel | N.A | N.A | N.A |
| | • PA System Panel | N.A | N.A | N.A |
| | • Batter backup | N.A | N.A | N.A |
| | • Building Floor Plans | N.A | N.A | N.A |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | 06 Fire buckets filled with sand, No smoking boards were found displayed in Hindi & English. No loose electric wiring were seen in premises & 04 CO2 45 kg flooding system found provided | | M.R |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no F.5(3A)/DFS/CNG/ 2005/96 dated 24/03/2005. Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended

Signature of the Inspecting Officer

Name

Designation

[Handwritten Signature]
[Handwritten Designation]

Signature of the Inspecting Officer

Name

Designation

[Handwritten Signature]
 20/4/15
 AD (B/W)

