

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001**

No. *F6/DFS/MS/motel/2015/52/1778*

Dated: *15/5/15*

**FIRE SAFETY CERTIFICATE**

Certified that M/S Friendshiptime.Com Private Ltd, Khasra No.22/10, 22/11,23/6,23/7, 8/2/1,23/15, 23/7,23/14/1,8/2/1,23/15,23/16/1 at NH-8, Village Samlkha, New Delhi-37, comprised of basement, ground and one upper floor (Basement=Services, GF=Banquet Hall, Dinning Area, Kitchen& 26 Guest Rooms, 1<sup>st</sup> Floor 23 Guest Rooms, Total=49 Guest Rooms), Owned/Occupied by M/S Friendshiptime.Com Private Ltd was granted NOC by this department vide letter No. F6/DFS/MS/2011/Motel/2381, dated 30-09-2011. The premises was re-inspected by the officer concerned of this department on 11-05-2015 in the presence of Sh. Kirti Nanda (Manager) and found that the said motel building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Residential (Motel) with effect from *15/05/2015* for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on *15/05/2015* at New Delhi by

*15/5*  
  
**(Dr.G.C.Misra)  
Chief Fire Officer  
T.No.011-23414333**

Copy to:-1. The Deputy Health Officer, Health Department, Najafgarh Zone, MCD, New Delhi-110043 w.r.t. letter No.DHO/NGZ/2014/3413, dated 22.04.15. *dc*

2. M/S Friendshiptime.Com Private Ltd, Khasra No.22/10,22/11,23/6,23/7, 8/2/1,23/15, 23/7,23/14/1,8/2/1,23/15,23/16/1 at NH-8, Village Samlkha, New Delhi-37.

**Conditions for the validity of fire safety certificate are as under :-**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. The employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All fire fighting equipments shall be maintained in perfect working condition all time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate in form J, six month prior to its expiry.

### INSPECTION REPORT

1. Name & address of the building : M/S Friendshiptime.Com Private Ltd, Khasra No.22/10,22/11,23/6, 23/7,8/2/1,23/15,23/7,23/14/1,8/2/1,23/15,23/16/1 at NH-8, Village Samlkha, New Delhi-37.
2. Building is comprised of : B+G+1,(Basement=Services, GF=Banquet Hall, Dinning Area, Kitchen& 26 Guest Rooms, 1<sup>st</sup> Floor 23 Guest Rooms.(Total=49 Guest Rooms).
3. Type of Occupancy : Motel
4. Type of Case : Old Case
5. Details of Previous NOC : No.F.6/DFS/MS/2011/Motel/2381, dated-30.09.11.
6. Fire Safety direction letter No :No.F6/DFS/MS/BP/GH/2005/351, Dated 18.02.2005
7. Date of Inspection : 11.05.2015.
8. Name of the Inspecting Officers: : Vedpal (ADO)
9. Name and designation of Officer  
from the building side : Sh. Kirti Nanda (Manager)
10. Year of Construction : 2006.
11. Applicant's letter No : No.DHO/NGZ/2014/3413, dated 22.04.15.

S.No	Minimum Standards on fire prevention and fire safety U/R33	Old NOC Requirements	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6m	32 m	MR
	Gate width	5m	5m	MR
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases	.		
	Upper Floor	05nos.	04 nos.	MR(old case)
	Basement	08nos.	10nos.	MR
	B. Width of Staircases			
	Upper Floor	1.5/1.25m.	1.46,1.4,1.25 &1.25m	MR(old case)
	Basement	1.5/1.35m	1.6,5=1.5,1.3, 1.25,1.15& 1.16m	MR(old case)
	c. Protection of exits	Required	Provided	MR
	Fire check door	Required	Provided	MR
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	1no.	03nos	MR
	g. Width of Corridor	1.25m	1.5m	MR
	h. Door Size	1m.	1m.	MR
3	Compartmentation			
	Fire check door	Required	Provided	MR
	Sealing of electrical shafts	Required	Provided	MR
	Fire rating of shaft door	Required	Provided	MR
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	Required	Provided	MR
4	Smoke Management System.			
	Basement	30a/c per hour	Provided	MR
	Upper floor(in restaurant only)	12 a/c per hour	Provided	MR



5.	Fire Extinguisher			
	Total numbers	48nos.	48nos.	MR
	types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers at each floor	03nos.	03nos.	MR
	Length of hose reel hose	30m	30m.	MR
	Nozzle diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	Heat & Smoke	N.A.
	Location of main panel	N.A	Reception	N.A.
	Location of repeater panel	N.A	Security Room	N.A.
	Alternate source of power	N.A.	Provided	N.A.
	Hooters	N.A.	Provided	N.A
8	MOEFA	Required	Provided	MR
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	Basement	Required	Provided	MR
	upper floor(Restaurant only)	Required	Provided	MR
	sprinkler above false ceiling	Required	Provided	MR
11	Internal Hydrants			
	size of riser/down-comer	100mm	100mm	MR
	Number of hydrants per floor	03nos.	03nos.	MR
	Hose Box	03nos.	03nos.	MR
12	Yard Hydrants.			
	Total number of hydrants	05nos.	05nos.	MR
	Hose Box	05nos.	05nos.	MR
13	Pumping Arrangements.			
	• Ground Level	Required	Provided	MR
	➤ Discharge of main Pump	2280LPM	2280LPM	MR
	➤ Head of Main Pump	60m	60m	MR
	➤ Number of main pumps	01no	01no	MR
	➤ Jockey pump out put	180LPM	180LPM	MR
	➤ Jockey pump head	60m	60m	MR
	➤ Standby pump out put	2280LPM	2280LPM	MR
	➤ Standby pump Head	60m	60m	MR
	➤ Auto Starting /Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace Level	N.A.	N.A.	N.A.
	➤ Discharge of pump	N.A.	N.A.	N.A.
	➤ Head of the Pump	N.A.	N.A.	N.A.
	➤ Power supply	N.A.	N.A.	N.A
	➤ Auto Starting of pump	N.A	N.A.	N.A.

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	100000Liters	100000Liters	MR
	Draw-off connection	Required	Provided	MR
	Fire service inlet	Required	Provided	MR
	Access to tank	Required	Provided	MR
	Overhead Tank capacity	10000Liters	10000Liters.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	Required	Provided	MR
	Firemen's grounding switch	Required	Provided	MR
	Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided DG Set	MR
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Battery backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for of special Risks, if any:	Required	ABC 10 KG Fire Extinguishers Provided	MR

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the NOC issued vide letter No.F.6/DFS/MS/2011/Motel/2381, dated 30.09.2011 renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly DAF is put up for kind consideration please.

 12/15  
Signature of the Inspecting Officer

Name : Vedpal

Designation : ADO