

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F.6/DFS/MS/school/2015/52/807

Dated: 20/5/2015

**FIRE SAFETY CERTIFICATE**

Certified that Guru Premasukh Jain Model School, B-1, Bhagya Vihar, Jain Colony, Rani Khera, Delhi-110081 comprised of (Single block) Ground + First floor of a premises comprised of ground + two upper floors owned/occupied by Guru Premasukh Jain Model School has already been issued fire safety certificate vide letter no. F.6/DFS/MS/2009/3658 Dated 02/12/2009. The premises was re-inspected by the officer from this department on dated 08/04/2015 in the presence of Sh. S.P Rana (Principal) and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of Letter No 262-362 dated 17/01/2005 issued by Director of Education and the building / premise is fit for occupancy of Group Class B (Educational) with effect from 20/5/2015 for a period of three years, subject to compliance of the conditions mentioned below:

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 20/5/15 at New Delhi by

  
(SANTOKH SINGH)  
Chief Fire Officer  
Ph: 011-23414250

**Copy to:**

1. The Principal, Guru Premasukh Jain Model School, B-1, Bhagya Vihar, Jain Colony, Rani Khera, Delhi-110081.
2. The Director of Education, Old Secretariat, Delhi.

## INSPECTION REPORT

Premises Ground + Two floors.  
Gr. And Gr. + One School running  
Second floor- Jain Sabha sadhu

1. Name & address of the building : Guru Prem Sukh Jain Model School, B-1, Bhagya Vihar, Jain Colony, Rani Khera, Delhi-110081.
  2. Type of Occupancy : Educational
  3. Type of Case : Renewal
  4. Details of previous NOC : Letter No. F.6/DFS/MS/2009/3658 Dated: 02/12/2009 ✓
  5. Fire Safety directives letter No : Dir of Education. Cir .17/01/2005
  6. Date of inspection : 08/04/2015
  7. Name of the Inspecting Officers : ADO (BW)
  8. Name and designation of officers  
from the building side : Sh. S.P Rana (Principal)
  9. Year of Construction : 2006 + 2013
  10. Applicant's letter No. : \_GPSJ/Fire/15 Dated 26/02/2015 \_\_\_\_\_
- Plot area:-640 sq Yards Covered area:-900 sq Yards No.'s of Student:-535 No.'s of Classrooms:-16

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building (FSC Required for Gr. + One floor only)</b>			
	• Road width	Accessible	Accessible	MR
	• Gate width	—	—	—
	• Width of internal road	—	—	—
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	—	—	—
	• Upper Floors	01	02	MR
	• Basements	—	—	—
	b. Width of staircases	—	—	—
	• Upper Floors	Old Case	Old Case	Old Case
	• Basements	—	—	—
	c. Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	R	P	MR
	g. Width of Corridor	—	—	—
		1.00 mtr	1.00 mtr	MR
	h. Door Size			



N-19

3	<b>Compartmentation.</b>			
	• Fire check door	—	—	—
	• Sealing of electrical shafts	—	—	—
	• Fire Rating of shaft door	—	—	—
	• Water Curtain	—	—	—
	• Fire Dampers	—	—	—
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	—	—
	• Upper floors	12 a/c per hour	—	—
5	<b>Fire Extinguishers</b>			
	• Total numbers	7 ABC	08	MR
	• Types	ISI marked	ABC	MR
	• IS marking		Yes	MR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	One	P	MR
	• Length of hose reel hose	30 m	P	MR
	• Nozzle diameter	5 mm	P	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	—	—	—
	• Location of Main Panel	—	—	—
	• Location of Repeater Panel	—	—	—
	• Alternate source of power	—	—	—
	• Mooters' Location	—	—	—
8	<b>MOEPA</b>	—	—	—
9	<b>Public Address System.</b>	—	—	—
10	<b>Automatic Sprinkler System.</b>			
	• Basement	—	—	—
	• Upper Floor	—	—	—
	• Sprinkler above false ceiling	—	—	—
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	—	—	—
	• Number of hydrants per floor	—	—	—
	• Hose Box	—	—	—

N-21

18	<b>Refuge Area.</b>			
	➤ Total Area	—	—	—
	➤ Location	—	—	—
19	<b>Fire Control Room</b>			
	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

**Note:-**General requirements for school as per Director of Education Circular dated 17/01/2005

1. Escape route ..... **Clear** .....
2. LPG cylinders in laboratories ..... **No** .....
3. Electric wiring ..... **Concealed**.....MCB .....**Provided**.....  
Electric circuit.....**ELCB provided**.....
4. Electric meter board ...**not Below S/C** .....
5. Basement use as per BBL 1983..... **N/A** .....
6. Emergency telephone no. board... **Displayed** .....
7. Generator set..... **No** .....

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no F.6/DFS/MS/2009/3658 Dated: 02/12/2009. Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended..

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name

Designation

Designation

*(Handwritten Signature)*  
21.4.15  
AOO (B/W)

*(Handwritten Signature)*