

McDonalds Family Restaurant at F 14/15, Model Town, New Delhi-110009

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F.6/DFS/MS/EH/2015/ *w2/789*

Dated: *19/05/2015*

FIRE SAFETY CERTIFICATE

Certified that **McDonalds Family Restaurant at F 14/15, Model Town, New Delhi-110009** located at **Ground Floor Only of** a premise comprised of **Basement, Mazzanine, Ground and Two Upper Floor** was granted NOC by this department vide letter no **F6/DFS/MS/2012/EH/1404 Dated 19/04/2012.** The premises was re-inspected by the officers concerned of this department on **17/04/2015** in the presence of **Sh. Shailendra Pandey** and observed that all the fire prevention and fire safety arrangement as provided in the premises found in good working condition. The premises have therefore, deem complied with the requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and premises is fit for **Assembly Building** occupancy with effect from **19/05/2015** for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of fire safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on *19/05/15* at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:

1. The Dy. Health Officer Civil Line Zone, Health Department MCD, 16, Rajpur Road, Delhi
2. MCDONALDS FAMIL RESTAURANTS AT F -14/15, Model Town, Delhi 11009

14-15

McDonalds Family Restaurant at F 14/15, Model Town, New Delhi-110009

INSPECTION REPORT

1. Name & address of the building : McDonalds at F14/15, Model Town, New Delhi-110009,
2. Type of Occupancy : Assembly
3. Type of Case : Renewal
4. Details of previous NOC : F-6/DFS/MS/2012/EH/1404 Dated 19/04/2012
5. Fire Safety directives letter No : Guidelines issued for restaurants
6. Date of inspection : 17 / 04 / 2015 **Basement & Mez. Floor - Storage**
7. Name of the Inspecting Officers : DO (NW) **G.F - Restaurant**
8. Name and designation of officers from the building side : Sh. Shailendra Pandey **Upper Two Floor – Commercial Purpose**
9. Year of Construction : *Before 2008*
10. Applicant's letter No. : L.No- nil Dated 12/02/2015.

	Minimum Standards on fire prevention and fire safety U/R 33	Guide lines issued for Restaurant	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	M/R
	• Gate width	--	--	--
	• Width of internal road	--	--	--
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	N/R	02	N/R
	• Basements	--	--	--
	b. Width of staircases			
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	--	--	--
	• Pressurization	--	--	--
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	--	--	--
	f. Door Size	--	--	--
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A

McDonalds Family Restaurant at F 14/15, Model Town, New Delhi-110009

	<ul style="list-style-type: none"> Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements 	30 a/c per hour	N/A	N.A
	<ul style="list-style-type: none"> Upper floors 	12 a/c per hour	P	M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	04 ISI marked	04 02 DCP 5 Kg 02 Co ₂ type 4.5 kg Yes	M/R M/R M/R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	One at each floor 30 m 5 mm	P P P	M/R M/R M/R
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A N/A N/A N/A	P N/A N/A N/A	N/A N/A N/A N/A
8	MOEFA	R	P	M/R
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	R R --	P P --	M/R M/R --
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	N/A N/A	N/A N/A

13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	--	--	--
		--	--	--
		--	--	--
		--	--	--
		--	--	--
		--	--	--
		--	--	--
		--	--	--
		--	--	--
		450 LPM + 180 LPM	P	M/R
		40 m	P	M/R
		R	P	M/R
		R	P	M/R
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		R	P	M/R
		N/A	N/A	N/A
		5,000 ltr	P	M/R
15	Exit Signage.	R	P	M/R
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby power supply	R	16 KVA	M/R
18	Refuge Area.			

N-18

McDonalds Family Restaurant at F 14/15, Model Town, New Delhi-110009

	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	--	No special risk at present	--

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. **F6/DFS/MS/2012/EH/1404 Dated 19/04/2012** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

DCFO (w2)

Signature of the Inspecting Officer

Name

Designation

Sush
20/4/15

