

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

Fax: 23412593, E-mail: cfohq.dlfire@nic.in, Tel:- 011-23414333


NO.F6/DFS/MS/EH/2015/82/803

Dated: 19/05/15

FIRE SAFETY CERTIFICATE

Certified that M/s. McDonald's Family Restaurant located at ground floor of Erore Cinema building, shop No. 2 &3, Jungpura Extn, New Delhi-110014 is running at ground floor of Erore Cinema building was granted NOC by this department vide letter No. F.6/DFS/MS/EH/2012/227 dated 27-01-2012. The premises was re-inspected by the officer concerned of this department on 13-05-2015 in the presence of Amjad Naseem, restaurant manager and found that the said eating house have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises / building is fit for occupancy Class- D Assembly (restaurant) with effect from 19/05/15 for a period of 3(three) years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules,2010.

Issued on 19/05/15 at New Delhi by.



(Dr. G.C. MISRA)
CHIEF FIRE OFFICER

Copy to: -

1. The Joint C.P.(Lic.), Police Station, Defence Colony, 1st floor, New Delhi.
2. The Manager, M/s. McDonald's Family Restaurant, Erore Cinema building, shop No. 2 &3, Jungpura Extn, New Delhi-110014

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : M/s. McDonald's Family Restaurant, Erose Cinema building, shop No. 2 &3, Jungpura Extn, New Delhi-110014
2. Type of Occupancy : Assembly, Group-D
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/EH/2012/227 dated 27-01-2012
5. Fire Safety directives letter No : N/A
6. Date of inspection : 13-05-2015
7. Name of the Inspecting Officers : M.K.Chattopadhyay, ADO(M.Rd)
8. Name and designation of officer
9. from the building side : Amjad Naseem, restaurant manager
10. Year of Construction : 2011
11. Applicant's letter No. : CPRPL/FM/NOC/2013-14/218 dated 05.03.2015.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	N/A	Provided (06 mts)	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	Ground Floor only	-	-
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-	-	-
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits	---	---	---
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	2.0 mts	2.30 mts & 1.45 mts	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A

	<ul style="list-style-type: none"> Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour 12 a/c per hour	N/A Venting provided in kitchen	N/A MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	06 ABC, CO ₂ ISI marked	Provided Provided Provided	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 30 m 5 mm	Provided Provided Provided	MR MR MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Heat/Smoke Ground floor N/A Required Required	Provided Provided N/A Provided Provided	MR MR N/A MR MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	N/A Required N/A	N/A Provided N/A	N/A MR N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	N/A	N/A	N/A

	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	-	-	-
	➤ Discharge of main Pump	2280 LPM	Provided in Cineplex	MR
	➤ Head of Main pump	70 mts	Provided in Cineplex	MR
	➤ Number of main pumps	02	Provided in Cineplex	MR
	➤ Jockey Pump out put	480 LPM	Provided in Cineplex	MR
	➤ Jockey pump head	70 mts	Provided in Cineplex	MR
	➤ Standby Pump out put	2280 LPM	Provided in Cineplex	MR
	➤ Standby Pump Head	70 mts	Provided in Cineplex	MR
	➤ Auto Starting/ Manual stopping	Required	Provided in Cineplex	MR
	➤ Pump House Access	Required	Provided in Cineplex	MR
	• Terrace level	---	---	---
	➤ Discharge of pump	950 LPM	Provided in Cineplex	MR
	➤ Head of the pump	45 mts	Provided in Cineplex	MR
	➤ Power Supply	Required	Provided in Cineplex	MR
	➤ Auto Starting of pump	Required	Provided in Cineplex	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	2,00,000 lts	Provided in Cineplex	MR
	➤ Draw-off connection	Required	Provided in Cineplex	MR
	➤ Fire service inlet	Required	Provided in Cineplex	MR
	➤ Access to tank	Required	Provided in Cineplex	MR
	• Overhead Tank capacity	40,000 lts	Provided in Cineplex	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided (500 KVA)	MR

18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	Required	Provided	MR
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	02 ABC type fire extinguishers found provided near elect. panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F.6/DFS/MS/EH/2012/227 dated 27-01-2012, renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

DFA is put up for approval & signature please.



[Handwritten Signature]
13/5

Signature of the Inspecting Officer
Name M.K.CHATTOPADHYAY
Designation: - Asstt. Div. Officer (M.Rd)

[Handwritten Signature]
14/5/15

[Handwritten Signature]
14/5/15

[Handwritten Signature]