

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No.F6/DFS/MS/School/2015/ ND2/835

Dated: 22.05.2015

FIRE SAFETY CERTIFICATE

Certified that **Ramjas Girls Sr. Sec. School & Primary School located at Daryaganj, New Delhi** comprised of Ground floor (Ramjas Girls Sr. Sec. School) and First floor (Ramjas Primary School) was granted FSC by this department vide letter No.F6/DFS/MS/School/2012/819 dated **06/03/12**. The premises was re-inspected by the officer concerned of this department on **28/04/15** in the presence of Mrs. Sushma shiromni & Mrs. S. Mehta and found that school have deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 01.03. 2011 that the building is fit for occupancy, class **B "Educational Building"** with effect from 22.05.2015.....for a period of three years, subject to conditions printed below.

Issued on 22.05.2015 at New Delhi.


(Dr. G.C.Misra)
Chief Fire Officer
Delhi Fire Service
Ph: - 011-23414333

- Copy to:- (1) Director of Education, Old Secretariat, Delhi
(2) The Principal Ramjas Girls Sr. Sec. School Daryaganj, New Delhi
(3) The Principal Ramjas Primary School Daryaganj, New Delhi

Conditions for the validity of fire safety certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire protections measures shall be maintained in perfect conditions all the time as seen during inspection.
3. All the staff members must know the correct method of operation of fire fighting system.
4. Any lapse rendering fire fighting system/equipment non-functional shall be the risk and responsibility of the management.
5. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010.the form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

817
INSPECTION REPORT

1. Name & address of the building :- Ramjas Girls Sr. Sec. School & Primary School, Daryaganj, New Delhi-110002
2. Type of occupancy:- **Group – B Education Building.**
3. Type of case:- Renewal.
4. Details of previous FSC:- No.F6/DFS/MS/School/2012/819 dated 06/03/12.
5. Fire safety directives No.- N/A
6. Date of inspection:- 28/04/15
7. Name of the inspecting officer:- A.D.O. Mehmood
8. Name & designation of officer:-
From the building side:- Mrs. Sushma Shiromani (Principal) & Mrs. Sneha Mehta (Principal)
9. Year of construction:- Old.
10. Applicant's letter No:- RPS/Fire//2015-16 Dated 22/04/15
- Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	As per Education Circular(Existing)	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	Approachable	06 mtr	MR
	2) Gate width	4 mtr.	4 mtr.	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 Nos.	02 Nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	0.95 mtr. 1.65 mtr	0.95 mtr. 1.65 mtr	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	02 Nos.	02 Nos.	Provided
	E. Width of corridor	1.5 mtr	2.70 mtr.	N/A
	F. Door size	1.5 mtr.	1.5 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	10 Nos.	10 Nos.	MR

	2) Types	ABC	ABC	
	3) ISI marking	ISI Marked	Yes	
6.	First-Aid Hose Reel			
	1) Total number of each floor	N/A	Provided	N/A
	2) Length of hose reel hose	N/A	Provided	N/A
	3) Nozzle diameter	N/A	Provided	N/A
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	Not required	Provided	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump output	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	360 LPM	N/A
	b) Head of pump	N/A	45 mtr.	N/A
	c) Power supply	N/A	Provided	N/A
	d) Auto starting of pump	N/A	Provided	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A

10/11

	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	N/A	5000 ltrs.	N/A
15.	Exit Signage.	N/A	N/A	N/A
16.	Provision of Lifts.	N/A	N/A	N/A
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	5 KVA	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:-			N/A

The fire protection system provided in the school were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No.F6/DFS/MS/School/2012/819 dated 06/03/12, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

(Signature)

(Signature)
12/11/15

(Signature)

Mehmood
Assistant Divisional Officer