

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001

No.F6/DFS/MS/GH/2015/ NO2/822

Dated : 21/5/15

FIRE SAFETY CERTIFICATE

Certified that **Standard Hotel** located at **17, Netaji Subhash Marg, Daryaganj, New Delhi** comprised of **Ground floor (Reception), Mezzanine floor (other office), 1st floor (11 guest rooms), 2nd floor (06 guest rooms) & Third floor (05 Guest rooms +Staff Kitchen +01 store room+01 staff room) total 22 guest rooms** was granted FSC by this department vide letter No.F6/DFS/MS/GH/2012/1377 dated 17/04/2012. The premise was re-inspected by the officer concerned of this department on 28/04/15 in the presence of **Shri A.K. Singh (Manager)** of the guest house and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Residential Group A-1 22 guest rooms at 1st to 3rd floor only** with effect from 21/5/15 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 21/5/15 at New Delhi by.


(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service
Ph: - 011-23414333

Copy to: - (1) The Addl. C.P.(Lic.), Police Station,
Defence colony, 1st floor, New Delhi

(2) The Owner,
M/s Standard Hotel, 17, Netaji Subhash Marg, Daryaganj, Delhi

Conditions:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

19/12

INSPECTION REPORT

1. Name & address of the building:- M/s Standard Hotel, 17, Netaji Subhash Marg, Daryaganj, New Delhi
2. Type of occupancy:- Residential Group A-1 (Ground + Mezzanine + 3 upper floors)
3. Type of case:- 22 guest rooms
Renewal
4. Details of previous FSC: - No. F6/DFS/MS/GH/2012/1377 dated 17/04/2012.
5. Fire safety directives No.- N/A
6. Date of inspection:- 28/04/15
7. Name of the inspecting officer:- A. D.O. Mehmood
8. Name & designation of officer
From the building side:- Shri A.K. Singh (Manager)
9. Year of construction:- 1940
10. Applicant's letter No:- Nil. Dated 30/03/15

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement (Existing)	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	06 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01 No	01 No.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.18 mtr.	1.18mtr.	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01 No	01 No	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	94 cms.	94 cms.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	N/A	N/A
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			

(Signature)

	1) Total numbers	15 Nos.	15 Nos.	
	2) Types	ABC & CO2	ABC, CO2 & W.CO2	
	3) ISI marking	Required	Provided	
6.	First-Aid Hose Reel			
	1) Total number of each floor	01 No.	01 No.	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm.	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	Provided	NA
	2) Number of hydrants per floor	N/A	Provided	NA
	3) Hose box	N/A	Provided	NA
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450LPM	450LPM	MR
	b) Head of pump	30 Mtr.	30 Mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			

24

	capacity			
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	2,500 Ltrs.	2,500 Ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the guest house were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No.F6/DFS/MS/GH/2012/1377 dated 17/04/2012, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended

D.O. (Central)

Ushmit
13/5/15

Mehmood
Mehmood

Assistant Divisional Officer