

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/VG/2012/1861/21/642

Dated: 22/5/15

FIRE SAFETY CERTIFICATE

Certified that the **Versus Video Game Parlour** located at **S.F. – 10, 2nd Floor, Pacific Mall, Tagore Garden, New Delhi** was issued FSC vide Letter No. F6/DFS/MS/VG/2012/1861 dated 23-05-2012. The premises was re inspected by the officers concerned of this department on 08-05-2015 in the presence of Mr. Devender Jha (Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class “ Assembly” Group D with effect from 22/5/15 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on22/5/15..... at New Delhi by.


(Santokh Singh)
Chief Fire Officer,
Ph: 011 – 23414250.

Copy to:

1. Versus Video Game Parlour,
S.F. – 10, 2nd Floor, Pacific Mall, Tagore Garden, New Delhi
2. Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony, New Delhi – 1100149.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Versus Video Game Parlour located at S.F. – 10, 2nd Floor, Paccific Mall, Tagore Garden, New Delhi
2. Type of Occupancy : Assembly
3. Type of Case : Renewal (Situated in Mall already issued NOC vide letter no. F6/DFS/MS/2014/WZ/345 dated 11-03-2014)
4. Details of previous NOC : Letter No. F6/DFS/MS/VG/2012/1861 dated 23-05-2012
5. Fire Safety directives Letter No. : FSC Issued to the mall
6. Date of inspection : 08-05-2015
7. Name of the Inspecting Officer : Mukesh Verma, ADO (MN)
8. Name and designation of Officer
from the building side : Sh. Devender Jha (Manager)
9. Year of Construction : 2011
10. Applicant's letter No. : 4452-55/Joint C.P/Lic.(Amst.) dated 05-03-2015

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	6 m NA NA	30m Provided NA NA	MR NA NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	2 NA	Provided NA	MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	Old Case NA	Old Case NA	MR NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA NA	NA NA	NA NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	Old Case	Old Case	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA

	➤ Pump House Access	NA	Common with the mall	NA
	• Terrace level			
	➤ Discharge of pump	900 lpm	Common with the mall	MR
	➤ Head of the pump	40 m	Common with the mall	MR
	➤ Power supply	Required	Common with the mall	MR
	➤ Auto starting of pump	Required	Common with the mall	MR
14.	Captive water Storage for fire fighting: Common with the mall			
	• Under ground tank capacity	NA	2,00,000 litres	NA
	➤ Draw off connection	NA	Provided	NA
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	NA	Provided	NA
	• Overhead Tank capacity	10, 000 litres	30, 000 Litres	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/VG/2012/1861 dated 23-05-2012 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name

Designation

Designation

Mukesh Verma
ADD (M)