

No. F6/DFS/MS/School/2015/52/698

Dated: 8/5/15

FIRE SAFETY CERTIFICATE

Certified that DAV Public School, Sector-B, Pocket-1, Vasant Kunj, New Delhi-110070, comprised of Basement, Ground plus two upper floors, owned/occupied by DAV College Managing Committee, Chitra Gupta Road, Delhi was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2011/3394, dated 08-12-2011. The premises was re-inspected by the officers concerned of this department on 30-04-2015 in the presence of **Sh. Sanjay Sharma, Account Officer** and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Educational** with effect from 08/05/2015.....2015 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 08/05/2015 at New Delhi by.


(Dr.G.C.Misra)

Chief Fire Officer

T.No.011-23414333

Copy to:- 1. Principal, DAV Public School, Sector-B, Pocket-1, Vasant Kunj, New Delhi-110070.

2. Dy. Director of Education, Old Secretariat, Civil Lines, Delhi.

Conditions for the validity of fire safety certificate are overleaf:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of ``land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate in form J, six month prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : DAV Public School, Sector-B, Pocket-1, Vasant Kunj, New Delhi-110070.
2. Building is comprised of : B+G+2.
3. Type of Occupancy : Education
4. Type of Case : Renewal.
5. Details of Previous NOC : No.F.6/DFS/MS/School/2011/3394, dated 08.12.2011.
6. Fire Safety direction letter No : As per Director of Education Circular.
7. Date of Inspection : 23.04.15.
8. Name of the Inspecting Officers: : Vedpal (ADO)
9. Name and designation of Officer from the building side : Sh.Sanjay Sharma (Account Officer).
10. Year of Construction : 1989.
11. Applicant's letter No : DAV/PS/VK/2015-16/11860, dated 16.04.15.

S.No	Minimum Standards on fire prevention and fire safety as per rules.	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	12 m	MR
	Gate width	5m	5m.	MR
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases	.		
	Upper Floor	2nos.	2nos.	MR
	Basement	2nos.	1no.+ 1ramp	MR
	B. Width of Staircases		.	
	Upper Floor	1.5 m(each)	1.5m & 1.45m	MR
	Basement	1.5m	1.1m & ramp=3m	MR
	c. Protection of exits	N.A.	N.A.	N.A.
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	1no.	2nos.	MR
	g. Width of Corridor	1.5 m	1.5 m	MR
	h. Door Size	1 m	1m	MR
3	Compartmentation			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	30a/c per hour	N.A.	N.A.
	Upper floor	12 a/c per hour	N.A.	N.A.

- Note:- Staircases are segregated at ground floor and away from basement entry.

5.	Fire Extinguisher	12 nos.	40 nos.	MR
	Total numbers	WCO ₂ & ABC	WCO ₂ & ABC & CO ₂	MR
	types		Type	
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.	02nos.	02nos.	MR.
	Total numbers of each floor	30m	30m	MR.
	Length of hose reel hose	5cm	5cm	MR.
	Nozzle diameter			
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
8	MOEFA	Required	Provided	MR
9	Public address System.			
10	Automatic Sprinkler System.			
		Required	Provided	MR
	Basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of down-comer	N.A.	N.A.	N.A.
	Number of hydrants per floor	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	➤ Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	➤ Terrace Level	01no.	02nos.	MR.
	➤ Discharge of pump	450LPM	450 & 180 LPM	MR
	➤ Head of the Pump	40m	40m (each)	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	15000 liters	15000Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	N.A.	Provided	N.A.
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.


The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the Fire Safety Certificate issued vide letter No.F.6/DFS/MS/School/2011/3394, dated 08.12.2011 renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly DFA is put up please.

Signature of the Inspecting Officer

Name : Vedpal

Designation: ADO

 11/5/15

