

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

E-mail:- cfohq.dlfire@nic.in

No.F.6/DFS/MS/School/2015/ 52/1757


Fax:- 011-23412593

Dated: 13/05/15

FIRE SAFETY CERTIFICATE

Certified that the building of Mata Nand Kaur Sr. Sec. Public School, Dhansa village, New Delhi-110073, is comprised of ground plus two upper floor, but school is running at ground plus one upper floor only, was issued Fire Safety Certificate by this department vide letter F6/DFS/MS/School/2012/942 dated 15-03-2012. The School building was re-inspected by the officer concerned of this department on 05-05-2015 in the presence of Sh. Ajay Sharma (Principal) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises (**Ground plus one upper floor only**) is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed as under.

Issued on..... 13/05/15 at New Delhi.



(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to:-

1. The Principal,
Mata Nand Kaur Sr. Sec. Public School,
Dhansa village, New Delhi-110073
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi - 110054

01c sm
12/5/15

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/F

Ground plus two upper floors but school running at ground plus one upper floor only
(Mata Nand Kaur Sr. Sec. Public School, Dhansa village, New Delhi-110073)

INSPECTION REPORT

1. Name & address of the building : Mata Nand Kaur Sr. Sec. Public School, Dhansa village, New Delhi-110073
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of Previous NOC : F6/DFS/MS/School/2012/942 dated 15-03-2012
5. Fire Safety directives letter No : N/A
6. Date of inspection : 05-05-2015
7. Name of Inspecting Officer : A.D.O. Sandeep Duggal
8. Name and designation of officers
From the building side : Sh. Ajay Sharma (Principal)
9. Year of Construction : Before 2009 (Ground & First floor)
10. Applicant's letter No. : Letter No. Nil dated Nil

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<p>Accessible</p> <p>—</p> <p>—</p>	<p>12 mtrs</p> <p>4.2 & 3.8 mtrs</p> <p>—</p>	<p>M/R</p> <p>M/R</p> <p>—</p>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02 No's	02 No's	M/R
	• Basements	N/A	N/A	No basement
	b. Width of staircases			
	• Upper Floor	—	152 & 147 cms	M/R, being old case
	• Basements	N/A	N/A	No basement
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	01 No.	N/A
	e. Width of Corridor	--	235 cms	M/R
	f. Door Size	--	90 to 95 cms	M/R, being old case
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	• Basements	N/A	N/A	No basement

Ground plus two upper floors but school running at ground plus one upper floor only
(Mata Nand Kaur Sr. Sec. Public School, Dhansa village, New Delhi-110073)

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter number F6/DFS/MS/School/2012/942 dated 15-03-2012 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note: - As per the letter given by the principal of the school (Placed at C-17), the school building is comprised of ground plus two upper floors but the school is running at ground plus one upper floor only.

Sandeep
07/08/15

Signature of Inspecting Officer

Name: - Sandeep Duggal

Designation: - Asstt. Divisional Officer

Signature of Inspecting Officer

Name

Designation

Divisional Officer (South West)

K. Kumar
8/5/15

