

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. *fc/dfs/ms/motel/2015/w2/863*

Dated: *28/05/2015*

FIRE SAFETY CERTIFICATE

Certified that Just Chill Water and Fun Park located in Sydney Grand Hotel and Resort Main G.T. Karnal Road, Village Singhola, Delhi 110040 comprised of Change rooms, Costume Shop, different water rides, wave pool, rain dance only owned / occupied by Sh. Ramesh Ralhan Sydney Grand Hotel Pvt. Ltd (Just Chill Water & Fun Park) has already been issued fire safety certificate vide Letter No F6/DFS/MS/Motel/2012/2331 Dated 29/06/2012. The premise was re-inspected by the officer concerned from this department on 30/04/2015 in the presence of Sh. Ramesh Ralhan and have deem complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy under the provision of Rules 113 of regulation for licensing and controlling places of public Amusement (Other than Cinema) and performance of Public Amusement 1980 with effect from *28/05/2015* for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

1. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
2. The fire suppression / protection arrangements provided are to minimize losses, if maintained in good working condition. These systems cannot give a guarantee that there will be no fire or losses in the event of one.
3. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
4. This report may not in any way be treated as regularization of unauthorized construction, if any. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on *28/05* / *05* / 2015 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:

1. Sh. Ramesh Ralhan, Sydney Grand Hotel and Resort [Just Chill Water and Fun Park] Main G.T. Karnal Road, Village Singhola, Delhi 110040.
2. The Joint Commissioner of Police (Lic), 1st floor, Police station, Defense Colony, New Delhi.

INSPECTION REPORT**Change Rooms, Costume Shop,****Different Water Rides, Wave Pool, Rain Dance**

1. Name & address of the building : Just Chill Water and Fun Park located in Sydney Grand Hotel
Pvt Ltd, Village Singhola, Main G.T. Karnal Road, Delhi.
2. Type of Occupancy : Assembly Building
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/Motel/2012/2331 Dated 29/06/2012
5. Fire Safety directives letter No : ---
6. Date of inspection : 30 / 04 /2015
7. Name of the Inspecting Officers : DO (NW) S. S Tuli
8. Name and designation of officers
from the building side : Sh. Ramesh Ralhan
9. 9. Year of Construction : 2007
10. 10. Applicant's letter No. : 4527-33 / Jt.C.P/Lic. (Amst.) dated 05/03/2015

	Minimum Standards on fire prevention and fire safety U/R 33	Under Amusement Act [other than cinema]	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	P	M.R
	• Gate width	05 mtr	P	M.R
	• Width of internal road	06 mtr	P	--
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	NA	NA	NA
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases	NA	NA	NA
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	g. Width of Corridor	NA	NA	NA
	h. Door Size	NA	NA	NA
3	Compartmentation.			
	• Fire check door	NA	NA	NA

	<ul style="list-style-type: none"> Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour	NA	NA
		12 a/c per hour	NA	NA
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	06	06	M.R
			ABC type	M.R
		ISI marked	yes	M.R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01	P	M.R
		30 m	P	M.R
		5 mm	P	M.R
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA	N/A	P	---
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	01	P	M.R
		01	P	M.R

13	Pumping Arrangements.			
	<ul style="list-style-type: none"> ● Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access ● Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	1620 LPM	P	NOC already issued to motel building
		--	--	--
		03	P	NOC already issued to motel building
		180 LPM	P	NOC already issued to motel building
		--	--	--
		1620 LPM	P	NOC already issued to motel building
		--	--	--
		--	--	--
		--	--	--
		--	--	--
		--	--	--
		--	--	--
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> ● Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank ● Overhead Tank capacity 	50,000 ltr	P	M.R
		--	--	--
		--	--	--
		--	--	--
		--	--	--
15	Exit Signage.	R	P	M.R
16	Provision of Lifts.			
	<ul style="list-style-type: none"> ● Pressurization of Lift Shaft ● Pressurization of Lift lobby ● Communication In lift Car ● Fireman's Grounding Switch ● Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17	Standby power supply	R	P	M.R
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	NA	NA	NA
		NA	NA	NA
19	Fire Control Room			
	<ul style="list-style-type: none"> ● Detector System Panel 	NA	NA	NA

Just Chill Water and Fun Park located in Sydney Grand Hotel Pvt. Ltd, Village Singhola, Delhi 110040

	<ul style="list-style-type: none">• Flow Switch Panel	NA	NA	NA
	<ul style="list-style-type: none">• PA System Panel	NA	NA	NA
	<ul style="list-style-type: none">• Batter backup	NA	NA	NA
	<ul style="list-style-type: none">• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. **F6/DFS/MS/Motel/2012/2331 Dated 29/06/2012**. Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

(N2)

Signature of the Inspecting Officer

Name

Designation

[Handwritten Signature]
13/5/15
(111)