

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

Fax: 23412593, E-mail: [cfohq.dlfire@nic.in](mailto:cfohq.dlfire@nic.in), Tel:- 011-23414333

No. F6/DFS/MS/School/2015/ 891

Dated: 29/05/15

**FIRE SAFETY CERTIFICATE**

Certified that **M.C. Primary Girls School-1 (Urdu) located at Abul Fazal Enclave, Jamia Nagar, New Delhi-110025** comprised of ground floor only Owned/Occupied by M.C. Primary School was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2012/442 dated 09/02/2012. The school building was re-inspected by the officer concerned of this department on 20.05.2015 in presence of Mr. Asgar, Teacher of the school and found that the School management have deemed complied with the fire prevention and fire safety requirements in accordance with the Directorate of Education circular No. F.6/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 and that the school building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the under mentioned conditions.

Issued on ----- 29/05/15 ----- at New Delhi by.

  
(Dr. G.C. MISRA)  
CHIEF FIRE OFFICER

Copy To: -

1. The Commissioner, SDMC, Civic Centre, Minto road, NewDelhi-110002.
2. The Principal, M.C. Primary Girls School-1 (Urdu), Abul Fazal Enclave, Jamia Nagar, New Delhi-110025.

**Conditions for the validity of fire safety Certificate**

1. All the Fire Safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning Authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The Basement shall be used strictly as per the provisions of Building Bye Laws.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

## INSPECTION REPORT

1. Name & address of the building : S.D.M.C. Primary School-1 (Urdu), Abul Fazal Enclave, Jamia Nagar, New Delhi-110025.
1. Type of Occupancy : Educational
2. Type of Case : Renewal
3. Details of previous NOC : F6/DFS/MS/School/2012/442 dated 09/02/2012
4. Fire Safety directives letter No : Directorate of Education circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011.
5. Date of inspection : 20.05.2015
6. Name of the Inspecting Officers : M.K.Chattopadhyay, ADO(M.Rd)
7. Name and designation of officers from the building side : Mr. Asgar, Teacher
9. Year of Construction : 2007
10. Applicant's letter No. : Nil dated 06.05.2015.

S.D.M.C. Primary School-1 (Urdu) is comprised of ground floor only.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Directorate of Education circular	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	Required	Provided	MR
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	Ground Floor only	N/A	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-----	-----	-----
	• Upper Floors	Ground Floor only	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	N/A	N/A	N/A

3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Sealing of electrical shafts</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Water Curtain</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Fire Dampers</li> </ul>	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	30 a/c per hour	N/A	N/A
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	12 a/c per hour	N/A	N/A
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> </ul>	06 nos.	Provided	MR
	<ul style="list-style-type: none"> <li>• Types</li> </ul>	ABC, CO <sub>2</sub> type	Provided	MR
	<ul style="list-style-type: none"> <li>• IS marking</li> </ul>	ISI marked	Provided	MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>	----	N/A	N/A
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>	30 m	N/A	N/A
	<ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>	5 mm	N/A	N/A
7	<b>Automatic fire detection and alarming system</b>	<b>Not required</b>		
	<ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Hooters' Location</li> </ul>	N/A	N/A	N/A
8	<b>MOEFA</b>	N/A	N/A	N/A
9	<b>Public Address System.</b>	N/A	N/A	N/A
10	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Upper Floor</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>	N/A	N/A	N/A





	<ul style="list-style-type: none"> <li>• Communication In lift Car</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Fireman's Grounding Switch</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Lift Signage</li> </ul>	N/A	N/A	N/A
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Flow Switch Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• PA System Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Batter backup</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Building Floor Plans</li> </ul>	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	01 ABC type fire extinguisher is provided near elect. Panel.	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/School/2012/442 dated 09/02/2012, renewal under the Directorate of Education circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 is recommended.

DFA is put up for approval & signature please

DO(SZ)

DCFO(SZ)

Signature of the Inspecting Officer  
Name (M.K. CHATTOPADHYAY)  
Designation: - Assistant Divisional Officer