

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE
(SEE SUB -RULE (1) OF RULE 35)
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE: NEW DELHI-110001

No.F.6/DFS/BH-2015/WZ/ 682

Dated 06/05/15

FIRE SAFETY CERTIFICATE

Certified that the Banquet Hall at Khasra No. 523/2(0-09), 528/2(1-0), Main Rohtak Road, Mundka, Delhi-41 comprised of Basement, Ground Floor and Two Upper Floors only, owned / occupied by Smt. Sudha Gupta & others have complied with the fire prevention and fire safety requirement in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 22.04.2015 in presence of Sh. Sanjay Bansal (Partner) and that the building/premises is fit for occupancy class Assembly (Group D) Banquet Hall with effect from 06 / 05 /2015 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire service rule, 2010.

Conditions for the validity of Fire Service Certificate:


1. All the fire safety arrangement provided therein shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the / construction etc. shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. "The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' (sub rule (1) of rule 37) along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs. Delhigovt.nic.in](http://www.dfs.Delhigovt.nic.in)

Issued on 06/05/15.....at New Delhi by


(Santokh Singh)
Chief Fire Officer
Delhi Fire Service
Phone -23414250

Copy to:

1. Smt. Sudha Gupta & others, Banquet Hall at Khasra No. 523/2(0-09), 528/2(1-0), Main Rohtak Road, Mundka, Delhi-41.



INSPECTION REPORT

1. Name & address of the building: Banquet Hall at Khasra No.523/2(0-09),
528/2(1-0), Main Rohtak Road, Mundka, Delhi-41.
2. Type of Occupancy : Assembly (Banquet Hall)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2014/2062 dated 02/09/2014
6. Date of inspection : 22/04/2015
7. Name of the Inspecting Officer : D.O. (West) & A.D.O. (JWP)
8. Name and designation of Officer
from the building side : Sh. Sanjay Bansal (Partner)
9. Year of Construction : 2014-15
10. Applicant's letter No. : -Nil Dated 17/03/2015

Basement + Ground + Two Upper
Floors Only

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 mtr	Provided	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	2	2 Stairs & 1Ramp	MR
	b. Width of staircases			
	• Upper floors	2.00 mtr.	2.00 mtr	MR
	• Basements	2.00 mtr	2.00 mtr & 3.50mtr (Ramp)	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	2	Provided	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	2.00mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			

6.	• Total numbers on each floor	1 at each floor ✓	2 at each floor	MR
	• Length of hose reel hose	30 mtr ✓	Provided	MR
	• Nozzle diameter	5 mm ✓	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	Smoke ✓	Provided	MR
	• Location of Main Panel	Ground Floor ✓	Provided	MR
	• Location of Repeater Panel	Alternate Floor ✓	Provided	NMR
	• Alternate source of power	Required ✓	Provided	MR
	• Hooters' Location	Ground Floor ✓	Provided	MR
8.	MOEFA	Required ✓	Provided	MR
9.	Public Address System	Required ✓	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required ✓	Provided	MR
	• Upper Floor	NR	NR	NR
	• Sprinkler above false ceiling	NR	NR	NR
11.	Internal Hydrants			
	• Size of riser/down-comer	150 mm ✓	Provided	MR
	• Number of hydrants per floor	One	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NR	NR	NR
	• Hose Box	NR	NR	NR
13.	Pumping Arrangements			
• Ground Level				
• Discharge of main pump	2280 LPM ✓	Provided	MR	
➤ Head of main pump	40 MH ✓	Provided	MR	
➤ Number of main pumps	One	Provided	MR	
➤ Jockey pump out put	180 LPM ✓	Provided	MR	
➤ Jockey pump head	40 MH ✓	Provided	MR	
➤ Standby Pump out put	2280LPM ✓	Provided	MR	
➤ Standby Pump Head	40 MH ✓	Provided	MR	
➤ Auto Staring/Manual stopping	Required	Provided	MR	
➤ Pump House Access	Required	Provided	MR	
• Terrace level				
➤ Discharge of pump	900LPM ✓	Provided	MR	
➤ Head of the pump	40MH ✓	Provided	MR	
➤ Power supply	Required	Provided	MR	
➤ Auto starting of pump	Required	Provided	MR	
14.	Captive water Storage for fire fighting			
	• Under Ground Tank capacity	50,000 Ltr ✓	Provided	MR
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Fire service outlet	N/A	N/A	N/A

		N17		
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	Required	Provided	MR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Batter backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Name : Sunil Chawdhary

Designation : D.O. (West)

Signature of the Inspecting Officer

Name : Ashok Kumar Jaiswal

Designation : A. D.O. (Jwala Puri)

Ashok Jaiswal
24/4/15