

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001.


No. F.6/DFS/MS/EH/2015/ 52/869

Dated: 28/05/15

FIRE SAFETY CERTIFICATE

Certified that the **The Barbeque company**, Premises No. H1-1&2, G.F, F.F, Anand Vihar, Jail Road, Hari Nagar, New Delhi-110064, is running at Ground and First floor only. The above restaurant was issued FSC vide Letter No. F6/DFS/MS/EH/2011/3262 dated 30-11-2011 in the name of Moon Walk Restaurant, now owned/ occupied by M/s The Barbeque Company ( a unit of Savour Hospitality). The Restaurant building was re-inspected by the officers concerned of this department on 19.05.2015 in the presence of Sh. Karandeep Singh (Partner) and found that the M/s The Barbeque Company ( a unit of Savour Hospitality) have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the restaurant building/premises is fit for occupancy class Group D assembly building w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....28/05/15.....at New Delhi.



(Dr. G C Misra)  
Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. The Deputy Health Officer,  
West Zone (SDMC), Public Health Department,  
Vishal Enclave, New Delhi-110027.  
(Letter No. D-332/HD/WZ dated 11.05.2015)
2. Authorised Signatory,  
The Barbeque company, Premises No. H1-1&2,  
G.F, F.F, Anand Vihar, Jail Road,  
Hari Nagar, New Delhi-110064



Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

**INSPECTION REPORT**

1. Name & address of the building : M/s The Barbeque company, Premises No. H1-1&2, G.F, F.F, Anand Vihar, Jail Road, Hari Nagar, New Delhi-110064.
2. Type of Occupancy : Group-D. (Assembly)
3. Type of Case : Renewal
4. Details of Previous NOC : No. F6/DFS/MS/EH/2011/3262 dated 30-11-2011
5. Fire Safety directives letter No : N/A
6. Date of inspection : 19.05.2015
7. Name of Inspecting Officer : D.O S.K. Tomar & A.D.O Sandeep Duggal
8. Name and designation of officers  
From the building side : Sh. Karandeep Singh (Partner)
9. Year of Construction : Before 2008
10. Applicant's letter No. : Letter No.D-332/HD/WZ dated 11.05.2015

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ BBL Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	<p style="text-align: center;">Accessible</p> <p style="text-align: center;">--</p> <p style="text-align: center;">--</p>	<p style="text-align: center;">12 mtrs. 200 cms.</p> <p style="text-align: center;">--</p>	<p style="text-align: center;">M/R</p> <p style="text-align: center;">M/R</p> <p style="text-align: center;">--</p>
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	<p style="text-align: center;">Two</p> <p style="text-align: center;">N/A</p>	<p style="text-align: center;">Two</p> <p style="text-align: center;">N/A</p>	<p style="text-align: center;">M/R</p> <p style="text-align: center;">No Basement</p>
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	<p style="text-align: center;">--</p> <p style="text-align: center;">N/A</p>	<p style="text-align: center;">128 cm &amp; 108 cm</p> <p style="text-align: center;">N/A</p>	<p style="text-align: center;">M/R Being old building</p> <p style="text-align: center;">No Basement</p>
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	<p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p>	<p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p>	<p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p>
	d. No. of continuous staircases to terrace			
		--	--	--
	e. Width of Corridor			
		--	108 cm	M/R Being old building
	f. Door Size			
		--	118X205 cm	M/R
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	<p style="text-align: center;">N/A</p> <p style="text-align: center;">--</p> <p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p>	<p style="text-align: center;">N/A</p> <p style="text-align: center;">sealed</p> <p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p>	<p style="text-align: center;">N/A</p> <p style="text-align: center;">--</p> <p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p>
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	--	N/A	No Basement



Restaurant is running at ground and first floor  
(M/s The Barbeque company, H1-1&2, G.F, F.F, Anand Vihar, Jail Road, Hari Nagar, New Delhi-110064)

	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	--	Exhaust fans are provided	M/R
<b>5.</b>	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	Two at each floor	Provided	M/R
		A.B.C 5 Kg/ Co2 ISI marked	Provided	M/R
			Provided	M/R
<b>6.</b>	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	One 30 mtrs. 5 mm	Provided	M/R
			Provided	M/R
			Provided	M/R
<b>7.</b>	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	-- -- -- --	Smoke & heat type Provided -- -- DG set of 82.5 KVA At exits	M/R -- -- M/R --
<b>8.</b>	<b>MOEFA</b>	Required	Provided	M/R
<b>9.</b>	<b>Public Address System</b>	--	Provided	M/R
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Ground Floor</li> <li>Sprinkler above false ceiling</li> </ul>	N/A -- --	N/A Provided --	No Basement M/R --
<b>11.</b>	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
<b>12.</b>	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	N/A N/A	N/A N/A	N/A N/A
<b>13.</b>	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/Manual Stopping</li> </ul> </li> </ul>	N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A

	<ul style="list-style-type: none"> <li>• Pump House Access</li> <li>• Terrace level <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>	N/A	N/A	N/A
		Required	450 LPM, 180 LPM	M/R
		30 mtrs	30 mtrs each	M/R
		Required	Provided	M/R
		--	--	--
<b>14.</b>	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity <ul style="list-style-type: none"> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> </ul> </li> <li>• Overhead Tank capacity</li> </ul>	--	--	--
		--	--	--
		--	--	--
		--	--	--
		5000 ltrs.	5000 ltrs.	M/R, Being old case
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	M/R
<b>16.</b>	<b>Provision of Lifts.</b>	<b>(No lift)</b>		
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
<b>17.</b>	<b>Standby power supply</b>	Required	DG set of 82.5 KVA	M/R
<b>18.</b>	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
<b>19.</b>	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Battery backup</li> <li>• Building Floor Plans</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
<b>20.</b>	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	N/A	N/A	N/A

N/10

Restaurant is running at ground and first floor  
(M/s The Barbeque company, H1-1&2, G.F, F.F, Anand Vihar, Jail Road, Hari Nagar, New Delhi-110064)

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the fire safety certificate issued vide letter no. No. F6/DFS/MS/EH/2011/3262 dated 30-11-2011 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

S. K. Tomar  
22/5/15

Signature of Inspecting Officer

Name: - S. K. TOMAR

Designation: - DIVISIONAL OFFICER

Sandeep  
22.05.2015

Signature of Inspecting Officer

Name SANDEEP DVGAL

Designation ASST. DIV. OFFICER