

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

Fax:- 011-23412593

E-mail ID: cfohq.dlfire@nic.in

No.F6/DFS/MS/EH/2015/ **NDZ/934**

Dated **08/06/15**

FIRE SAFETY CERTIFICATE

Certified that the **Eating House (Cafeteria)** located at **Main Gate, National Zoological Park, Mathura Road, New Delhi** comprised of **Ground floor only** was granted FSC by this department vide letter No. **F6/DFS/MS/2EH/2012/1433** dated **20/04/2012**. The premise was re-inspected by the officer concerned of this department on **28/05/15** in the presence of **Sh. Shiv Kumar Singh (Owner)** and found that the said restaurant building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Assembly Building Group – D** with effect from **08/06/15** for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued **08/06/15** at New Delhi by.


(Dr. G.C. Misra)
Chief Fire Officer
Ph. 011-23414333

Copy to:-

1. Medical Officer of Health,
Health Department, City Zone,
Car Parking, Asaf Ali Road, New Delhi.
2. Sh. Shiv Kumar Singh,
Kiosk, Main Gate Outgate, National Zoological park,
Mathura road, New Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Eating House (Cafeteria) located at Main Gate, National Zoological Park, Mathura Road, New Delhi (One store & restaurant in open area)
2. Type of occupancy : Assembly Building (Ground floor only)
3. Type of case:- : Renewal
4. Details of previous FSC : F6/DFS/MS/EH/2012/1433 dated 20/04/12
5. Fire safety directives No. : NA
6. Date of inspection:- : 28/05/15
7. Name of the inspecting officer : Sh. M.K. Sharma ADO/CC
8. Name & designation of officer
From the building side : Sh. Shiv Kumar Singh(Owner)
9. Year of construction :
10. Applicant's letter No : Nil dated 16/04/15

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing	Provided at site	Old Case Remarks MR/NMR
1.	Access to Building			
	1) Road width	12.5 Mtr.	12.5 Mtr.	MR
	2) Gate width	3.25 mtr.	3.25 mtr.	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	NA	NA	NA
	2. Basements	NA	NA	NA
	B. Width of staircase			
	1. Upper floors	NA	NA	NA
	2. Basements	NA	NA	NA
	C. Protection of exits			
	1. Fire check door	NA	NA	NA
	2. Pressurization	NA	NA	NA
	D. No. of continuous staircase to terrace	NA	NA	NA
	E. Width of corridor	NA	NA	NA
	F. Door size	1 mtr.	1 mtr.	MR
3.	Compartmentation			
	1) Fire check door	NA	NA	NA
	2) Sealing of electrical shafts	NA	NA	NA
	3) Fire rating of shaft door	NA	NA	NA
	4) Water curtain	NA	NA	NA
	5) Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	1) Basements	NA	NA	NA
	2) Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	1) Total numbers	08 Nos.	08 Nos.	MR
	2) Types	ABC & CO2	ABC, CO2 & W.CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number	01	01	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm.	MR

7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	NA	NA	NA
	2) Location of main panel	NA	NA	NA
	3) Location of repeater panel	NA	NA	NA
	4) Alternate source of power	NA	NA	NA
	5) Hooter's Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	NA	NA	NA
	3) Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	1) Size of riser/down-comer	NA	NA	NA
	2) Number of hydrants per floor	NA	NA	NA
	3) Hose box each floor	NA	NA	NA
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	225 LPM	2250 LPM	MR
	b) Head of main pump	40 mtr.	40 mtr.	MR
	c) Number of main pump	01	01	MR
	d) Jockey pump out put	NA	NA	NA
	e) Jockey pump head	NA	NA	NA
	f) Stand by pump output	NA	NA	NA
	g) Stand by pump head	NA	NA	NA
	h) Auto starting/Manual stopping	NA	NA	NA
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	NA	NA	NA
	a) Draw-off connection	NA	NA	NA
	b) Fire service inlet	NA	NA	NA
	c) Access to tank	NA	NA	NA
	d) Over head tank capacity	25,00 Ltrs.	25,00 Ltrs.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	NA	NA	NA
	b) Pressurization of lift lobby	NA	NA	NA
	c) Communication in lift car	NA	NA	NA
	d) Fireman's switch	NA	NA	NA

7/10

	e) Lift signage	NA	NA	NA
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	NA	NA	NA
	Total area location	NA	NA	NA
19.	Fire Control Room	NA	NA	NA
	a) Detector system panel	NA	NA	NA
	b) Flow switch panel	NA	NA	NA
	c) PA system panel	NA	NA	NA
	d) Battery backup	NA	NA	NA
	e) Building floor plan	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the restaurant building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F6/DFS/MS/EH/2012/1433 dated 20/04/2012 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer

M.K. Sharma

Name :- M.K. Sharma
Designation :- ADO (CC)

Do (ed)

28/5/15

28/5/15