

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F.6/DFS/MS/EH/2015/ W2/930

Dated: 08/06/2015

FIRE SAFETY CERTIFICATE

Certified that **McDonalds Family Restaurant "D-Mall" Shop No 25-27, Twin District Centre, Rohini, Delhi** comprised of **Ground Floor Only** was granted NOC by this department vide letter no **F6/DFS/MS/2012/EH/1408 Dated 19/04/2012**. The premises was re-inspected by the officer concerned of this department on **20/05/2015** in the presence of **Sh. Dharmender Nath Thakur** and observed that all the fire prevention and fire safety arrangement as provided in the premises found in good working condition. The premises have therefore, deem complied with the requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and premises is fit for **Assembly Building** occupancy with effect from **08/06/2015** for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of fire safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on. 08/06/15 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:

1. The Dy. Health Officer, Rohini Zone, Health Department MCD, Sector - 5, Rohini, Delhi
2. Mc Donald's Family Restaurant "D-Mall" Shop No 25-27, Twin District Centre, Rohini, Delhi

INSPECTION REPORT

1. Name & address of the building : McDonalds Family Restaurant "D- Mall" Shop no 25-27
Ground Floor, Twin District Centre, Rohini, Delhi
2. Type of Occupancy : Assembly **Restaurant running on ground floor only**
3. Type of Case : Renewal
4. Details of previous NOC : F-6/DFS/MS/2012/EH/1408 Dated 19/04/2012
5. Fire Safety directives letter No : **nil**
6. Date of inspection : 20 / 05 / 2015
7. Name of the Inspecting Officers : DO (NW)
8. Name and designation of officers
from the building side : Sh. Dharmender Nath Thakur
9. Year of Construction : 2010
10. Applicant's letter No. : L.No- nil Dated 03/04/2015.

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	09	P	M/R ✓
	• Gate width		No gate to premise	--
	• Width of internal road	--	--	--
2	Number, Width, Type & Arrangement of Exits (On Ground Floor only)			
	a. Number of staircases			
	• Upper Floors	N/R	02	N/R ✓
	• Basements	--	--	--
	b. Width of staircases			
	• Upper Floors	N/A	N/A	N/A ✓
	• Basements	N/A	N/A	N/A ✓
	c. Protection of exits			
	• Fire check door	--	--	--
	• Pressurization	--	--	--
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	--	--	--
	f. Door Size	2 mtr	02 mtr & 1.70 mtr	Being old bldg & issued NOC by deptt. Earlier letter at 26.8.10 ✓
3	Compartmentation.			

	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	R	Common with mall	M/R
		R	Common with mall	M/R
		R	Common with mall	M/R
		--	--	--
		--	--	--
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	Separate ventilation for LT panel room provided	M/R
		12 a/c per hour		P
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	04	04	M/R
		ISI marked	ABC type	M/R
			Yes	M/R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	One at each floor	P	M/R
		30 m	P	M/R
		5 mm	P	M/R
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	Smoke/Heat	Provided in restaurant	M.R
		GF	Common with mall	M.R
		R	Common with mall	M.R
		R	Common with mall	M.R
		R	Common with mall	M.R
8	MOEFA	R	P	M.R
9	Public Address System.	R	Common with mall	M.R
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	R	Common with mall	M.R
		R	Common with mall	M.R
		R	Common with mall	M.R
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	100 mm	P	M/R
		01	Common with mall	M/R
		01	Common with mall	M/R
12	Yard Hydrants.			

McDonalds Family Restaurant "D-Mall" Shop No 25-27, Twin District Centre, Rohini, Delhi

	<ul style="list-style-type: none"> Total number of hydrants 	02	Common with mall	M.R
	<ul style="list-style-type: none"> Hose Box 	02	Common with mall	M.R
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 			
		2280LPM	Common with mall	M.R
		70 m	Common with mall	M.R
		2	Common with mall	M.R
		180 LPM	Common with mall	M.R
		70 m	Common with mall	M.R
		2280 LPM	Common with mall	M.R
		70 m	Common with mall	M.R
		R	Common with mall	M.R
		R	Common with mall	M.R
		N/A	Pump house common with "D Mall" & all pumps functional at time of inspection	M/R
		N/A		M/R
		N/A		M/R
		N/A		M/R
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity 	1,50,000 Ltr	Common with mall	M.R
	<ul style="list-style-type: none"> ➤ Draw-off connection 	R	Common with mall	M.R
	<ul style="list-style-type: none"> ➤ Fire service inlet 	R	Common with mall	M.R
	<ul style="list-style-type: none"> ➤ Access to tank 	R	Common with mall	M.R
	<ul style="list-style-type: none"> Overhead Tank capacity 	10,000 ltr	Common with mall	M/R
15	Exit Signage.	R	P	M/R
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	R	P	M.R
	<ul style="list-style-type: none"> Pressurization of Lift lobby 	R	P	M.R
	<ul style="list-style-type: none"> Communication In lift Car 	R	P	M.R
	<ul style="list-style-type: none"> Fireman's Grounding Switch 	R	P	M.R
	<ul style="list-style-type: none"> Lift Signage 	R	P	M.R

McDonalds Family Restaurant "D-Mall" Shop No 25-27, Twin District Centre, Rohini, Delhi

17	Standby power supply	R	P	M/R
	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	R	P	M.R
	• Flow Switch Panel			
	• PA System Panel	R	P	M.R
	• Batter backup	R	P	M.R
	• Building Floor Plans	R	P	M.R
20	Special Fire Protection Systems for Protection of special Risks, if any:	--	No special risk at present	--

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. **F6/DFS/MS/2012/EH/1408 Dated 19/04/2012** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

Depto (W2)

Signature of the Inspecting Officer

Name

Designation

Depto
21/5/15
DO (NW)

390/DFP(20)