

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

No.F6/MS/DFS/GH/2015/ 52/926

Dated: 04/06/15

FIRE SAFETY CERTIFICATE

Certified that the Saket27Guest House(A Unit Of BMB Resorts Pvt. Ltd.), located at J -27,Saket , New Delhi - 110017 comprised of basement ground & 03 upper floors (24 guest rooms), was granted FSC by this department vide letter No.F6/DFS/MS/GH/2012/2127 dated 12/06/2012.The premises was re-inspected by the officer concerned of this department on 25/05/2015 in the presence of Mr. Jai Bhagwan and observed that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Group-A, Residential (Lodging and Rooming House)** with effect from 04/06/15 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued 04/06/15 at New Delhi by.



(Dr. G.C. Misra)
Chief Fire Officer
Tel: 011-23414333

Copy to:-

Mr. Arun Sharma (General Manager)
Saket 27, J-27, Saket, New Delhi-110017

Handwritten initials and date
04/06/15

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building:- Saket 27 Guest House (A Unit Of BMB Resorts Pvt Ltd.), J-27, Saket, New Delhi 110017
2. Type of occupancy:- Residential (Lodging and Rooming House)
3. Type of case: -Renewal
4. Details of previous NOC: - F6/DFS/MS/GH/2012/2127 dated 12/06/12
5. Fire safety directives No.- Nil
6. Date of inspection:- 25/05/2015
7. Name of the inspecting officer:- D.B.Mukherjee, A.D.O.(BCP)
8. Name & designation of officer From the building side: - Mr. Jai Bhagwan
9. Year of construction:- 2009
- 10.Applicant's letter No:- Nil dated: 21/04/2015

Building is comprised of Basement, Ground + 03 Upper Floors .

Sl. No	Minimum Standards on fire Prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	12mtr.	Provided	MR
	2) Gate width	N/A	N/A	N/A
	3)Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01nos	Provided 01 nos.	MR
	2. Basements	02nos	Provided 02 nos.	MR
	B. Width of staircase			
	1. Upper floors	1.25m	1.25m	MR
	2. Basements	1.25m	1.25m & 1m	MR
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	Required	01 nos.	MR
	E. Width of corridor	Required	1.50m	MR
	F. Door size	1m	Provided	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	Exhaust Fan	MR
	2) Upper floors	12 a/c per hour	Exhaust Fan	MR
5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	15 Nos. Provided	MR
	2) Types		ABC, Co2	MR
	3) ISI marking		Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01 no.	Provided	MR
	2) Length of hose reel hose	30 m	Yes	MR
	3) Nozzle diameter	5 mm	Yes	MR

7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Not Required	Smoke & Heat	MR
	2) Location of main panel	Not Required	Ground Floor	MR
	3) Location of repeater panel	Not Required	Provided	MR
	4) Alternate source of power	Not Required	Provided	MR
	5) Hooter's Location	Not Required	Provided at every floor	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 lpm	Provided 02 nos.	MR
	b) Head of pump	44 mtr	44m & 44m	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	5,000 Ltrs.	Provided 10 KL	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided DG Set	MR
18.	Refuge Area			
	Total area location	N/A	N/A	N/A

19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the building were tested and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to renew the FSC issued vide letter No. F6/DFS/MS/ GH/2012/2127 dated 12/06/2012 under rules 35 of the Delhi Fire Service Rules 2010. Accordingly DFA is put up for perusal and signature pl.



Signature of the inspecting officer
 Name: - D.B.Mukherjee.
 Designation:- Assistant Divisional Officer (BCP)