

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO. F6/DFS/MS/EH/2015/SZ/ 904

Dated: 03/06/15

FIRE SAFETY CERTIFICATE

Certified that the M/S Stylish Hotels Pvt. Ltd.(Berco's Restaurant) Manish Metro Plaza-1, Plot No-1, Sector-12, Dwarka, New Delhi-110075, running at first floor of the building comprised of ground plus three upper floors was granted NOC by this department vide letter no. F6/DFS/MS/EH/2012/1884 Dated 24.5.2012. The premises have been re-inspected by the officer concerned of this department on 26.5.2015 in presence of Sh. RajKumar Dhawan (Director) and that the building is fit for occupancy class D "Assembly building (Restaurant)" with effect from...03/06/15... for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed overleaf.

Issued on ...03/06/15... at New Delhi by



(Dr. G C Misra)
Chief Fire Officer
Ph.011-23414333

Copy To:

1. DHO/West Zone, Deputy Health Office, Municipal Corporation of Delhi, Najafgarh Zone New Delhi.
2. Director, M/S Stylish Hotels Pvt. Ltd. (Berco's Restaurant) located at first floor, Manish Metro Plaza-1, Plot No-1, Sector-12, Dwarka, New Delhi-110075.

one
copy

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	M/S Stylish Hotels Pvt. Ltd. (Berco's Restaurant, First Floor, Manish Merto Plaza-1, Plot No. 1, Pocket-5, Sector-12, Dwarka, New Delhi-110075)		
2	Type of Occupancy	Assembly "D" Restaurant		
3	Type of case	Renewal		
4	Details of previous NOC	No. F-6/DFS/MS/EH/2012/1884 Dated 24.5.2012		
5	Fire safety directives letter No	Nil		
6	Date of inspection	26.5.2015		
7	Name of the inspecting Officers :	ADO S.P Bhardwaj (Dwarka)		
8	Name and designation of officers from the building side	Sh. Rajkumar Dhawan (Director)		
9	Year of construction	Ground plus Three upper Floors	<u>Restaurant Runinig at 1st Floor</u>	
10	Applicant's letter No.	Nil Dated 14.5.2015	Ground + 3 upper Floors	
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Old Case /NBC Requirement	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	Accessible	18 Mtrs.	MR
	2) Gate width	Old Case	120 Cms.	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	Old Case	One	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	Old Case	1.22 to 1.25 Mtrs.	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Requied	One	
	e. Width of corridor	Old Case	1.65 Mtrs.	MR
	f. Door size	Old Case	1.39 x 196 & 1.52 x 205 Mtrs.	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement		N/A	N/A
	upper floors	12 a/c per hour	Exhust Fans	MR

5	Fire Extinguishers			
	total numbers		4 Nos	MR
	Types		ABC, Co2,	MR
	KVA	ISI	Yes	MR
6	First-Aid Hose Reels.			
	total numbers on each floor	1 No.	Provided	MR
	Length of Hose reel hose	30 m	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system			
	Type of detectors	Heat & Smoke	Provided	MR
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	Required	DG Set 85	MR
	hooter's location	N/A	N/A	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	Required	Provided	MR
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	100 MM	100 MM	MR
	Number of Hydrants per floor	One at First Floor	One at First floor	MR
	hose Box	Required	Provided	MR
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level/			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	Old Case	450 LPM, 180 LPM	MR
	b. head of the pump	Old Case	35 Mtrs	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	Old Case	5000 ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A

N/11

17	Standby power supply	Required	Provided	MR
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: N/A			

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety requirements under the rules, renewal of Fire Safety Certificate issued vide letter no.F6/MS/EH/2012/1884 dated 24.5.2012 is recommended under rules 35 of the Delhi Fire Service Rules 2010.

Accordingly DFA is put up for approval and signature please.

Signature of the Inspecting Officer

Name

S.P Bhardwaj

Designation

ADO (DWARKA)

Sanyal
22/5/15