

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001


No. F6/DFS/MS/EH/2015/M02/943

Dated: 08/06/15

FIRE SAFETY CERTIFICATE

Certified that the The Yellow Chilli Resturant running at G-11,ground floor level of a building comprised of basement , ground plus three upper floors at Plot No.11,V3S Mall, District Centre Laxmi Nagar,Delhi-92, owned/occupied by M/s A unit of Royal Hospitality, was granted FSC vide letter no.F6/DFS/MS/EH/2012/742 dated 02.03.2012.The restaurant was inspected by the officer concerned of this department on 04.04.15. in the presence of Sh.Joginder Singh (Manager) and found that the restaurant building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of condition under rule 38 that the G-11 of building is fit for occupancy Group D Assembly Building "Restaurant" with effect from08/06/15..... for a period of three years, subject to conditions printed overleaf.

Issued on08/06/15..... at New Delhi by



(Dr. G C Misra)
Chief Fire Officer
Ph. No. 23414333

oc

To,
M/s A unit of Royal Hospitality
G-11,Ground Floor,Plot No.11,V3S Mall,
District Centre Laxmi Nagar,Delhi-92

Copy to:-
The Dy. Health Officer,
East Delhi Municipal Corporation ,Health Department,
Shahdara (South) Zone, Karkardooma, Shahdara, Delhi

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation,ventilation,structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate,six months prior to its expiry"
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building : The Yellow Chilli at G-11,GF, plot no. 10,
District Centre, Laxmi Nagar, Delhi
2. Building is comprised of : Basement, Ground + 3 upper floors.
- 3.Type of Occupancy : Assembly
- 4.Type of Case : Renewal
- 5.Details of Previous NOC letter :F6/DFS/MS/EH/2012/742 dated 02/03/2012
6. Fire Safety direction letter No : N/A
- 7.Date of Inspection : 04.04.2015
- 8.Name of the Inspecting officers : DO Virendra Singh
- 9.Name and designation of Officer
from the building side :Sh.Joginder Singh (Manager)
- 10.Year of Construction :2006
11. Applicant's letter No : Nil


S.NO.	Minimum Standards on fire prevention and fire safety U/R33	NBC/BBL Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	12 Mtrs.	36 Mtrs.& 13.8 Mtr,	MR
	• Gate width	4.5 Mtrs.	6 Mtrs.	MR
	• Width of internal road	6 Mtrs.	6 Mtr.	MR
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	B. Width of Staircases	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	c. Protection of exits	N/A	N/A	N/A
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	e. No. of continuous staircases to terrace	1no.	1 no.	MR
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	2 M	2 M & 1 M	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Sealed	MR
	• Fire rating of shaft door	0 2 hrs.	0 2 hrs.	MR
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	Required	Provided	MR
	• Upper floor	Required	Provided	MR
5.	Fire Extinguisher			
	• Total numbers	04 Nos.	06 Nos.	MR
	• Types	ABC & Co2	ABC & Co2	MR
	• IS marking	ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	• Total numbers of each floor	2 nos.	2 nos.	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	Heat & smoke	Provided	MR
	• Location of main panel	Control room	Basement	MR
	• Location of repeater panel	Security Room	Provided	MR
	• Alternate source of power	Battery & DG Set	Provided	MR
	• Hooters's location	Staircase	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• upper floor	Required	Provided	MR
	• sprinkler above false ceiling	Required	Provided	MR
11	Internal Hydrants			
	• size of riser/down-comer	150 mm	150 mm	MR
	• Number of hydrants per floor	2 nos.	2 nos.	MR
	• Hose Box	2 nos.	2 nos.	MR
12	Yard Hydrants.			
	• Total number of hydrants	5 nos.	5 nos.	MR
	• Hose Box	5 nos.	5 nos.	MR
13	Pumping Arrangements.			
	• Ground Level	Required	Provided	MR
	➤ Discharge of main Pump	2850 LPM	2850 LPM	MR
	➤ Head of Main Pump	70 Mtrs.	70 Mtrs.	MR
	➤ Number of main pumps	1 No.	1No.	MR
	➤ Jockey pump out put	180 LPM	180 LPM	MR
	➤ Jockey pump head	70 Mtrs.	70 Mtrs.	MR
	➤ Standby pump out put	2850 LPM	2850 LPM	MR
	➤ Standby pump Head	70 Mtrs	70 Mtrs	MR
	➤ Auto Starting /Manual stopping	Required	Auto	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace Level	N/A	N/A	N/A
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the Pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	1,00,000 Ltrs.	1,20,000 Ltrs.	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	20,000 Ltrs.	40,000 Ltrs.	MR

15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	Required	Provided	MR
	• Pressurization of Lift lobby	Required	Provided	MR
	• Communication in lift car	Required	Provided	MR
	• Firemen's grounding switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	Required	Provided	MR
	• Flow switch panel	Required	Provided	MR
	• PA system panel	Required	Provided	MR
	• Batter backup	Required	Provided	MR
	• Building Floor Plans	Required	provided	MR
20	Special Fire Protection systems for protection of special Risks, if any:	Required	Provided in all LT & HT Panels	MR

The fire safety arrangements provided in the building were tested/ checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire Safety measures as required under the rules. The fire safety certificate issued vide letter no.F.6/DFS/MS/EH/2012/742 dated 02.03.2012 is recommended.


 Signature of the Inspecting Officer
 Name: Virendra Singh
 Designation: DO(ED)

DCFO(NDZ)