

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F6/DFS/MS/School/2015/W2/973

Dated: 10/06/2015


**FIRE SAFETY CERTIFICATE**

Certified that Daffodil Public School, at Gali No.4, Prem Colony, Bawana Road, Narela, Delhi-110040 comprised of Ground + Two upper floor (Single block) owned/occupied by Daffodil Public School have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of Fire Service on dated 12/05/2015 in the presence of Sh. R. P. Tyagi (Principal) and that the building / premises is fit for occupancy class Group-B Education with effect from...10/06/15...for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rule,2010.

**Conditions for the validity of Fire Safety Certificate:**

- 1 All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 This certificate cannot be treated in any case for regularizations of unauthorized construction.
- 6 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 10/06/15 at New Delhi by

  
(SANTOKH SINGH)  
Chief Fire Officer  
Ph: 011-23414250

**Copy to:**

1. The Principal, Daffodil Public School, Gali No.4, Prem Nagar, Bawana Road, Narela, Delhi-110040.
2. The Director of Education, Old Secretariat, Delhi



**INSPECTION REPORT**One block  
Gr. + Two floor

1. Name & address of the building : Daffodil Public School, Gali No.4, Prem Colony, Bawana Road, Narela, Delhi-110040
  2. Type of Occupancy : Educational
  3. Type of Case : New
  4. Details of previous NOC : Letter No. nil Dated: nil
  5. Fire Safety directives letter No : DFS Act 2007 & DFS Rules 2010
  6. Date of inspection : 12/05/2015
  7. Name of the Inspecting Officers : ADO (BW)
  8. Name and designation of officers  
from the building side : Sh. R. P. Tyagi (Principal)
  9. Year of Construction : 2014 -15
  10. Applicant's letter No. : D.P.S/36/15 Dated 27/04/15
- Plot area:-5000 sq yard Covered area:-1800 sq yard No.'s of Student:-500 No.'s of Classrooms:-  
21 + 3 room for other purpose

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part IV	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Accessible	Accessible ✓	MR
	• Gate width	—	—	—
	• Width of internal road	—	—	—
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	—	—	—
	• Upper Floors	01	02 ✓	MR
	• Basements	—	—	—
	b. Width of staircases	—	—	—
	• Upper Floors	1.50 mtr	1.55 mtr & 1.50 mtr ✓	MR
	• Basements	—	—	—
	c. Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	—	—	—
		R	P ✓	MR
	g. Width of Corridor	—	—	—
	h. Door Size	1.00 mtr	1.00 mtr ✓	MR

3	<b>Compartmentation.</b>	—	—	—
	• Fire check door	—	—	—
	• Sealing of electrical shafts	—	—	—
	• Fire Rating of shaft door	—	—	—
	• Water Curtain	—	—	—
	• Fire Dampers	—	—	—
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	—	—
	• Upper floors	12 a/c per hour	—	—
5	<b>Fire Extinguishers</b>			
	• Total numbers	07 ABC	07	MR
	• Types	ISI marked	ABC	MR
	• IS marking		Yes	MR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	One	P	MR
	• Length of hose reel hose	30 m	P	MR
	• Nozzle diameter	5 mm	P	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	—	—	—
	• Location of Main Panel	—	—	—
	• Location of Repeater Panel	—	—	—
	• Alternate source of power	—	—	—
	• Hooters' Location	—	—	—
8	<b>MOEFA</b>	—	—	—
9	<b>Public Address System.</b>	—	—	—
10	<b>Automatic Sprinkler System.</b>			
	• Basement	—	—	—
	• Upper Floor	—	—	—
	• Sprinkler above false ceiling	—	—	—
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	—	—	—
	• Number of hydrants per floor	—	—	—
	• Hose Box	—	—	—

12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	—	—	—
	• Hose Box	—	—	—
13	<b>Pumping Arrangements.</b>			
	• Ground Level	—	—	—
	➤ Discharge of main Pump	—	—	—
	➤ Head of Main pump	—	—	—
	➤ Number of main pumps	—	—	—
	➤ Jockey Pump out put	—	—	—
	➤ Jockey pump head	—	—	—
	➤ Standby Pump out put	—	—	—
	➤ Standby Pump Head	—	—	—
	➤ Auto Starting/ Manual stopping	—	—	—
	➤ Pump House Access	—	—	—
	• Terrace level	—	—	—
	➤ Discharge of pump	450 LMP	P	MR
	➤ Head of the pump	40 m	P	MR
	➤ Power Supply	—	—	—
	➤ Auto Starting of pump	—	—	—
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	—	—	—
	➤ Draw-off connection	—	—	—
	➤ Fire service inlet	—	—	—
	➤ Access to tank	—	—	—
	• Overhead Tank capacity	10,000 ltr	10,000 ltr	MR
15	<b>Exit Signage.</b>	R	P	MR
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	—	—	—
	• Pressurization of Lift lobby	—	—	—
	• Communication In lift Car	—	—	—
	• Fireman's Grounding Switch	—	—	—
	• Lift Signage	—	—	—
17	<b>Standby power supply</b>	—	—	—

18	<b>Refuge Area.</b>			
	➤ Total Area	—	—	—
	➤ Location	—	—	—
19	<b>Fire Control Room</b>			
	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

**Note:-**General requirements for school as per Director of Education Circular dated...01/03/2011

1. Escape route..... **Clear** .....
2. LPG cylinders in laboratories ..... **No** .....
3. Electric wiring ..... **Concealed**.....MCB .....**Provided**.....  
Electric circuit.....**ELCB provided**.....
4. Electric meter board .....**Not Below S/C** .....
5. Basement use as per BBL 1983..... **N/A** .....
6. Emergency telephone no. board... **Displayed** .....
7. Generator set..... **No** .....

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers nil.

Signature of the Inspecting Officer

Name

Designation

Signature of the Inspecting Officer

Name

Designation



*[Handwritten signature and designation]*

*[Handwritten signature and designation: ADO (BIO)]*