

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/school/2015/w2/1995

Dated: 10/06/15

FIRE SAFETY CERTIFICATE

Certified that the **Minni Preparatory School**, located at **R-576 Rishi Nagar,,Rani Bagh, Delhi-34** comprised of Ground + 02 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/2009/3582 Dated 27/11/2009. The premises was re inspected by the officers concerned of this department on 28-04-2015 in the presence of **Sh P Sethi (Principal)** and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 262-362 Dated 17-01-2005 and that the premises is fit for occupancy class "Educational" Group B with effect from 10/06/15 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 10/06/15 at New Delhi by.


(Santokh Singh)
Chief Fire Officer
PH 011-23414250

Copy to:

1. The Principal, Minni Preparatory School, R-576, Rishi Nagar, Rani Bagh, Delhi-34

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The basement shall be used strictly as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Minni Preparatory School, R-576, Rishi Nagar, Rani bagh, Delhi-34
2. Type of Occupancy : Educational Total one Blocks(Ground + 2Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F-6/DFS/MS/2009/3582 Dated 27/11/2009
5. Fire Safety directives Letter No. : DOE circular 262-362 dated 17-01-2005
6. Date of inspection : 28/04/2015
7. Name of the Inspecting Officer : Udaivir singh ADO
8. Name and designation of Officer from the building side : Sh. P Sethi (Principal)
9. Year of Construction : 2001
10. Applicant's letter No. : Nil Dated 06/04/2015

Plot Area - 100 M²
 Covered Area - 100 M²
 No. of Class Rooms-12
 No. of Student- 160

| S No | Minimum standards on fire prevention and fire safety U/R 33 | Cr.No.262-362 dated 17-1-05 | Provided at site | Remarks | | | | | | | | | |
|------------|--|---|---|----------|----|------------|---------|----|----|----|----|--|--|
| 1. | Access of building | | | MR/NMR | | | | | | | | | |
| | <ul style="list-style-type: none"> • Road width • Gate width • Width of internal road | <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;">Accessible</td> <td style="width: 30%;">Provided</td> <td style="width: 40%;">MR</td> </tr> <tr> <td>Accessible</td> <td>On Road</td> <td>MR</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> </table> | Accessible | Provided | MR | Accessible | On Road | MR | NA | NA | NA | | |
| Accessible | Provided | MR | | | | | | | | | | | |
| Accessible | On Road | MR | | | | | | | | | | | |
| NA | NA | NA | | | | | | | | | | | |
| 2. | Number, width, Type & Arrangements of exits | | | | | | | | | | | | |
| | a. Number of staircases | 2 | Provided | MR | | | | | | | | | |
| | • Upper floors | NA | NA | NA | | | | | | | | | |
| | • Basements | | | | | | | | | | | | |
| | b. Width of staircases | 1.5mtrs | 90cm & 120cm | MR | | | | | | | | | |
| | • Upper floors | NA | NA | NA | | | | | | | | | |
| | • Basements | | | | | | | | | | | | |
| | c. Protection of exits | NA | NA | NA | | | | | | | | | |
| | • Fire check door | NA | NA | NA | | | | | | | | | |
| | • Pressurization | NA | NA | NA | | | | | | | | | |
| | d. No of continuous staircase to terrace | 1 | Provided | MR | | | | | | | | | |
| | e. Width Of Corridor | NA | NA | NA | | | | | | | | | |
| | f. Door Size | 1mtr | Old Case (all class rooms have less than 45 students) | Old Case | | | | | | | | | |
| 3. | Compartmentation | | | | | | | | | | | | |
| | • Fire check door | NA | NA | NA | | | | | | | | | |
| | • Sealing of electrical shafts | NA | NA | NA | | | | | | | | | |
| | • Fire Rating of shaft door | NA | NA | NA | | | | | | | | | |
| | • Water Curtain | NA | NA | NA | | | | | | | | | |
| | • Fire Dampers | NA | NA | NA | | | | | | | | | |

| | | | | |
|-----|---|--|--|----------------------------|
| 4. | Smoke managements System | | | |
| | <ul style="list-style-type: none"> Basements Upper floors | NA | NA | NA |
| | | NA | NA | NA |
| 5. | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> Total numbers Types IS marking | 6nos. ABC & CO ₂ ISI marked | <input checked="" type="checkbox"/> Provided <input checked="" type="checkbox"/> Provided <input checked="" type="checkbox"/> Provided | MR MR MR |
| 6. | First – Aid Hose Reels | | | |
| | <ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter | 1 30m 5mm | <input checked="" type="checkbox"/> Provided <input checked="" type="checkbox"/> Provided <input checked="" type="checkbox"/> Provided | MR MR MR |
| 7. | Automatic fire detection and alarming system | | | |
| | <ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location | NA NA NA NA NA | NA NA NA NA NA | NA NA NA NA NA |
| 8. | MOEFA | Required | Provided | MR |
| 9. | Public Address System | Required | Provided | MR |
| 10. | Automatic Sprinkler System | | | |
| | <ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling | NA NA NA | NA NA NA | NA NA NA |
| 11. | Internal Hydrants: | | | |
| | <ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box | 100mm 01 01 | <input checked="" type="checkbox"/> Provided <input checked="" type="checkbox"/> Provided <input checked="" type="checkbox"/> Provided | MR MR MR |
| 12. | Yard Hydrants | | | |
| | <ul style="list-style-type: none"> Total number of hydrants Hose Box | NA NA | NA NA | NA NA |
| 13. | Pumping Arrangements: | | | |
| | <ul style="list-style-type: none"> Ground Level Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put | NA NA NA NA | NA NA NA NA | NA NA NA NA |

| | | | | |
|-----|--|----------|----------|----|
| | ➤ Jockey pump head | NA | NA | NA |
| | ➤ Standby Pump out put | NA | NA | NA |
| | ➤ Standby Pump Head | NA | NA | NA |
| | ➤ Auto Staring/Manual stopping | NA | NA | NA |
| | ➤ Pump House Access | NA | NA | NA |
| | • Terrace level | | | |
| | ➤ Discharge of pump | 450 lpm | Provided | MR |
| | ➤ Head of the pump | 40Mtr | Provided | MR |
| | ➤ Power supply | Required | Provided | MR |
| | ➤ Auto starting of pump | Required | Provided | MR |
| 14. | Captive water Storage for fire fighting: | | | |
| | • Under ground tank capacity | NA | NA | NA |
| | ➤ Draw off connection | NA | NA | NA |
| | ➤ Fire service inlet | NA | NA | NA |
| | ➤ Access to tank | NA | NA | NA |
| | • Overhead Tank capacity | 5,000Ltr | Provided | MR |
| 15 | Exit Signage | Required | Provided | MR |
| 16. | Provision of Lifts | | | |
| | ➤ Pressurization of Lift Shaft | NA | NA | NA |
| | ➤ Pressurization of lift lobby | NA | NA | NA |
| | ➤ Communication in lift Car | NA | NA | NA |
| | ➤ Fireman's Grounding Switch | NA | NA | NA |
| | ➤ Lift Signage | NA | NA | NA |
| 17. | Standby power supply | NA | NA | NA |
| 18. | Refuge Area | | | |
| | ➤ Total area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |
| 19. | Fire control room | | | |
| | ➤ Detector system panel | NA | NA | NA |
| | ➤ Flow Switch Panel | NA | NA | NA |
| | ➤ PA System Panel | NA | NA | NA |
| | ➤ Battery backup | NA | NA | NA |
| | ➤ Building Floor Plans | NA | NA | NA |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | NA | NA | NA |

Note:-General requirements for schools as per Director of Education circular dated 01/03/2011.

1. Escape route Clear.....

2. LPG cylinders in laboratories ; NA
3. Electric wiring ...Conduit Wiring ✓ MCB and ELCB
Electric circuit
4. Electric meter boardNot under the staircase. ✓
5. Basement use as per BBL 1983 ... NA ✓
6. Emergency telephone no. boardDisplayed.. ✓
7. Generator set NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/2009/3582 Dated 27/11/2009 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

 Officer

Name Uda Vir Singh
 Designation ~~ADWP~~

Signature of the Inspecting

Name

Designation