

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI- 110001

No. F6/DFS/MS/school/2015/NO2/993

Dated: 10/06/15

FIRE SAFETY CERTIFICATE

Certified that the Shri Ram Vidya Mandir School at Shri Siddh Hanuman Mandir, Mandawali Fazal Pur, Delhi-92, owned/occupied by Shri Ram Vidya Mandir School comprised of ground plus two upper floors was issued NOC vide letter no. No.F.6/MS/DFS/2006/2422 dated 11.09.2006. The school building was inspected by the officer concerned of this department on 12.05.2015 in the presence of Manager school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular no.F.16/Estate/CC/FS/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education and found that the GF+FF +SF of building is fit for occupancy class B "Educational Building" with effect from 10/06/15 for a period of three years, subject to conditions printed overleaf.

Issued on 10/06/15 at New Delhi by



(Dr.G.C.Misra)  
Chief Fire Officer  
Ph.011-23414333

o/c  
RK

To,  
The Manager  
Shri Ram Vidya Mandir School  
Shri Siddh Hanuman Mandir, Mandawali Fazal Pur, Delhi-92,

Copy to:-  
The Dy. Director of Education  
East Delhi Municipal Corporation  
Udyog Sadan, 419, FIE, Patparganj, Delhi.

**- Conditions -**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
- 6 . "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate,six months prior to its expiry"
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

## INSPECTION REPORT

1. Name & address of the building : Shree Ram Vidya Mandir School, Shri Siddh Hanuman Mandir, Fazalpur, Delhi-92
2. Building is comprised of : G+2
3. Type of Occupancy : Educational
4. Type of Case : **Renewal**
5. Details of Previous NOC : Letter No- F6//MS/DFS/2006/2422 Dated 11.09.2006
6. Fire Safety direction letter No : F.16/Estate/CC/Fire safety/2011/3298 to 3398  
Dated. 01.03.11
7. Date of Inspection : 12.05.2015
8. Name of the Inspecting Officers: : R.K.Yadav (ADO)
9. Name of the designation of Officer  
from the building side : Manager
10. Year of Construction : 1974
11. Applicant's letter No : SRVM/2014 dated 09/04/15

S.No	Minimum Standards on fire safety requirements as per circular no. 3298 to 3398 dated 01.03.11	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	4 m	Old Case/MR
	Gate width	N.A.	N.A.	N.A.
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	Upper Floor	1 no.	2 no.	MR
	Basement	N.A.	N.A.	N.A.
	B. Width of Staircases			
	Upper Floor	1.5 m	1.05 m, 1 m	MR
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits			
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	1 no.	1 no.	MR
	g. Width of Corridor	1.5 m	1.5 m	MR
	h. Door Size	1 m	1 m	MR
3	Compartmentation.			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	30a/c per hour	N.A.	N.A.
	Upper floor	12a/c per hour	N.A.	N.A.

5.	Fire Extinguisher			
	Total numbers	6 no.	6 no.	MR
	types	ABC+ CO <sub>2</sub>	ABC+ CO <sub>2</sub>	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total number of each floor	01 no.	1 no	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	MOEFA	N.A.	N.A.	N.A.
9	Public address System.	N.A.	Provided	MR
10	Automatic Sprinkler System.			
	Basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	N.A.	N.A.	N.A.
	Number of hydrants each floor	N.A.	N.A.	N.A.
	Hose box each floor	N.A.	N.A.	N.A.
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
		40 m	40 m	MR
	➤ Head of the Pump	Required	Provided	MR
	➤ Power supply			
	➤ Auto Starting of pump	Required	Provided	MR

N/S

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	10,000 Liters	10,000 Liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	N.A.	N.A.	N.A.
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The NOC issued vide letter no. F.6/MS/DFS/2006/2422 Dated 11.09.2006 renewal under the circular no. F.16/Estate/CC/FS/2011/3298 to 3398 dated 1.3.11 is recommended fire safety certificate.

*R. K. Yadav*  
 Signature of the Inspecting Officer 3/6/2015

Name:-R.K.Yadav  
 Designation:-ADO (LN)

DO(ED)

*Sub...*